

INTERNATIONAL STANDARD

NORME INTERNATIONALE

Boxes and enclosures for electrical accessories for household and similar fixed electrical installations –

Part 1: General requirements

Boîtes et enveloppes pour appareillage électrique pour installations électriques fixes pour usages domestiques et analogues –

Partie 1: Exigences générales

IECNORM.COM : Click to view the full PDF of IEC 60670-1:2015



THIS PUBLICATION IS COPYRIGHT PROTECTED

Copyright © 2015 IEC, Geneva, Switzerland

All rights reserved. Unless otherwise specified, no part of this publication may be reproduced or utilized in any form or by any means, electronic or mechanical, including photocopying and microfilm, without permission in writing from either IEC or IEC's member National Committee in the country of the requester. If you have any questions about IEC copyright or have an enquiry about obtaining additional rights to this publication, please contact the address below or your local IEC member National Committee for further information.

Droits de reproduction réservés. Sauf indication contraire, aucune partie de cette publication ne peut être reproduite ni utilisée sous quelque forme que ce soit et par aucun procédé, électronique ou mécanique, y compris la photocopie et les microfilms, sans l'accord écrit de l'IEC ou du Comité national de l'IEC du pays du demandeur. Si vous avez des questions sur le copyright de l'IEC ou si vous désirez obtenir des droits supplémentaires sur cette publication, utilisez les coordonnées ci-après ou contactez le Comité national de l'IEC de votre pays de résidence.

IEC Central Office
3, rue de Varembe
CH-1211 Geneva 20
Switzerland

Tel.: +41 22 919 02 11
Fax: +41 22 919 03 00
info@iec.ch
www.iec.ch

About the IEC

The International Electrotechnical Commission (IEC) is the leading global organization that prepares and publishes International Standards for all electrical, electronic and related technologies.

About IEC publications

The technical content of IEC publications is kept under constant review by the IEC. Please make sure that you have the latest edition, a corrigenda or an amendment might have been published.

IEC Catalogue - webstore.iec.ch/catalogue

The stand-alone application for consulting the entire bibliographical information on IEC International Standards, Technical Specifications, Technical Reports and other documents. Available for PC, Mac OS, Android Tablets and iPad.

IEC publications search - www.iec.ch/searchpub

The advanced search enables to find IEC publications by a variety of criteria (reference number, text, technical committee,...). It also gives information on projects, replaced and withdrawn publications.

IEC Just Published - webstore.iec.ch/justpublished

Stay up to date on all new IEC publications. Just Published details all new publications released. Available online and also once a month by email.

Electropedia - www.electropedia.org

The world's leading online dictionary of electronic and electrical terms containing more than 30 000 terms and definitions in English and French, with equivalent terms in 15 additional languages. Also known as the International Electrotechnical Vocabulary (IEV) online.

IEC Glossary - std.iec.ch/glossary

More than 60 000 electrotechnical terminology entries in English and French extracted from the Terms and Definitions clause of IEC publications issued since 2002. Some entries have been collected from earlier publications of IEC TC 37, 77, 86 and CISPR.

IEC Customer Service Centre - webstore.iec.ch/csc

If you wish to give us your feedback on this publication or need further assistance, please contact the Customer Service Centre: csc@iec.ch.

A propos de l'IEC

La Commission Electrotechnique Internationale (IEC) est la première organisation mondiale qui élabore et publie des Normes internationales pour tout ce qui a trait à l'électricité, à l'électronique et aux technologies apparentées.

A propos des publications IEC

Le contenu technique des publications IEC est constamment revu. Veuillez vous assurer que vous possédez l'édition la plus récente, un corrigendum ou amendement peut avoir été publié.

Catalogue IEC - webstore.iec.ch/catalogue

Application autonome pour consulter tous les renseignements bibliographiques sur les Normes internationales, Spécifications techniques, Rapports techniques et autres documents de l'IEC. Disponible pour PC, Mac OS, tablettes Android et iPad.

Recherche de publications IEC - www.iec.ch/searchpub

La recherche avancée permet de trouver des publications IEC en utilisant différents critères (numéro de référence, texte, comité d'études,...). Elle donne aussi des informations sur les projets et les publications remplacées ou retirées.

IEC Just Published - webstore.iec.ch/justpublished

Restez informé sur les nouvelles publications IEC. Just Published détaille les nouvelles publications parues. Disponible en ligne et aussi une fois par mois par email.

Electropedia - www.electropedia.org

Le premier dictionnaire en ligne de termes électroniques et électriques. Il contient plus de 30 000 termes et définitions en anglais et en français, ainsi que les termes équivalents dans 15 langues additionnelles. Egalement appelé Vocabulaire Electrotechnique International (IEV) en ligne.

Glossaire IEC - std.iec.ch/glossary

Plus de 60 000 entrées terminologiques électrotechniques, en anglais et en français, extraites des articles Termes et Définitions des publications IEC parues depuis 2002. Plus certaines entrées antérieures extraites des publications des CE 37, 77, 86 et CISPR de l'IEC.

Service Clients - webstore.iec.ch/csc

Si vous désirez nous donner des commentaires sur cette publication ou si vous avez des questions contactez-nous: csc@iec.ch.

INTERNATIONAL STANDARD

NORME INTERNATIONALE

**Boxes and enclosures for electrical accessories for household and similar fixed electrical installations –
Part 1: General requirements**

**Boîtes et enveloppes pour appareillage électrique pour installations électriques fixes pour usages domestiques et analogues –
Partie 1: Exigences générales**

INTERNATIONAL
ELECTROTECHNICAL
COMMISSION

COMMISSION
ELECTROTECHNIQUE
INTERNATIONALE

ICS 29.120.10

ISBN 978-2-8322-2337-6

Warning! Make sure that you obtained this publication from an authorized distributor. Attention! Veuillez vous assurer que vous avez obtenu cette publication via un distributeur agréé.
--

CONTENTS

FOREWORD	5
1 Scope	7
2 Normative references	7
3 Terms and definitions	8
4 General requirements	11
5 General notes on tests	11
6 Ratings	11
7 Classification	12
8 Marking	13
9 Dimensions	14
10 Protection against electric shock	14
11 Provision for earthing	15
11.1 Boxes and enclosures with exposed conductive parts	15
11.2 Boxes and enclosures of insulating material classified according to 7.2.2.2 and 7.2.2.3	16
11.3 Boxes or enclosures with removable sides according to 7.1.2	17
11.4 Earthing terminal threads	17
12 Construction	18
12.1 General	18
12.2 Lids, covers or cover-plates or parts of them	18
12.2.1 General	18
12.2.2 Screw-type fixing	18
12.2.3 Non-screw-type fixing operable without the use of a tool or a key	18
12.2.4 Non screw-type fixing operable with the use of a tool or a key	24
12.3 Drain holes	25
12.4 Mounting of enclosures	25
12.5 Boxes and enclosures with inlets for flexible cables	25
12.6 Boxes and enclosures with inlets for applications other than flexible cables	25
12.7 Boxes and enclosures with a cable anchorage(s)	26
12.8 Boxes and enclosures with cable retention means	27
12.9 Knock-outs intended to be removed by mechanical impact	28
12.9.1 General	28
12.9.2 Knock-out retention	28
12.9.3 Knock-out removal	28
12.9.4 Flat surfaces surrounding knock-outs	29
12.10 Screw fixings	29
12.11 Fixing of boxes and enclosures classified according to 7.2.1	30
12.12 Fixing of flush type and semi-flush type boxes and enclosures classified according to 7.2.2.1	33
12.13 Boxes and enclosures classified according to 7.2.2.2 and 7.2.2.3	34
12.13.1 General	34
12.13.2 Boxes intended for mounting on a wood structural member of a wall	35
12.13.3 Boxes intended for mounting to a wooden structural member of a ceiling	35
12.13.4 Boxes intended for mounting to a steel-stud structural member of a wall	35

12.13.5	Internal volume of boxes and enclosures classified according to 7.2.2.2 and 7.2.2.3	36
12.13.6	Boxes intended for mounting in a finished structure	37
12.14	Cable gland entry.....	37
12.15	Boxes and enclosures with inlets (outlets) or spouts (hubs) for conduits	38
12.16	Internal volume of boxes and enclosures	38
13	Resistance to ageing, protection against ingress of solid objects and against harmful ingress of water	39
13.1	Resistance to ageing	39
13.2	Protection against the ingress of solid objects.....	41
13.3	Protection against harmful ingress of water.....	42
14	Insulation resistance and electric strength	47
15	Mechanical strength	49
15.1	General.....	49
15.2	Impact test at low temperature	49
15.3	Compression test.....	50
15.4	Impact test for boxes and enclosures	51
15.5	Compression test for enclosures made of natural or synthetic rubber or a mixture of both.....	56
16	Resistance to heat.....	58
16.1	Parts of insulating material necessary to retain current-carrying parts.....	58
16.2	Parts of insulating material not necessary to retain current-carrying parts.....	59
16.3	Boxes and enclosures of insulating materials classified according to 7.2.2.2 or 7.2.2.3	59
16.3.1	Mechanical strength.....	59
16.3.2	Parts of insulating material necessary to retain parts of the earthing circuit	60
17	Creepage distances, clearances and distances through sealing compound.....	60
18	Resistance of insulating material to abnormal heat and fire	61
19	Resistance to tracking	63
20	Resistance to corrosion	63
21	Electromagnetic compatibility (EMC)	63
Annex A (informative)	Examples of enclosures and parts thereof	64
Bibliography		65
Figure 1	– Examples of membranes and grommets	10
Figure 2	– Demonstration of the non-penetration of the internal volume	15
Figure 3	– Earthing strap	16
Figure 4	– Test strap.....	17
Figure 5	– Arrangement for test on covers or cover-plates (see 12.2.3.2 and 12.2.3.3)	20
Figure 6	– Gauge for the verification of the outline of lids, covers or cover-plates	21
Figure 7	– Examples of application of the gauge of Figure 6 on covers fixed without screws on a mounting surface or supporting surface.....	22
Figure 8	– Compliance criteria of application of the gauge of Figure 6	23
Figure 9	– Gauge for verification of grooves, holes and reverse tapers	24
Figure 10	– Sketch showing the direction of application of the gauge of Figure 9	24
Figure 11	– Apparatus for testing the cable anchorage	27

Figure 12 – Example of mounting block for boxes to be embedded in masonry (flush type and semi-flush type).....	32
Figure 13 – Example of the fixing of the auxiliary device mounted on a specimen	32
Figure 14 – Example of test apparatus for the test	33
Figure 15 – Verification of fixing means for boxes and enclosures classified according to 7.2.2.1	34
Figure 16 – Test of the force and measurement of the displacement.....	36
Figure 17 – Volume measurement.....	39
Figure 18 – Reference surfaces for boxes and enclosures	43
Figure 19 – Test wall	45
Figure 20 – Example of the protected volume	47
Figure 21 – Apparatus for impact test at low temperature.....	50
Figure 22 – Mounting block for flush-type boxes and enclosures in order to apply blows on the rear surface.....	52
Figure 23 – Sequence of blows for parts A, B, C, D, E, F and G	55
Figure 24 – Test devices for load compression test for enclosures made of natural or synthetic rubber or a mixture of both.....	58
Figure 25 – Rigid crossbar	60
Figure 26 – Diagrammatic representation of the glow-wire test	62
Figure A.1 – Examples of enclosures and parts thereof.....	64
Table 1 – Classification of boxes and enclosures (1 of 2).....	12
Table 2 – Forces to be applied to lids, covers, cover-plates or actuating members whose fixing is not dependent on screws	19
Table 3 – Forces and torques to be applied to cable anchorages	26
Table 4 – Tightening torques for the verification of the mechanical strength of screws	30
Table 5 – Torque test values for cable glands	38
Table 6 – Test voltage for electric strength test.....	48
Table 7 – Determination of parts A, B, C, D, E, F and G.....	52
Table 8 – Height of fall for impact test.....	53

INTERNATIONAL ELECTROTECHNICAL COMMISSION

**BOXES AND ENCLOSURES FOR ELECTRICAL ACCESSORIES FOR
HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –****Part 1: General requirements****FOREWORD**

- 1) The International Electrotechnical Commission (IEC) is a worldwide organization for standardization comprising all national electrotechnical committees (IEC National Committees). The object of IEC is to promote international co-operation on all questions concerning standardization in the electrical and electronic fields. To this end and in addition to other activities, IEC publishes International Standards, Technical Specifications, Technical Reports, Publicly Available Specifications (PAS) and Guides (hereafter referred to as "IEC Publication(s)"). Their preparation is entrusted to technical committees; any IEC National Committee interested in the subject dealt with may participate in this preparatory work. International governmental and non-governmental organizations liaising with the IEC also participate in this preparation. IEC collaborates closely with the International Organization for Standardization (ISO) in accordance with conditions determined by agreement between the two organizations.
- 2) The formal decisions or agreements of IEC on technical matters express, as nearly as possible, an international consensus of opinion on the relevant subjects since each technical committee has representation from all interested IEC National Committees.
- 3) IEC Publications have the form of recommendations for international use and are accepted by IEC National Committees in that sense. While all reasonable efforts are made to ensure that the technical content of IEC Publications is accurate, IEC cannot be held responsible for the way in which they are used or for any misinterpretation by any end user.
- 4) In order to promote international uniformity, IEC National Committees undertake to apply IEC Publications transparently to the maximum extent possible in their national and regional publications. Any divergence between any IEC Publication and the corresponding national or regional publication shall be clearly indicated in the latter.
- 5) IEC itself does not provide any attestation of conformity. Independent certification bodies provide conformity assessment services and, in some areas, access to IEC marks of conformity. IEC is not responsible for any services carried out by independent certification bodies.
- 6) All users should ensure that they have the latest edition of this publication.
- 7) No liability shall attach to IEC or its directors, employees, servants or agents including individual experts and members of its technical committees and IEC National Committees for any personal injury, property damage or other damage of any nature whatsoever, whether direct or indirect, or for costs (including legal fees) and expenses arising out of the publication, use of, or reliance upon, this IEC Publication or any other IEC Publications.
- 8) Attention is drawn to the Normative references cited in this publication. Use of the referenced publications is indispensable for the correct application of this publication.
- 9) Attention is drawn to the possibility that some of the elements of this IEC Publication may be the subject of patent rights. IEC shall not be held responsible for identifying any or all such patent rights.

International Standard IEC 60670-1 has been prepared by subcommittee SC 23B: Plugs, socket-outlets and switches, of IEC technical committee 23: Electrical accessories.

This second edition cancels and replaces the first edition published in 2002 and its Amendment 1:2011. This edition constitutes a technical revision.

This edition includes the following significant technical changes with respect to the previous edition: Review of classification Table 1.

The text of this standard is based on the following documents:

FDIS	Report on voting
23B/1176/FDIS	23B/1184/RVD

Full information on the voting for the approval of this standard can be found in the report on voting indicated in the above table.

This publication has been drafted in accordance with the ISO/IEC Directives, Part 2.

In this publication, the following print types are used:

In this standard, the following print types are used:

- requirements proper: in roman type;
- *test specifications: in italic type;*
- explanatory matter: in smaller roman type.

A list of all parts in the IEC 60670 series, published under the general title *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations* can be found on the IEC website.

The committee has decided that the contents of this publication will remain unchanged until the stability date indicated on the IEC website under "<http://webstore.iec.ch>" in the data related to the specific publication. At this date, the publication will be

- reconfirmed,
- withdrawn,
- replaced by a revised edition, or
- amended.

BOXES AND ENCLOSURES FOR ELECTRICAL ACCESSORIES FOR HOUSEHOLD AND SIMILAR FIXED ELECTRICAL INSTALLATIONS –

Part 1: General requirements

1 Scope

This part of IEC 60670 applies to boxes, enclosures and parts of enclosures (hereafter called “boxes” and “enclosures”) for electrical accessories with a rated voltage not exceeding 1 000 V a.c. and 1 500 V d.c. intended for household or similar fixed electrical installations, either indoors or outdoors.

Boxes and enclosures complying with this standard are suitable for use at ambient temperatures not normally exceeding +40 °C, but their average over a period of 24 h does not exceed +35 °C, with a lower limit of the ambient air temperature of –5 °C.

During the installation the temperature may be outside the above temperature range according to the classification of the boxes and the enclosures.

This International Standard is intended to apply to boxes and enclosures for electrical accessories within the scope of IEC technical committee 23.

This standard may be used as a reference document for other IEC technical committees and subcommittees.

A box or an enclosure which is an integral part of an electrical accessory and provides protection for that accessory against external influences (for example mechanical impact, ingress of solid objects or water, etc.) is covered by the relevant standard for such an accessory.

This standard does not apply to

- ceiling roses;
- luminaire supporting couplers;
- boxes, enclosures and parts of enclosures specifically designed to be used for cable trunking and ducting systems complying with IEC 61084 and which are not intended to be installed outside of these systems.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

IEC 60068-2-75:1997¹, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

¹ First edition. This edition has been replaced in 2014 by IEC 60068-2-75:2014, *Environmental testing – Part 2-75: Tests – Test Eh: Hammer tests*

IEC 60112:2003, *Method for the determination of the proof and the comparative tracking indices of solid insulating materials*

IEC 60423:2007, *Conduit systems for cable management – Outside diameters of conduits for electrical installations and threads for conduits and fittings*

IEC 60529:1989, *Degrees of protection provided by enclosures (IP Code)*

IEC 60529:1989/AMD1:1999/AMD2:2013, *Degrees of protection provided by enclosures (IP Code)*

IEC 60695-2-11:2000², *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products*

IEC 60695-10-2:2003³, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test*

IEC 60981:2004, *Extra-heavy duty rigid steel conduits*

IEC 61032:1997, *Protection of persons and equipment by enclosures – Probes for verification*

IEC 61140:2001, *Protection against electric shock – Common aspects for installation and equipment*

IEC 61140:2001/AMD1:2004, *Protection against electric shock – Common aspects for installation and equipment*

ISO/IEC Guide 51, *Safety aspects – Guidelines for their inclusion in standards*

3 Terms and definitions

For the purposes of this document, the following terms and definitions apply.

3.1

enclosure

combination of parts, such as boxes, covers, cover-plates, lids, box extensions, accessories, etc., providing after assembly and installation as in normal use, an appropriate protection against external influences, and a defined protection against contact with enclosed live parts from any accessible direction

Note 1 to entry: See Annex A.

3.2

box

part of an enclosure provided with means for fixing a cover, cover-plate, accessory, etc., and intended to receive accessories (such as socket-outlets, switches, etc.)

3.3

box extension

part of an enclosure which is intended to extend a box for the purpose of either increasing the internal volume of the box or enclosure or to adjust for mounting the box flush or semi-flush with the finished surface of a wall or the like

² First edition. This edition has been replaced in 2014 by IEC 60695-2-11:2014, *Fire hazard testing – Part 2-11: Glowing/hot-wire based test methods – Glow-wire flammability test method for end-products (GWEPT)*

³ Second edition. This edition has been replaced in 2014 by IEC 60695-10-2:2014, *Fire hazard testing – Part 10-2: Abnormal heat – Ball pressure test method*

3.4**lid****cover****cover-plate**

part of an enclosure, not integral with or part of an accessory, which may either retain an accessory in position or enclose it

3.5**raised cover**

cover intended for mounting directly onto a box to provide for the attachment of accessories and to increase the internal volume of the enclosure

Note 1 to entry: The centre portion of the cover is raised to accommodate a specific wall or ceiling thickness and to permit the mounting of the accessory on it, flush with the surface of the wall or ceiling.

3.6**exposed conductive part**

conductive part of electrical equipment, which can be touched and which is not normally live, but which can become live when basic insulation fails

3.7**surface mounting box or enclosure**

box or enclosure which is intended for mounting on a surface

Note 1 to entry: See Annex A.

3.8**flush-mounting box or enclosure**

box or enclosure which is intended for mounting flush with the surface

Note 1 to entry: See Annex A.

3.9**semi-flush mounting box or enclosure**

box or enclosure which is intended to fit within a mounting surface and partially projects from the mounting surface

3.10**cable gland**

device designed to permit the entry of a cable, flexible cable or insulated conductor into an enclosure, and which provides sealing and retention and eventually may also provide other functions such as earthing, bonding, insulation, cable guarding, strain relief or a combination of these

3.11**seal**

material used to fill up the space between the inside of a gland and the cable passing through, usually compressed by the gland and thereby forming a joint

3.12**gasket**


material introduced between mating surfaces of an enclosure which in compression forms a joint

3.13**grommet**

component used to support and protect the cable or conduit at the point of entry, which may also prevent the ingress of moisture or contaminants

Note 1 to entry: See Figure 1.

[SOURCE: IEC 60050-581:2008, 581-27-19, modified]



Key

- 1 box
- 2 entry membrane
- 3 enclosure
- 4 protective membrane
- 5 grommet

Figure 1 – Examples of membranes and grommets

3.14

entry membrane

component or an integral part of an enclosure used to protect the cable which may be used to support the cable or conduit at the point of entry

Note 1 to entry: An entry membrane may also prevent the ingress of moisture or contaminants and may be part of a grommet (see Figure 1).

3.15

protecting membrane

component or an integral part of an enclosure that is not intended to be penetrated in normal use and is intended to provide protection against ingress of water or solid objects and/or to allow the operation of an accessory

Note 1 to entry: See Figure 1.

3.16

composite material

combination of metal and insulating material

3.17

spout

hub

open entry of a box permitting the insertion and containment of a conduit

3.18

cable retention

ability to limit the displacement of a fitted cable against pull forces

3.19**cable anchorage**

ability to limit the displacement of a fitted flexible cable against pull and push forces and torques

3.20**blanking-plug**

component used to close an open inlet or an open knock out

4 General requirements

Boxes and enclosures shall be so designed and constructed that, in normal use, their performance is reliable and safety is achieved by reducing risk to a tolerable level, as defined in ISO/IEC Guide 51.

Compliance is checked by meeting all the relevant requirements and tests specified.

5 General notes on tests

5.1 Tests according to this standard are type tests.

Unless otherwise specified, boxes and enclosures are tested as delivered.

Accessories complying with other standards are not tested again.

Tests on boxes and enclosures of insulating material shall be performed after a preconditioning of at least 10 days at ambient temperature and relative air humidity of between 45 % and 85 %.

Unless otherwise specified, the tests are carried out in the order of the clauses, at an ambient temperature between +15 °C and +35 °C on a set of three specimens.

In case of doubt, the tests are made at an ambient temperature of $+(20 \pm 5)$ °C on a set of three new specimens.

5.2 The specimens are submitted to all the relevant tests and the requirements are satisfied if all the tests are met.

If one of the specimens does not satisfy a test due to an assembly or a manufacturing fault, that test and any preceding ones which may have influenced the results of the test shall be repeated and also the tests which follow shall be made in the required sequence on another full set of specimens, all of which shall comply with the requirements.

NOTE When submitting the first set of specimens, the applicant can also submit the additional set of specimens which may be necessary, should one specimen fail. The testing station will then, without further request, test the additional set of specimens and will only reject if a further failure occurs. If the additional set of specimens is not submitted at the same time, the failure of one specimen will entail rejection.

6 Ratings

See the relevant part of Parts 21 to 24 of the IEC 60670 series.

7 Classification

Boxes and enclosures are classified according to Table 1. (All classification references used in this document, directly refer to this table).

Table 1 – Classification of boxes and enclosures (1 of 2)

Classification criteria		
7.1 The nature of their material	7.1.1 Insulating	
	7.1.2 Metallic	
	7.1.3 Composite	
	7.1.4 Natural or synthetic rubber or a mixture of both	
7.2 The type of installation	7.2.1 Flush, semi-flush in solid walls, ceilings or floors	7.2.1.1 Not suitable for installation into concrete
		7.2.1.2 Suitable for installation into concrete with a maximum temperature during the casting process of +60 °C
		7.2.1.3 Suitable for installation into concrete with a maximum temperature during the casting process of +90 °C
	7.2.2 Flush or semi-flush in hollow walls, hollow ceilings, hollow floors or furniture	7.2.2.1 Class Ha
		7.2.2.2 Class Hb for walls
		7.2.2.3 Class Hb for ceilings
	7.2.3 Surface mounting on walls, ceilings, floors or furniture	
7.3 The type(s) of inlets (outlets) ^a	7.3.1 With inlets for sheathed cables for fixed installations	
	7.3.2 With inlets for flexible cables	
	7.3.3 With inlets for plain or corrugated conduits	
	7.3.4 With inlets for threaded conduits	
	7.3.5 With inlets for other types of conductors/cables or conduits	
	7.3.6 With spouts (hub)	
	7.3.7 Without inlets. Inlet openings will be made during installation	
7.4 The clamping means	7.4.1 With cable retention	
	7.4.2 With cable anchorage	
	7.4.3 With clamping means for flexible conduit	
	7.4.4 Without clamping means	
7.5 The minimum temperature during installation	7.5.1 –5 °C	
	7.5.2 –15 °C	
	7.5.3 –25 °C	

Table 1 (2 of 2)

Classification criteria		
7.6 The degree of protection against access to hazardous parts and against harmful effects due to the ingress of solid foreign objects according to IEC 60529 with a minimum degree of IP 2X		
7.7 The degree of protection against harmful effects due to the ingress of water according to IEC 60529		
7.8 The degree of protection of the part mounted inside the hollow walls of the boxes classified according to 7.2.2.1	7.8.1 IP 2X	
	7.8.2 > IP2X	
7.9 The provision for fixing accessories to boxes	7.9.1 Boxes supplied with screws	
	7.9.2 Boxes intended to receive screws	
	7.9.3 Boxes intended to receive claws	
	7.9.4 Boxes intended to receive other means	
^a Boxes and enclosures may have more than one type of inlet.		
NOTE In the following countries the class Ha boxes and enclosures are used: BR, CH, DE, FR, IT, NO, PT, SE, UK		

8 Marking

8.1 Boxes and enclosures shall be marked with

- a) the name, trade mark or identification mark of the manufacturer or the responsible vendor.

In addition enclosures shall be marked with:

- b) the first characteristic numeral for the degree of protection against access to hazardous parts and against harmful effects due to ingress of solid foreign objects, if declared to be higher than 4 in which case the second characteristic numeral shall also be marked;
- c) the second characteristic numeral for the degree of protection against harmful effects due to ingress of water, if declared to be higher than 2 in which case the first characteristic numeral shall also be marked;

- d) the following marking $\text{IPXX} \begin{smallmatrix} \wedge \\ \wedge \\ \wedge \end{smallmatrix}$ on the cover of flush enclosures intended to be mounted on rough surfaces and where the IP is dependent on the surface (see Figure 5).

The IP code, if applicable, shall be marked on the outside of the enclosure so as to be easily discernible when the enclosure is mounted and wired as for normal use;

- e) the type reference, which may be a catalogue number;

NOTE In the following country the marking of the type reference is not used: UK.

- f) for boxes and enclosures classified as in 7.2.2.2 and 7.2.2.3, the minimum internal volume in cm^3 as determined by the test in 12.16. The internal volume shall be marked on the inside of the box or enclosure. The marking on a box or enclosure shall be such that the value can be read after installation of the box in the normal manner but before the installation of the wiring devices and wiring;

The following information shall be marked on the boxes and enclosures or provided by the manufacturer on the smallest package unit or in the manufacturer's instructions which need not be provided with the product:

- g) +90 °C for boxes and enclosures classified according to 7.2.1.3;

- h) the necessary information concerning the openings which can be made during installation in the case of boxes and enclosures classified according to 7.3.7;
- i) the minimum temperature during installation for boxes classified according to 7.5.2 and 7.5.3;
- j) the symbol Ha for boxes classified according to 7.2.2.1 and the symbol Hb for boxes classified according to 7.2.2.2 and 7.2.2.3.

Unless self-evident, further information for the correct use of the enclosure shall be given in the manufacturer's instructions which need not be provided with the product.

In special cases, in order to achieve a higher degree of protection by the use of special parts an instruction sheet should be provided and should indicate the higher degree of protection. In such a case, the marking covers the initial degree of protection.

8.2 The marking on the boxes and enclosures shall be durable and easily legible.

Compliance with 8.1 and 8.2 is checked by inspection and by the following test.

The test is made by rubbing the marking by hand for 15 s with a piece of cloth soaked with water and again for 15 s with a piece of cloth soaked with petroleum spirit.

NOTE Marking made by moulding, pressing or engraving is considered durable and is therefore not subjected to this test.

It is recommended that the petroleum spirit used consist of a solvent hexane with an aromatic content of maximum 0,1 % by volume, a kauributanol value of approximately 29, an initial boiling-point of approximately +65 °C, a dry point of approximately +69 °C and a density of approximately 0,68 g/cm³.

After the test the marking shall still be legible.

9 Dimensions

Boxes and enclosures shall comply with the appropriate standard sheets, if any.

Compliance is checked by inspection and measurement.

10 Protection against electric shock

Boxes and enclosures shall be so designed that, when they are assembled, equipped and installed as for normal use in accordance with the manufacturer's instructions, live parts are not accessible.

Where enclosures are supplied without a cover, cover-plate or an accessory they are tested with the appropriate parts fitted according to the information given in the manufacturer's instructions.

Compliance is checked by inspection and in case of doubt by the following test.

Enclosures shall be tested with test probe 11 according to IEC 61032 applied for 1 min with a force of 20 N, and the test probe shall not penetrate in the internal volume of the enclosure, as shown in Figure 2.




Figure 2 – Demonstration of the non-penetration of the internal volume

Tests shall be carried out on parts which are accessible after installation.

In addition, all enclosures according to 7.1.1, 7.1.3 and 7.1.4 with parts made of thermoplastic or elastomeric material shall be subjected for 1 min to a force applied through the tip of test probe 11 of IEC 61032 but at an ambient temperature of $+(35 \pm 2) ^\circ\text{C}$, the enclosure being at this temperature.

The probe is applied to all places where yielding of insulating material could impair the safety with a force of 75 N except to membranes, grommets and knock-outs or the like.

Knock-outs are tested according to 12.9.2.

11 Provision for earthing

11.1 Boxes and enclosures with exposed conductive parts

Boxes and enclosures with exposed conductive parts shall be provided with an earthing means of low resistance or have provision for the fitting of such an earthing means. For the purpose of this requirement, small screws and the like, for fixing bases, covers or coverplates, etc. isolated from live parts, are not considered as exposed conductive parts.

Exposed conductive parts of covers or cover-plates shall be connected through a low resistance connection to the earthing means when fitted as for normal use.

Compliance is checked by the following test.

A current derived from an a.c. source having a no-load voltage not exceeding 12 V and equal to $(25 \pm 1) \text{ A}$ is passed between the earthing terminal and each exposed conductive part in turn. The voltage drop between the earthing terminal and each of the exposed conductive parts is measured, and the resistance calculated from the current and this voltage drop.

In no case shall the resistance exceed $0,05 \Omega$.

Care should be taken that the contact resistance between the tip of the measuring probe and the exposed conductive part under test does not influence the test results.

NOTE In insulating boxes and enclosures having an IP degree higher than IPX0, provisions can be made for the addition of means for the effective continuity of the earthing conductor, when more than one inlet is provided.

The earthing means or the provision for the fitting of such an earthing means shall be located so that:


- the means is readily accessible through the open face of the box, and

- the removal of an accessory mounted in the box does not disturb the continuity of the earthing circuit, and
- the means is not part of a removable cover, back, or side of the box or enclosure.

Compliance is checked by inspection.

11.2 Boxes and enclosures of insulating material classified according to 7.2.2.2 and 7.2.2.3

Boxes and enclosures of insulating material shall be provided with a minimum of one earthing strap having one screw terminal for earthing purposes with a connecting capacity of at least 4 mm². The design of the earthing strap shall ensure that the metal mounting yokes of accessories mounted inside the box and metallic covers mounted on the box are connected to the earthing conductors (see Figures 3 and 4).



Key

- 1 earthing strap
- 2 earthing terminal screw
- 3 plastic box
- 4 accessory
- 5 metal cover
- 6 accessory's metal mounting yoke
- 7 accessory earthing terminal
- 8 bonding jumper

Figure 3 – Earthing strap




Figure 4 – Test strap

Compliance is checked by inspection.

The earthing strap shall be securely fastened to the box or enclosure.

Compliance is checked by the test in 16.3.2.

11.3 Boxes or enclosures with removable sides according to 7.1.2

A box or enclosure classified according to 7.1.2 that has removable sides shall be constructed so that the electrical bond between separable parts includes at least one threaded screw connection.

Compliance is checked by inspection.

11.4 Earthing terminal threads

The threads of the earthing terminal delivered with or integrated in boxes and enclosures shall not be stripped when the torque shown in the relevant column of Table 4 is applied.

Compliance is checked by inspection and by the following test.

The screws are tightened and loosened 5 times.

The test is made by using a suitable screwdriver or an appropriate tool applying a torque as indicated in Table 4.

If a screw has a hexagonal head with a slot, only the test with the screwdriver is made, with the relevant torque given in column II of Table 4.

Greater values of torque may be used if so stated by the manufacturer, when the relevant information is provided.

Column I applies to screws which cannot be tightened by means of a screwdriver with a blade wider than the nominal diameter of the thread of the screw.

Column II applies to other screws which are tightened by means of a screwdriver.

Column III applies to screws and nuts which are tightened by means other than a screwdriver.

Column IV applies to screws which are tightened by means of a square blade screwdriver.

During the test, there shall be no damage, such as breakage of screw or damage to the head slot (rendering the use of the appropriate screwdriver impossible) or to the threads or to the

enclosure impairing the further use of the fixing means. The screws shall be gradually tightened in one smooth and continuous movement.

12 Construction

12.1 General

Boxes and enclosures shall be constructed without sharp edges. Burrs shall be removed from mould lines of interior surfaces so that there are no sharp edges or undue obstructions to the passage of wiring or coupling of parts in the intended use of the product.

The inner and outer surfaces of a box or cover shall not be subject to peeling, scaling or flaking and shall be smooth and free from blisters, cracks, and other defects.

Compliance is checked by inspection.

12.2 Lids, covers or cover-plates or parts of them

12.2.1 General

Lids, covers, or cover-plates or parts of them, such as protective membranes, which are intended to ensure protection against electric shock, shall be held in place effectively.

It is recommended that the fixing means of covers or cover-plates be captive. The use of tight-fitting washers of cardboard or the like is deemed to be an adequate method for securing screws intended to be captive.

12.2.2 Screw-type fixing

A box or enclosure intended to accept a lid, cover, or cover plate by means of screw fixing shall be provided with means to accommodate the intended screws.

For lids, covers or cover plates whose fixing is of the screw type, compliance is checked by inspection.

12.2.3 Non-screw-type fixing operable without the use of a tool or a key

12.2.3.1 General

A box or enclosure intended to accept a lid, cover, or cover plate with non-screw-type fixing operable without the use of a tool or a key shall be provided with means to fix the lid, cover, or cover plate.

For lids, covers or cover-plates whose removal is obtained by applying a force according to the requirements in Table 2 in a direction approximately perpendicular to the mounting/supporting surface when their removal may give access with test probe B of IEC 61032:

- *to live parts;*
- *to non-earthed conductive parts separated from live parts by basic insulation;*
- *only to*
 - *insulating parts, or,*
 - *earthed conductive parts, or*
 - *conductive parts separated from live parts by double or reinforced insulation, or*
 - *live parts of SELV circuits according to IEC 61140 having a voltage not greater than 25 V a.c. or 60 V d.c.*

Compliance is checked by the tests of 12.2.3.2 and 12.2.3.3.

Table 2 – Forces to be applied to lids, covers, cover-plates or actuating members whose fixing is not dependent on screws

Accessibility with the test probe B of IEC 61032 after removal of lids, covers or cover-plates or parts of them	Force to be applied			
	N			
	Enclosures complying with 12.2.3.4 and 12.2.3.5		Enclosures not complying with 12.2.3.4 and 12.2.3.5	
	Shall not come off	Shall come off*	Shall not come off	Shall come off*
To live parts	40	120	80	120
To non-earthed conductive parts separated from live parts by basic insulation	10	120	20	120
To insulating parts or earthed conductive parts or conductive parts separated from live parts by double or reinforced insulation or live parts of SELV circuits according to IEC 61140 having a voltage not greater than 25 V a.c. or 60 V d.c.	10	120	10	120
* This column does not apply for 12.2.4.				

Boxes and enclosures are mounted as for normal use.

Flush-type boxes and enclosures are fixed and installed as for normal use. If they are provided with locking means which can be operated without the aid of a tool, these means are unlocked.

12.2.3.2 Verification of the non-removal of the lids, covers or cover-plates

Forces are gradually applied in one smooth and continuous movement in a direction perpendicular to the mounting surfaces, in such a way that the resulting force acting on the centre of the lids, covers or cover-plates, or parts of them, is as specified in the relevant column of Table 2.


The force is applied for 1 min.

The lids, covers or cover-plates, shall not come off.

For flush-mounting boxes or enclosures, the test is then repeated on new specimens, the lid, cover or cover-plate is mounted on the box, after a sheet of hard material ($1 \pm 0,1$) mm thick, has been fitted on the wall around the supporting frame, as shown in Figure 5.

The sheet of hard material is used to simulate wallpaper and may consist of a number of pieces.

Dimensions in millimetres



Key

- | | | | |
|---|------------------------|---|--------------|
| 1 | sheet of hard material | 4 | wall |
| 2 | cover-plate | 5 | mounting box |
| 3 | supporting frame | | |

Figure 5 – Arrangement for test on covers or cover-plates (see 12.2.3.2 and 12.2.3.3)

12.2.3.3 Verification of the removal of the lids, covers or cover-plates

A force not exceeding that specified in the relevant column of Table 2 is gradually applied in one smooth and continuous movement, in a direction perpendicular to the mounting/supporting surfaces, to lids, covers or cover-plates, or parts of them by means of a hook placed in turn in each of the grooves, holes, spaces or the like, provided for removing them.

The lids, covers or cover-plates shall come off.

The test is made 10 times on each separable part the fixing of which is not dependent on screws (equally distributing as far as practicable the application points); the removal force is applied each time to the different grooves, holes or the like provided for removing the separable part.

For flush-mounting boxes or enclosures the test is then repeated on new specimens.

The lid, cover or cover-plate is mounted on the box after a sheet of hard material ($1 \pm 0,1$) mm thick has been fitted on the wall around the supporting frame, as shown in Figure 5.

After the test, the specimens shall show no damage within the meaning of this standard.

12.2.3.4 Verification of the outline of lids, covers and cover-plates

The gauge shown in Figure 6 is pushed towards each side of each lid, cover or cover-plate which is fixed without screws on a mounting or supporting surface, as shown in Figure 7. The face B resting on the mounting/supporting surface, with the face A perpendicular to it, the gauge is applied at right angles to each side under test.

In the case of a lid, cover or cover-plate fixed without screws to another lid, cover or cover-plate or to a mounting box, having the same outline dimensions, the face B of the gauge shall be placed at the same level as the junction; the outline of the lid, cover or cover-plate shall not exceed the outline of the supporting surface.

The distances between the face C of the gauge and the outline of the side under test, measured parallel to face B, shall not decrease (with the exception of grooves, holes, reverse tapers or the like, placed at a distance less than 7 mm from a plane including face B and complying with the test of 12.2.3.5) when measurements are repeated starting from point X in the direction of the arrow Y (see Figure 8).





Figure 6 – Gauge for the verification of the outline of lids, covers or cover-plates




IEC

Key

- 1 mounting surface
- 2 cover
- 3 surface support
- 4 spacing piece with the same thickness as that of the supporting part

Figure 7 – Examples of application of the gauge of Figure 6 on covers fixed without screws on a mounting surface or supporting surface

Dimensions in millimetres



Cases a) and b) do not comply.

Cases c), d), e) and f) comply (compliance shall, however, also be checked with the requirements of 12.2.3.5 using the gauge shown in Figure 9).


Figure 8 – Compliance criteria of application of the gauge of Figure 6

12.2.3.5 Verification of grooves, holes and reverse tapers

A gauge according to Figure 9, applied with a force of $(1 \pm 0,2)$ N, shall not enter more than 1,0 mm from the upper part of any groove, hole or reverse taper or the like when the gauge is applied parallel to the mounting/supporting surface and at right angles to the part under test, as shown in Figure 10.

NOTE The verification of whether the gauge according to Figure 10 has entered more than 1,0 mm is made with reference to a surface perpendicular to face B and including the upper part of the outline of the grooves, holes, reverse tapers or the like.


Dimensions in millimetres



Key

- 1 test rod (metal)
- 2 right-angled sharp edges

Figure 9 – Gauge for verification of grooves, holes and reverse tapers



Key

- 1 cover
- 2 mounting support

Figure 10 – Sketch showing the direction of application of the gauge of Figure 9

12.2.4 Non screw-type fixing operable with the use of a tool or a key

For lids, covers or cover-plates whose fixing is not dependent on screws and whose removal is obtained by using a tool and/or a key, in accordance with the manufacturer's instructions, compliance is checked by the same tests of 12.2.3 except that the lids, covers or cover-plates or parts of them need not come off when applying a force not exceeding 120 N in directions perpendicular to the mounting/supporting surface.

12.3 Drain holes

Surface and semi-flush mounting enclosures with a degree of protection IPX1 to IPX6 shall be designed to allow the opening of a drain hole of at least 5 mm in diameter or 20 mm² in area with a minimum width or length of 3 mm.

Drain holes shall be so located and available in such a number that one of the holes can always become effective in any intended mounting position of the enclosure.

NOTE A drain hole in the back of the enclosure is deemed to be effective if the design of the enclosure ensures a clearance from the wall to provide a drainage space for the water of at least the size specified for the drain hole.

Compliance is checked by inspection and measurement.

12.4 Mounting of enclosures

Enclosures shall have provisions for their suitable attachment according to the type of installation (see 7.2).

Enclosures of insulating material shall be constructed in such a way that any conductive parts of fixing means inside the box or enclosure intended to be used for mounting the enclosure are surrounded by insulation which projects above the top of the fixing means by an amount of not less than 10 % of the maximum width of the cavity for the fixing means.

Compliance is checked by inspection and by measurement.

12.5 Boxes and enclosures with inlets for flexible cables

Inlets (outlets) provided in boxes and enclosures classified according to 7.3.2 shall be so designed and constructed that the flexible cables can be easily introduced, and will not damage the flexible cable where it enters the box or enclosure impairing its further use.

Compliance is checked by manual test.

12.6 Boxes and enclosures with inlets for applications other than flexible cables

Inlet openings classified according to 7.3 other than 7.3.2, if any, shall allow the introduction of

- a conduit or suitable fitting connecting it to the box or enclosure, and/or
- the protective covering of the cable

so as to provide mechanical protection of the conductors where they enter the box or enclosure.

An inlet opening for conduit entries, or at least two of them if there is more than one, shall be capable of accepting either conduits of sizes, or a combination of sizes, in accordance with the requirements of IEC 60423 and/or IEC 60981.

Compliance is checked by inspection with the appropriate cables or conduits installed.

Inlet openings of adequate size may also be obtained by the use of knock-outs or suitable insertion pieces or by means of an appropriate cutting tool.

NOTE In the following countries, it is required that inlet openings in boxes intended to receive switches or socket outlets have spout(s) with inlet stops: NL.

12.7 Boxes and enclosures with a cable anchorage(s)

Clamping means of boxes and enclosures classified according to 7.4.2 shall be such that the connection of the conductors of the flexible cable are relieved from strain when this flexible cable is accessible and likely to be stressed after installation.

It shall be clear how the relief from strain and the prevention of twisting are intended to be effected.

Cable anchorages shall be

- suitable for the different types of flexible cable for which the box is intended to be used;
- constructed in such a way that at least one part of it is integral with, or permanently fixed to, one of the component parts of the box;
- of insulating material or be provided with an insulating lining fixed to the metal parts.

Compliance is checked by inspection and the following test.

The effectiveness of the cable anchorage is checked by means of an apparatus as shown in Figure 11.

The cable anchorage is applied as in normal use, clamping screws, if any, being tightened with a torque equal to the 2/3 of the relevant torque specified in Table 4 or, for glands, equal to the relevant torque specified in Table 5.

After reassembly of the specimen, it shall not be possible to push the flexible cable into the specimen by more than 1 mm with the relevant force as specified in Table 3.


The cable is then subjected 50 times for 1 s to a pull force as specified in Table 3 and immediately afterwards the flexible cable is subjected to a torque not less than the relevant value specified in Table 3 for (15 ± 1) s applied as near as practicable to the cable entry.

Table 3 – Forces and torques to be applied to cable anchorages

External dimensions of flexible cable mm	Force N	Torque Nm
Up to and including 5,2 × 7,6	40 ± 2	0,05
Up to and including 8	50 ± 2	0,1
Above 8 up to and including 11	60 ± 2	0,15
Above 11 up to and including 16	80 ± 2	0,35
Above 16	100 ± 2	0,42

After the tests, the flexible cable shall not have been displaced by more than 2 mm and the cable anchorage (strain relief) shall not show any damage which leads to non-compliance with this standard.

Dimensions in millimetres

**Key**

- 1 box
- 2 crank
- 3 eccentric

Figure 11 – Apparatus for testing the cable anchorage**12.8 Boxes and enclosures with cable retention means**

Cable retention means of boxes and enclosures classified according to 7.4.1 shall retain the cable in place.

NOTE In the following countries, a cable retention is required for boxes and enclosures for hollow walls due to installation practices: DE.

Compliance is checked by the following test which is carried out on three specimens of retention means.

For boxes and enclosures classified according to 7.5.2 or 7.5.3, the test shall be carried out at $(-15 \pm 2) ^\circ\text{C}$ and $(-25 \pm 2) ^\circ\text{C}$ respectively.

First a cable of the maximum nominal cross-sectional area and, subsequently, a cable with the minimum nominal cross-sectional area as declared by the manufacturer shall be used.

The cable is fitted in the cable retention means according to the manufacturer's instructions.

The cable is loaded with an axial force of $(20 \pm 1) \text{ N}$.

The load is maintained for 1 min and at the end of this period the displacement of the cable shall not exceed 3 mm following the removal of the load.

12.9 Knock-outs intended to be removed by mechanical impact

12.9.1 General

It shall be possible to remove knock-outs intended to be removed by mechanical impact without damaging the box.

Knock-outs intended for use with cables shall be free from chips or burrs.

In knock-outs intended for use with conduits and/or a grommet or a membrane, chips and burrs are disregarded.

In order to close an open knock-out in a box or an enclosure classified according to 7.1.2 a blanking-plug can be used.

This blanking-plug used without a locknut

- shall not become dislodged or damaged, and
- its effectiveness shall not be impaired, and
- it shall fulfil all requirements for knock-outs.

This requirement does not apply to a blanking-plug which is assembled by threading into a threaded inlet.

Compliance is checked by inspection and by the tests as specified in 12.9.2 and 12.9.3.

12.9.2 Knock-out retention

For boxes and enclosures having knock-outs that

- *do not provide access to live parts and are accessible after installation, a force of (30 ± 1) N shall be applied to a knock-out for (15 ± 1) s,*
- *provide direct access to live parts after installation, a force of (40 ± 1) N shall be applied to a knock-out for (60 ± 1) s,*

by means of a 6 mm diameter mandrel with a flat end.

The force is to be applied without a blow in a direction perpendicular to the plane of the knock-out and at a point most likely to cause movement.

When the box is provided with a multi-stage knock-out, the force shall be applied to the smallest knock-out.

The knock-out shall remain in place and the degree of protection of the box or enclosure shall be unchanged when measured 1 h after the force has been removed.

12.9.3 Knock-out removal

The knock-outs shall be removed by means of a tool, as stated by the manufacturer. The side edge of a screwdriver may be run along the edge of the knock-out opening once to remove any fragile tabs remaining along the edge.

For boxes or enclosures according to 7.1.1 or 7.1.3 the test is repeated with one previously untested box or enclosure which has been conditioned for $5\text{ h} \pm 10\text{ min}$ in air maintained at the minimum temperature during installation as specified according to 7.5. Immediately following this conditioning, the knock-out is to be removed as above.

For a box or enclosure employing multi-stage knock-outs, there shall be no displacement of a larger stage when a smaller stage is removed.

After the test, there shall be no sharp edges, except for knock-outs for conduits and/or for use with a grommet or a membrane and the box and enclosure shall not be damaged.

12.9.4 Flat surfaces surrounding knock-outs

Knock-outs intended for the use of grommets, glands or fittings shall be located in flat surfaces to permit grommets, glands or fittings to be seated fully against these surfaces when installed as intended.

Projections or indentations in the flat surface area shall be prohibited, however holes shall be allowed. The flat surface areas of adjacent knock-outs that partially or wholly overlap meet the intent of this requirement.

Compliance is checked by inspection and by measurement according to the appropriate national standard sheet, if any.

12.10 Screw fixings

Fixing means for lids, covers, cover plates, accessories, terminals, connecting devices, strain reliefs, etc. effected by screws shall be so designed and constructed that these means withstand the mechanical stresses occurring during installation and normal use.

Screws or other fixing means made from insulating material similar to screws without standardized thread which have to be tightened by any tool for fixing covers shall be tested according to the manufacturer's instructions.

NOTE In the following country flush-type boxes shall have metal inserts and be provided with metal screws having ISO metric thread: NL.

Thread-forming and thread-cutting screws intended only for mechanical assembly may be used provided they are supplied together with one of the pieces with which they are intended to be assembled.

For thread-forming and thread-cutting screws, the screw assembly operation shall be done before carrying out the tests.

Compliance is checked by inspection and by the following test.

The screws of the fixing means are tightened and loosened:

- 10 times for metal screws in engagement with a thread of insulating material;
- 5 times in all other cases.

Screws and nuts in engagement with a thread of insulating material and screws of insulating material are completely removed and reinserted each time. The test is made by using a suitable screwdriver or an appropriate tool applying a torque as indicated in Table 4.

If a screw has a hexagonal head with a slot, only the test with the screwdriver is made, with the relevant torque given in column II of Table 4.

Greater values of torque may be used if so stated by the manufacturer, when the relevant information is provided.

Column I applies

- to screws which cannot be tightened by means of a screwdriver with a blade wider than the nominal diameter of the thread of the screw,
- to non-metallic screws,
- to metallic screws in a thread of insulating material. In this latter case, the width of the profile of the recess to tighten the screw is chosen instead of the diameter of the thread when this profile width is smaller than the nominal diameter of the thread with a minimum of 3 mm.

Column II applies to other screws which are tightened by means of a screwdriver.

Column III applies to screws and nuts which are tightened by means other than a screwdriver.

Column IV applies to screws which are tightened by means of a square blade screwdriver.

During the test, there shall be no damage, such as breakage of screw or damage to the head slot (rendering the use of the appropriate screwdriver impossible) or to the threads or to the enclosure impairing the further use of the fixing means. The screws shall be gradually tightened in one smooth and continuous movement.

Table 4 – Tightening torques for the verification of the mechanical strength of screws

Nominal diameter of screw thread mm	Torque for metallic and non-metallic screws Nm			
	I	II	III	IV
Up to and including 2,8	0,20	0,40	0,40	0,70
Over 2,8 up to and including 3,0	0,25	0,50	0,50	0,90
Over 3,0 up to and including 3,2	0,30	0,60	0,60	1,10
Over 3,2 up to and including 3,6	0,40	0,80	0,80	1,40
Over 3,6 up to and including 4,1	0,70	1,20	1,20	1,80
Over 4,1 up to and including 4,7	0,80	1,80	1,80	2,30
Over 4,7 up to and including 5,3	0,80	2,00	2,00	4,00
Over 5,3 up to and including 6,0	1,20	2,50	3,00	4,40
Over 6,0 up to and including 8,0	2,50	3,50	6,00	4,70
Over 8,0	3,00 ^a	4,00	10,00	5,00

^a Or to be specified by the manufacturer.

12.11 Fixing of boxes and enclosures classified according to 7.2.1

Flush type boxes and enclosures other than for hollow walls, and as otherwise indicated below, shall be provided with fixing means for their suitable attachment to the wall, ceiling or floor. Screws intended to fix the box or enclosure to the building structure need not be supplied with the box or enclosure but can be provided by the installer according to the manufacturer's instructions.

Separately supplied fixing means for a box or enclosure shall comply with the requirements for the fixing means of the box or enclosure with which they are intended to be used and shall include a means for fixing to the box or enclosure.

Screws, additional mechanical supports or design features, which prevent the displacement of the box or the enclosure, are considered to be adequate fixing means.

NOTE Edges, ribs, recesses, partial edges and the like are examples of design features intended to prevent the displacement of the box or the enclosure.

Compliance is checked by inspection.

Boxes and enclosures not fulfilling at least one of the above requirements and having an internal volume less than 400 cm³, shall be tested as follows.

The internal volume of the box or enclosure shall be checked by inspection or by the test in 12.16.

For boxes and parts of enclosures to be embedded in masonry the specimen is mounted into the mounting block shown in Figure 12 and fixed according to the manufacturer's instructions.

The gap between the main external profile of the specimen and the internal profile of the recess in the mounting block shall be at least 20 mm and for parts that project from the main profile never less than 10 mm. The block is filled by the material specified in the manufacturer's instructions, or by plaster where the manufacturer's instructions do not specify the material.

The assembly is kept at ambient temperature for $(10 \pm 1/0)$ days.

The auxiliary device described in Figure 13 is mounted on the specimen and the screws are tightened with a torque equal to two thirds of the applicable torque given in Table 4.


The assembly is then fixed to the mounting plate (A) of an apparatus shown in Figure 14, so that the axes of the screws are normal to the mounting plane.

The total weight of the device including the principal weight (PW) shall be $(72 \pm 0,1)$ N, and the supplementary weight (SW) shall be $(8 \pm 0,1)$ N.

The supplementary weight (SW) and the principal weight (PW) are introduced on the axis of the device and fixed by the carrier (C) (see Figure 14).

The supplementary weight shall fall from a height of 50 mm onto the principal weight 10 times.

After the test the specimen shall not have been displaced by more than 0,5 mm from the mounting block.




Key

- 1 specimen
- 2 plaster
- 3 block of wood

* The gap between the main external profile of the box and the internal profile of the recess in the mounting block shall be at least 20 mm, and for parts which project from the main profile never less than 10 mm.


Figure 12 – Example of mounting block for boxes to be embedded in masonry (flush type and semi-flush type)



Key

- 1 auxiliary device
- 2 specimen

Figure 13 – Example of the fixing of the auxiliary device mounted on a specimen

**Key**

- 1 supplementary weight (SW)
- 2 principal weight (PW)
- 3 carrier (C)
- 4 mounting plate (A)

Figure 14 – Example of test apparatus for the test

12.12 Fixing of flush type and semi-flush type boxes and enclosures classified according to 7.2.2.1

Boxes and enclosures for hollow walls or the like classified according to 7.2.2.1 shall have suitable means for fixing the box or the enclosure to hollow walls, hollow ceilings, hollow floors or furniture.

The fixing means shall not rely on the cable management system.

Compliance is checked by the following test.

A specimen of the box or enclosure is mounted in a test wall in accordance with the manufacturer's instructions. Where the manufacturer's instructions are not specific regarding the type of wall, a sheet of plywood (10 ± 1) mm thick, 500 mm wide and 500 mm high shall be used.

a) Checking pull and torque

A lever shall be fixed with the fixing means for accessories or covers to the specimen, as shown in Figure 15.


This lever is loaded for one minute with a force F_1 as shown in Figure 15 a) in such a way that a torque ($F_1 \times a$) of 3 Nm is applied to the box and simultaneously with a force F_2 as shown in Figure 15 b) of 100 N applied on the main axis of the box perpendicular to the mounting surface.

After this test, the specimens shall show no damage impairing their further use and the displacement of the lever shall be no more than 2° .

b) Checking displacement

The end of the lever is subjected for 1 min to a force F_3 applied to the same point where F_1 was applied in such a way that a torque ($F_3 \times b$) of 3 Nm is applied to the box as shown in Figure 15 c).

After the test, the edge of the box shall not have been displaced by more than 1 mm in comparison to the mounting surface.



Key

- 1 test specimen
- 2 sheet of plywood
- 3 lever
- 4 main axis of the box

Figure 15 – Verification of fixing means for boxes and enclosures classified according to 7.2.2.1

12.13 Boxes and enclosures classified according to 7.2.2.2 and 7.2.2.3

12.13.1 General

Boxes and enclosures for hollow walls or the like classified according to 7.2.2.2 and 7.2.2.3 shall have suitable means for fixing the box or the enclosure to hollow walls and hollow ceilings.

The fixing means shall not rely on the cable management system.

Compliance is checked by the tests in 12.13.2, 12.13.3, 12.13.4 or 12.13.6 as applicable.

12.13.2 Boxes intended for mounting on a wood structural member of a wall

The box shall be mounted as in normal use to a (38 mm × 90 mm) wood structural member of any convenient length so that the plane of the front of the box is in vertical position.

The assembly shall withstand a force of 225 N gradually applied centrally from the base of the box for a period of 5 min.

After the removal of the force, there shall be no pulling out of the nails or screws used to mount the box or movement of the face of the box in the horizontal plane of more than 3 mm.

12.13.3 Boxes intended for mounting to a wooden structural member of a ceiling

The box shall be mounted as in normal use to a (38 mm × 190 mm) wood structural member of any convenient length so that the plane of the front of the box is in horizontal position.

The assembly shall withstand a force of 225 N gradually applied centrally from the face of the box for a period of 1 min.

With the force still applied, the deflection of the face of the box shall not exceed 6 mm measured from a plane parallel to the horizontal face of the structural member.

12.13.4 Boxes intended for mounting to a steel-stud structural member of a wall

The box shall be mounted as in normal use to a steel-stud structural member as shown in Figure 16.


The assembly shall withstand a force of 180 N gradually applied centrally from the face of the box for a period of 5 min, first in a direction tending to push the box into the wall opening and then in the opposite direction, tending to pull the box out of the opening.

With the force still applied, the deflection of the box shall not exceed 2 mm in either direction.

NOTE Additional support for the box can be necessary to minimize deflection.

Application of the force and measurement of the displacement are shown in Figure 16.

Dimensions in millimetres



Key

- 1 box
- 2 steel stud
- 3 additional support
- 4 maximum deflection
- 5 plywood
- 6 bracket
- 7 three screws per side per panel

Figure 16 – Test of the force and measurement of the displacement

12.13.5 Internal volume of boxes and enclosures classified according to 7.2.2.2 and 7.2.2.3

For boxes, enclosures, raised covers and box extensions classified according to 7.2.2.2 and 7.2.2.3, the declared internal volume of a box, enclosure, raised cover or box extension shall be verified.

A box or enclosure provided with a partition shall have the volume of each partitioned section verified.

Compliance is checked by the test of 12.16.

12.13.6 Boxes intended for mounting in a finished structure

The supporting means of a box intended for installation in a finished structure shall not crack or break nor shall the face of the box be permanently displaced more than 3,2 mm from the plane of the face of the test surface when measured 1 min after the test load is removed.

NOTE In a finished structure, structural framing members are not typically accessible for mounting and supporting boxes or enclosures flush or semi-flush in hollow walls.

Compliance is checked by the following test:

Six boxes intended for use in walls or eight boxes intended for use in ceilings shall be installed in a 9,5 mm thick plywood sheet reinforced with a support 152 mm from one edge of the opening for the boxes, or in a finished surface in accordance with the manufacturer's instructions.

Screws for the box supporting means shall be tightened in accordance with the manufacturer's instructions. In the absence of instructions, screws shall be tightened in accordance with column IV of Table 4. A screw that strips before being tightened to the torque specified shall not override more than once.

Following installation, a force of 222 N shall be applied for 5 min consecutively to each of two boxes in a direction normal to the plane of the face of the test surface along the centerline of the box, and tending to push the box into the opening. The same force is to be applied to each of two previously untested boxes in a direction tending to pull the box out of the opening. Following this test, the screw shall be capable of being removed by a screwdriver.

Two additional samples of a box secured so that the plane of the front of the box is vertical, shall be subjected to a force of 222 N applied for 5 min suspended from the lower rear corner of the outer back edge of the box.

12.14 Cable gland entry

Cable glands shall not damage the box or enclosure when used as intended.

Compliance is checked by the following test.

Cable glands are fitted with a cylindrical metal rod having a diameter, in millimetres, equal to the internal diameter of the gasket rounded to the nearest whole number as specified in the first column of Table 5. The cable glands are then tightened and loosened 10 times by means of a suitable tool with the torque specified in Table 5 with a tolerance of $\left(\begin{smallmatrix} +5 \\ 0 \end{smallmatrix} \right) \%$, the relevant torque being applied for 1 min $\pm$ 5 s.

Table 5 – Torque test values for cable glands

Diameter of test rod mm	Torque Nm	
	Metal glands	Glands of insulating material
Up to and including 8	4,0	2,5
Over 8 up to and including 14	6,3	3,8
Over 14 up to and including 20	7,5	5,0
Over 20	10,0	7,5

After the test, the boxes and enclosures shall show no damage within the meaning of this standard.

12.15 Boxes and enclosures with inlets (outlets) or spouts (hubs) for conduits

12.15.1 Boxes and enclosures classified according to 7.3.4 and conical spouts as in 7.3.6 shall withstand the tests of 12.15.2, 12.15.3 and 12.15.4.

Threaded spouts are not submitted to the tests of 12.15.2 and 12.15.3.

Boxes and enclosures classified according to 7.4.3 shall withstand the tests of subclauses 12.15.2 and 12.15.3.

The tests are carried out with conduits of minimum nominal size according to IEC 60423 or IEC 60981 after installation as in normal use or assembly according to the manufacturer's instructions.

12.15.2 Enclosures with the inlet spout for conduits, if any, shall be tested so that a minimum size piece of conduit is pressed for $1 \text{ min} \pm 5 \text{ s}$ with a force of $(100 \pm 2) \text{ N}$. The inlet spout shall prevent further entry of the conduit into the box.

12.15.3 A pull-out test shall be carried out after the test according to 12.15.2, as follows. The conduit with the minimum size corresponding to the insert opening shall be loaded axially for 1 min with a tensile force of $(20 \pm 2) \text{ N}$. The conduit shall not come loose from the inlet spout of the enclosure.

12.15.4 The resistance to bending strain of an inlet spout shall be tested as follows. A piece of a conduit shall be inserted into the inlet spout with a compressible force of $(100 \pm 2) \text{ N}$ and loaded with a bending moment of 3 Nm. The strain shall slowly rise from zero to full value and the test shall be done in six different directions through the centre line of the inlet spout with an interval of $(60 \pm 2)^\circ$. At each angle position the inlet spout shall be loaded for 1 min. The inlet spout shall not come loose or be damaged and the conduit shall stay within the inlet spout.

NOTE An inlet stop can be designed as a rib on the inside of the inlet spout.


12.16 Internal volume of boxes and enclosures

When referred to in this standard, the declared internal volume of the box or enclosure, each partitioned section of a box or enclosure, raised covers and box extensions shall be measured in the following manner.

- All internal screws, clamps, etc, shall be removed except earthing terminals and assembly screws.
- Any projections such as a cover or flush-mounting ears that extend beyond the normal edge of the box or enclosure shall be ground flush with the edge.

- c) All knock-outs shall be left as punched and shall be sealed externally.
- d) All openings shall be plugged with modelling clay, putty, wax or other material(s) and shall be filled flush with the internal surface.
- e) The box, enclosure, or raised covers shall be covered with a flat plate of any convenient transparent material not more than 3,2 mm thick. In the centre of the plate a hole with a nominal diameter of 13 mm shall be provided (see Figure 17). If necessary, the gap between the box, enclosure or raised cover and the plate shall be sealed with the material used to seal the other openings.
- f) Using any convenient graduated cylinder or measuring flask filled with water at room temperature, the box, enclosure, or raised cover shall be filled without overflowing. The difference in the volume of water in the measuring cylinder measured before and after the filling of the box, enclosure or raised cover indicates the volume of the box.

The volume of a side pocket provided to increase the volume of a box or enclosure shall be calculated using a depth-of-pocket not more than the smallest dimension of the opening into that side pocket.



Key

- 1 box
- 2 cover
- 3 opening for water fill
- 4 seal if necessary

Figure 17 – Volume measurement

13 Resistance to ageing, protection against ingress of solid objects and against harmful ingress of water

13.1 Resistance to ageing

13.1.1 Insulating and composite boxes and enclosures, glands, grommets and replaceable membranes shall be resistant to ageing.

Compliance is checked as follows.

Boxes and enclosures of insulating or composite material with provision for glands or grommets are mounted and assembled as in normal use or according to the manufacturer's instructions.

Boxes and enclosures of insulating or composite material without provision for glands, grommets, or membranes are assembled according to the manufacturer's instructions.

Parts intended for decorative purposes which can be removed without the aid of a tool, shall be removed before the tests.

For boxes and enclosures provided with glands or grommets, approximately half of the number of glands or grommets of each of the boxes and enclosures are fitted with seals together with cylindrical metal rods having a diameter equal to the lower limit specified for the mean overall diameter of the smallest cable as declared by the manufacturer. The remainder of the glands or grommets of the same boxes and enclosures are fitted with seals together with cylindrical metal rods having a diameter equal to the upper limit specified for the mean overall diameter of the largest cable as declared by the manufacturer.

Where the number of glands or grommets in a box is greater than six, the test is made with three glands or grommets equipped for the smallest cable size and three glands or grommets equipped for the largest cable size on each box.

In the case of grommets, the rod shall be kept in place in such a way that the rod cannot move. The means to keep the rod in place shall have no influence on the results of the tests.

The glands are tightened with a torque equal to two-thirds of that applied during the test of 12.14 (Table 5) any other openings being closed. Greater values of torque may be used if so stated by the manufacturer.

The specimens are then subjected to a test in a heating cabinet with an atmosphere having the composition and pressure of the ambient air.

The temperature in the heating cabinet is $(70 \pm 2) ^\circ\text{C}$.

The specimens are kept in the cabinet for $(168^{+4}_0) \text{ h}$.

After the treatment, the specimens are removed from the cabinet and kept at room temperature for $(96^{+4}_0) \text{ h}$.

After the test, the specimen shall show no harmful deformation or similar damage, which may impair their further use within the meaning of this standard.

13.1.2 Grommets, blanking plugs and entry membranes in inlet openings and protecting membranes shall be reliably fixed and shall not be displaced by the mechanical and thermal stresses occurring in normal use.

Compliance is checked by the following test, which shall be applied to all grommets, blanking plugs, replaceable and non-replaceable membranes.

Grommets, blanking plugs and membranes are tested while fixed to the enclosures.

First, the enclosures that have been subjected to the treatment specified in 13.1.1 are placed for $2 \text{ h} \pm 15 \text{ min}$ in a heating cabinet as described in 13.1.1, the temperature being maintained at $(40 \pm 2) ^\circ\text{C}$.

Immediately after this period, a force of $(30^{+0}_{-2}) \text{ N}$ is applied for $(5 \pm 1) \text{ s}$ to various parts of the grommets, blanking plugs and/or membranes by means of the tip of test probe 11 according to IEC 61032.

During these tests, the grommets, blanking plugs and/or membranes shall not be deformed to such an extent that live parts of any included accessory become accessible.

For grommets, blanking plugs and/or membranes likely to be subjected to an axial pull in normal use, an axial pull of (30 ± 2) N shall be applied for (5 ± 1) s.

The test is then repeated on the same enclosures fitted with grommets, blanking plugs and/or membranes which have not been subjected to any treatment.

After the test, grommets, blanking plugs and/or membranes shall show no harmful deformation, cracks or similar damage which would lead to non-compliance with this standard.

13.1.3 Grommets, blanking plugs and entry membranes in inlet openings of boxes and enclosures classified according to 7.5.2 and 7.5.3 shall be so designed and made of such material that the introduction of the cables and conduits is permitted when ambient temperature is low.

Compliance is checked by the following test.

The enclosure is fitted with grommets, blanking plugs and/or entry membranes which have not been subjected to any ageing treatment.

After being left to cool down to the ambient temperature, the boxes and enclosures are then kept for 2 h in a refrigerator

- *at a temperature of (-15 ± 2) °C for boxes and enclosures classified according to 7.5.2, or*
- *at a temperature of (-25 ± 2) °C for boxes classified according to 7.5.3.*

Immediately after conditioning, while the boxes and enclosures are still cold and in the refrigerator, it shall be possible to pierce any blind grommets, blanking plugs and entry membranes and to introduce cables and conduits of the maximum diameter intended, the cables and conduits having been submitted to the same conditioning as the boxes and enclosures.

After the test, the grommets, blanking plugs or entry membranes shall show no harmful deformation, cracks or similar damage which would lead to non-compliance with this standard.

13.2 Protection against the ingress of solid objects

Enclosures shall provide a degree of protection against the ingress of solid objects in accordance with their declared IP Code.

For boxes and enclosures classified according to 7.2.2.1 the above requirement applies also to the part mounted inside the hollow wall according to classification 7.8.

NOTE In the following countries a minimum protection degree of IP30 is required for parts of boxes and enclosures inside hollow walls due to installation practices: DE, DK, SE, NO

Compliance is checked by the appropriate test of IEC 60529 under the following test conditions.

Enclosures are mounted as for normal use according to the manufacturer's instructions.

For boxes and enclosures classified according to 7.2.2.1, the test on the part mounted inside the wall is made on a box mounted so that the rear part is accessible for the test.

Unless otherwise stated herein, where the enclosure has drain holes, at least one open drain hole shall be in the lowest position.

Enclosures with screwed glands or grommets are fitted with cables having the smallest and the largest cross-sectional area and/or conduit having the smallest and the largest diameter/dimensions, if any, as declared by the manufacturer.

Fixing screws of the cover or cover-plate of the box are tightened with a torque equal to two-thirds of the values from Table 4 used for the test of 12.10.

Greater values of torque may be used if so stated by the manufacturer, when the relevant information is provided.

Other fixing means shall be fastened as in normal use or, if provided, according to the manufacturer's instructions.

Cable and/or conduit entry means are made according to the manufacturer's instructions.

Parts which can be removed without the aid of a tool are removed.

Glands are not filled with sealing compound or the like.

For degree of protection IP5X, the test is carried out according to IEC 60529 category 2 and the drain holes, if any, shall not be open.

For degrees of protection up to and including IP4X, the protection is satisfactory if the full diameter of the probe does not pass through any opening other than through drain holes, in which case the probe shall not touch live parts within the enclosure.

For degree of protection IP5X, the protection is satisfactory if the dust does not cover the whole inner surface.

For degree of protection IP6X, the test is carried out according to IEC 60529 and the drain hole, if any, shall not be open. The protection is satisfactory if there is no dust inside the box or enclosure.

13.3 Protection against harmful ingress of water

13.3.1 Enclosures with a degree of protection higher than IPX0 shall provide a degree of protection against harmful ingress of water in accordance with the declared IP Code.

Compliance is checked by the appropriate tests of IEC 60529 under the following test conditions.

For surface enclosures and flush and semi-flush enclosures with dimensions $S \leq 0,04 \text{ m}^2$ or perimeter $\leq 0,8 \text{ m}$, see 13.3.2 and 13.3.3.


For surface enclosures and flush and semi-flush enclosures with dimensions $S > 0,04 \text{ m}^2$ and perimeter $> 0,8 \text{ m}$, see 13.3.2 and 13.3.4.

The reference surface S to be chosen for verification is calculated as follows.

- *For square and rectangular boxes and enclosures, the surface to take into account is the smallest interior width (l) multiplied by the depth (h) (see Figure 18 a)).*
- *For round boxes and enclosures, the surface to take into account is the interior depth (h) of the box or enclosure multiplied by the smallest diameter (d) divided by 4 (see Figure 18 b)).*

Enclosures with screwed glands or grommets are fitted with cables having the smallest and the largest cross-sectional area and/or conduit having the smallest and the largest diameter/dimensions, if any, as declared by the manufacturer.

Fixing screws of the cover or cover-plate of the box are tightened with a torque equal to two-thirds of the values from Table 4 used for the test of 12.10.




Key

h depth

l internal width

* For a rectangular box placed horizontally, the surface S to take into account is the smallest one.

a) Reference surface for square boxes and enclosures



Key

h internal depth

d smallest diameter

b) Reference surface for round boxes and enclosures

Figure 18 – Reference surfaces for boxes and enclosures

13.3.2 *Surface-mounting enclosures are mounted as for normal use according to the manufacturer's instructions with any open drain holes in the lowest position unless otherwise specified.*


Flush type and semi-flush type enclosures are fixed in a test wall in accordance with the manufacturer's instructions.

In this case, the manufacturer's instructions shall specify a type of wall, as well as the mounting. These shall be described in sufficient detail to ensure reproducible tests.

Where the manufacturer's instructions do not specify a type of wall, the test wall according to Figure 19 is used.

IECNORM.COM : Click to view the full PDF of IEC 60670-1:2015

Dimensions in millimetres



IEC

Key

- 1 box
- 2 brick
- 3 mortar
- 4 surface reference

* Or in accordance with the manufacturer's instructions

All mortar joints are 10 mm thick unless otherwise specified.

Figure 19 – Test wall

The test wall of Figure 19 is made with bricks having smooth surfaces. When the box is mounted in the test wall, it shall fit tight against the wall so that water cannot enter between the box and the wall.

If sealing material is used in order to seal the box into the wall, the sealing compound should not influence the sealing properties of the specimen to be tested.

NOTE 1 Figure 19 shows an example where the edge of the box is positioned in the reference plane, other positions are possible according to the instructions of the manufacturer.

The test wall is placed in a vertical position.

Enclosures are mounted as in normal use and fitted with cables having conductors of the largest and smallest cross-sectional area as declared by the manufacturer.

NOTE 2 For IPX3 and IPX4, the oscillating tube according to Figure 4 of IEC 60529:1989 is used unless the dimensions of the enclosure imply the use of the spray nozzle according to Figure 5 of IEC 60529:1989.

During the tests of enclosures of degree of protection higher than IPX4, drain holes, if any, shall not be opened.

Care shall be taken not to disturb, for example, to knock or shake, the enclosure, in such a manner that the test result will be affected.

13.3.3 *Immediately after the test, there shall be no more than $0,2 \text{ ml} \times S \text{ (cm}^2\text{)}$ water in the enclosure.*

NOTE For a degree of protection higher than IPX4, it can be necessary to open the drain holes for inspection.

If the enclosure is not provided with drain holes, consideration should be given to any accumulation of water which may occur, for example, condensation.

After the test, the specimens of boxes and enclosures classified according to 7.1.1, 7.1.3 and 7.1.4, as appropriate, shall withstand an electric strength test specified in 14.3 which shall be started within 5 min of the completion of the test according to this subclause.

13.3.4 *Ingress of water is verified by the use of dry absorbent paper positioned to cover the base area of the protected volume.*

NOTE 1 The base is always the bottom of the protected area when installed.

Unless it is decided otherwise by the manufacturer the protected volume shall correspond to the total internal space of the box reduced by 5 % on each face of the box, i.e. 10 % on each dimension of the enclosure (See Figure 20).

$$V_p = 0,9 L \times 0,9 D \times 0,9 H$$

where

V_p is the protected volume;

L is the length;

D is the depth;

H is height.

NOTE 2 In case of a round box the protected volume is equal to $V_p = 0,9 H \times \pi(0,9 \times d)^2 / 4$.


In order to construct the protected volume in absorbent paper the manufacturer should provide for the test a specimen where the absorbent paper is suspended by a reliable suspension means.

NOTE 3 The formula is only an explanation of the protected volume which is decreased by 5 % on each side of the enclosure. No calculation is required.

For doors or covers a strip of paper, bent to form a 90° angle profile, is attached to the cover or lid in the lowest position in order to protrude inside the box until it reaches the internal protected volume of the box (See Figure 20).

If the enclosure could have more than one position of installation the test shall be carried out in all cases of installation.

Immediately after the test, the indicator paper shall still be dry.



Key

- 1 cover
- 2 absorbent paper
- 3 box
- 4 protected volume

NOTE The base is always the bottom of the protected area when installed.

Figure 20 – Example of the protected volume

14 Insulation resistance and electric strength

14.1 The insulation resistance and the electric strength of enclosures classified according to 7.1.1, 7.1.3 and 7.1.4 shall be adequate.

Compliance is checked by the tests of 14.2 and 14.3, these tests being made immediately after the following humidity treatment.

The specimens are placed in a humidity cabinet containing air with a relative humidity maintained between 91 % and 95 %.

The temperature of the air where the specimens are placed is maintained within ± 1 °C of any convenient value t between +20 °C and +30 °C.

Before being placed in the humidity cabinet, the specimens are brought to a temperature between t and $(t + 4)$ °C.

The specimens are kept in the cabinet for

- 2 days (48^{+2}_0) h for enclosures classified IPX0;
- 7 days (168^{+4}_0) h for other enclosures.

NOTE In most cases, the specimens can be brought to the specified temperature by keeping them at this temperature for at least 4 h before the humidity treatment. A relative humidity between 91 % and 95 % can be

obtained by placing a saturated solution of sodium sulphate (Na_2SO_4) or potassium nitrate (KNO_3) in water having a sufficiently large contact surface with the air in the humidity cabinet.

After this treatment, the specimen shall show no damage impairing its further use and shall pass the following tests.

14.2 When a solid material is intended to provide electrical insulation between live parts and the body, the insulation resistance between the body and a metal foil in contact with the internal surface of the box and enclosure, is measured with a d.c. voltage of approximately 500 V, the measurement being made 1 min after application of the voltage.

The term “body” includes all accessible metal parts, metal foil in contact with the outer surface of accessible external parts of insulating material, fixing screws of bases or covers and external assembly screws.

If metal foil is used for testing the insulation resistance and the electric strength, one metal foil is placed in contact with the inner surfaces and another metal foil, having a size not exceeding 200 mm × 100 mm, is placed in contact with the external surfaces and, if necessary, is moved so as to test all parts.

Care shall be taken that during the test the distance between the inner and the outer metal foil shall be arranged in such a way that there is no flashover in the surroundings of holes, premoulded knock-outs, membranes, etc.

The insulation resistance shall be not less than 5 MΩ.

14.3 The electric strength is tested by applying a voltage of a substantially sinusoidal waveform, having a nominal frequency of 50 Hz or 60 Hz and a value as specified in Table 6, for 1 min between the parts listed in 14.2.

The test voltage is taken from Table 6 according to the rated insulation voltage as declared by the manufacturer.

For enclosures having class II protection, the test voltage according to Table 6 is multiplied by 1,5.

Initially, not more than half the prescribed voltage is applied, then it is raised rapidly to the full value.

No flashover or breakdown shall occur during the test.

Table 6 – Test voltage for electric strength test

Rated insulation voltage V	Test voltage V
≤130	1 250
>130 and ≤250	2 000
>250 and ≤450	2 500
>450 and ≤750	3 000
>750	3 500

The high-voltage transformer used for the test is so designed that, when the output terminals are short-circuited after the output voltage has been adjusted to the appropriate test voltage, the output current is of at least 200 mA. The overcurrent relay shall not trip when the output current is less than 100 mA.

The r.m.s. value of the test voltage applied is measured within ±3 %.

Glow discharges without a drop in voltage are disregarded.

During the test a metal foil, as described in 14.2, is placed in contact with the inner surfaces and another metal foil is placed in contact with the external surfaces and, if necessary, moved so as to test all the parts.

15 Mechanical strength

15.1 General

Boxes and enclosures shall have adequate strength to withstand the mechanical stresses occurring during installation and normal use.

Compliance is checked by the appropriate tests of 15.2 to 15.5 as follows:

- *for non-metallic boxes and enclosures intended for use in cast concrete classified according to 7.2.1.2 or 7.2.1.3, by the test of 15.2;*
- *for non-metallic boxes and enclosures intended for use in cast concrete and able to withstand 90 °C during the casting process classified according to 7.2.1.3, by the test of 15.3;*
- *for non-metallic boxes and enclosures classified according to*
 - a) *7.2.3,*
 - b) *7.2.1.1 or 7.2.2 and also classified according to 7.5.2 or 7.5.3,**by the test of 15.4*
- *for non-metallic boxes and enclosures, the parts which are intended to be accessible after the completion of the building process, by the test of 15.4*
- *for boxes and enclosures classified according to 7.1.4 by the test of 15.5.*

When an enclosure is too large to fit the test apparatus shown in Annex D of IEC 60068-2-75:1997, or where it is impractical to use the pendulum hammer for tests at low temperature, the tests are carried out in the same conditions as those specified in 15.2 or 15.4, but using the spring hammer according to IEC 60068-2-75 calibrated to the impact energy corresponding to the impact required by the relevant subclause 15.2 or 15.4.

15.2 Impact test at low temperature

The specimen shall be subjected to an impact test with a vertical hammer test apparatus (see Figure 21) placed on a pad of closed cell expanded sponge rubber 40 mm thick when uncompressed and having a density of approximately 538 kg/m³.

The whole arrangement together with the specimens shall be placed in a refrigerator, the temperature within being maintained for 2 h ± 15 min at

- *(–5 ± 2) °C for types as classified according to 7.5.1;*
- *(–15 ± 2) °C for types as classified according to 7.5.2;*
- *(–25 ± 2) °C for types as classified according to 7.5.3.*


At the end of this period, each specimen is subjected to an impact by means of a mass of 1 kg falling vertically from a height of 100 mm.

One blow is applied on the back and four equally spaced on the side walls.

After the test, the specimens shall show no damage leading to non-compliance with the standard.

Cracks passing through the material not visible with normal or corrected vision without magnification, surface cracks in fibre-reinforced mouldings and small indentations are disregarded.

Dimensions in millimetres



IEC

- 1 falling weight ($1\,000 \pm 1$) g
- 2 steel intermediate piece 100 g
- 3 slightly rounded edges
- 4 specimen
- 5 steel support (10 ± 1) kg

Figure 21 – Apparatus for impact test at low temperature

15.3 Compression test

The boxes and enclosures are placed in a heating cabinet for (60 ± 15) min at a temperature of $(+90 \pm 5)$ °C.

The boxes and enclosures are then allowed to cool down to ambient temperature.

After the test, the boxes and enclosures shall show neither deformation nor damage leading to non-compliance with the standard.

The boxes and enclosures are then placed between two flat hardwood plates each having a surface area sufficient to cover the face and back of the box. The plates are then loaded without impact with a force of (500 ± 5) N for $1 \text{ min} \pm 5 \text{ s}$ which is applied away from the front face of the box towards the back.

After the test, the box and the enclosure shall show no deformation or damage leading to non-compliance with the standard or affecting its further intended use.

During these two tests, the boxes and enclosures shall be fitted according to the manufacturer's instructions with the special part (if any) intended to improve the mechanical behaviour of the boxes and enclosures during the casting of the concrete.

For the test, any special part shall be delivered together with the box and the enclosure.

15.4 Impact test for boxes and enclosures

The specimens are checked by applying blows by means of the pendulum hammer test apparatus as described in IEC 60068-2-75 (test EHA), with an equivalent mass of 250 g.

NOTE The impact test apparatus described in Annex D of IEC 60068-2-75:1997 is the pendulum hammer.

For boxes classified according to 7.5.2 or 7.5.3, this test shall be performed by placing the assembly including the specimen and the mounting block to which it is attached in a refrigerator, the temperature within being maintained for $2 \text{ h} \pm 15 \text{ min}$ at the following temperature:

- $(-15 \pm 2) ^\circ\text{C}$ for types as classified according to 7.5.2;
- $(-25 \pm 2) ^\circ\text{C}$ for types as classified according to 7.5.3.


At the end of this period the specimens are removed from the refrigerator and immediately submitted to the impact test.

Specimens classified according to 7.2.1.1 intended to be flush-mounted in normal use are reverse-mounted for the purpose of the test, so that the rear surface of the specimen is accessible as shown in Figure 22.

Test specimens are mounted on a mounting block made from a 8 mm thick, 175 mm $\times$ 175 mm plywood sheet which is secured at its top and bottom edges by a rigid bracket. Inlet/outlet openings without knock-outs are left open. Where inlet/outlet openings are provided with knock-outs, one is opened.

Specimens classified according to 7.2.3 are mounted in accordance with the manufacturer's instruction.

The mounting support as shown in Figure 22 shall be designed to allow the specimen to be moved horizontally and turned about an axis perpendicular to the surface of the plywood sheet.

**Key**

- 1 box
- 2 mounting plate

Figure 22 – Mounting block for flush-type boxes and enclosures in order to apply blows on the rear surface

The design of the mounting support shall be such that

- *the mounting support has a mass of (10 ± 1) kg and is mounted on a rigid frame;*
- *the specimen can be mounted so that the point of impact lies in the vertical plane through the axis of the pivot;*
- *the plywood sheet can be turned about a vertical axis.*

Parts are submitted to an impact energy and a specified number of blows dependent on the distance of the accessible surface of the specimen from the surface of the plywood sheet when mounted as above. Distances A, B, C, D, E, F and G are defined as indicated in Table 7.

Table 7 – Determination of parts A, B, C, D, E, F and G

Part to be tested	Distance (<i>d</i>) from the surface of the plywood sheet mm	Parts
Front surfaces of covers and cover-plates of enclosures which are intended to be accessible after installation, and Rear surfaces of boxes and enclosures classified according to 7.5.2 or 7.5.3	Not applicable	A
Parts of boxes and enclosures intended to be accessible after installation and classified according to 7.2.1 semi-flush, 7.2.2 semi-flush or 7.2.3, with the exception of front surfaces already tested as parts A	$5 \leq d < 15$	B
	$15 \leq d < 25$	C
	$25 \leq d < 50$	D
	$50 \leq d < 100$	E
	$100 \leq d < 200$	F
	$200 \leq d$	G

The striking element shall fall from a height which is specified in Table 8.

Table 8 – Height of fall for impact test

Height of fall mm	Parts of enclosures to be subjected to the impact
80	A
120	B
160	C
200	D
240	E
320	F
400	G
The tolerance on the value of the height of fall is 1 %.	

The height of fall is the vertical distance between the position of the checking point, when the pendulum is released, and the position of that point at the moment of impact. The checking point is marked on the surface of the striking element where the line through the point of intersection of the axis of the steel tube of the pendulum and the striking element, perpendicular to the place through both axes, meets the surface.

NOTE Theoretically, the centre of gravity of the striking element should be the checking point. As the centre of gravity in practice is difficult to determine, the checking point is chosen as described above.

The specimens are subjected to blows, which are evenly distributed over the specimen.

The following blows are applied:

- *for each part A (as far as applicable), five blows as below:*
 - *one blow in the centre, then after the specimen has been moved horizontally;*
 - *one on each of the two least favourable points between the centre and the edges,*
 - *and then, after the specimen has been turned $90^\circ \pm 2^\circ$ about its axis perpendicular to the plywood*
 - *one on each of two similar points;*
- *for parts B (as far as applicable), C, D, E, F and G, four blows (see Figure 23) as below:*
 - *one blow is applied on the side of the specimen on which the blow can be applied after the plywood sheet has been turned $60^\circ \pm 2^\circ$ about a vertical axis;*
 - *one blow is applied on the opposite side on which the blow can be applied after the plywood sheet has been turned $60^\circ \pm 2^\circ$ about a vertical axis in the opposite direction;*
 - *after the specimen is turned $90^\circ \pm 2^\circ$ about its axis perpendicular to the plywood;*
 - *one blow is applied on one of the sides of the specimen on which the blow can be applied after the plywood sheet has been turned $60^\circ \pm 2^\circ$ about a vertical axis;*
 - *one blow is applied on the opposite side of the specimen on which the blow can be applied after the plywood sheet has been turned $60^\circ \pm 2^\circ$ about a vertical axis in the opposite direction.*

The blows shall not be applied to


- *knock-outs or to an area within 10 mm of them,*
- *other parts not necessary to achieve the declared IP of the enclosure,*
- *accessories and equipment complying with the other relevant standards,*
- *fixing means recessed below the surface, that are not subject to impacts in normal use.*

If inlet openings are provided, the specimen is so mounted that the two lines of blows are as nearly as possible equidistant from these openings.

After the test, the specimens shall show no damage leading to non-compliance with the standard.

There shall be no cracks passing through the material which are visible to normal or corrected vision without magnification. Surface cracks in fibre-reinforced mouldings and small indentations are ignored.

IECNORM.COM : Click to view the full PDF of IEC 60670-1:2015



IEC

Key

- 1 mounting support
2 pivot
3 specimen

Application of the blows			
Sketch	Total number of blows	Points of application	Parts to be tested
a)	3	One at the centre One between O and P* One between O and Q*	Front surfaces and rear surfaces of boxes or enclosures classified according to 7.2.1.1
b)	2	One between O and R* One between O and S*	
c)	2	One on the surface T* One on the surface U*	Accessible parts of boxes or enclosures intended to be surface-mounted in normal use except front surfaces and rear surfaces of boxes or enclosures classified according to 7.2.1.1
d)	2	One on the surface V* One on the surface Z*	

* The blow is applied to the most unfavourable point.

Figure 23 – Sequence of blows for parts A, B, C, D, E, F and G

15.5 Compression test for enclosures made of natural or synthetic rubber or a mixture of both

Boxes and enclosures classified according to 7.1.4 shall withstand a load which can be expected in normal use.

Compliance is checked by the following test:

The enclosure shall be mounted according to the instructions of the manufacturer in a horizontal position in or on a sheet of plywood. Then, the cover of the enclosure and special parts, if any, are loaded as follows (see Figure 24).

- a) *The cover is loaded with a force of 50 N, applied gradually on an area of 1 cm² at the foreseeable point of maximum deflection of the cover.*


The enclosure shall support the test load for 1 min without deflecting more than 3 mm. The deflection is to be measured when the force reaches the specified value, excluding any influence resulting from the deflection of the plywood and gasket compression.

The permanent deformation at any point on the cover, excluding the deflection of the plywood and gasket compression, shall not exceed 1 mm, measured 1 h after the load is removed.

- b) *A pressure of 50 N/cm² is gradually applied (up to a maximum force of 1 000 N) by means of a sheet of plywood with a thickness of (9 ± 1) mm, in contact with the whole area of the cover.*

The enclosure shall support the test load for 1 min and there shall be no damage to the enclosure.

After the test, the boxes or enclosures shall show no damage leading to non-compliance with this standard.




IEC


Key

- 1 test force
- 2 cylinder
- 3 plywood panel
- 4 boxes made of natural or synthetic rubber or a mixture of both
- 5 support

a) For test a (flush-mounted enclosures)


**Key**

- 1 test force
- 2 cylinder
- 3 solid surface
- 4 boxes made of natural or synthetic rubber or a mixture of both
- 5 support

b) For test a (surface-mounted enclosures)**Key**

- 1 test force
- 2 weight
- 3 solid surface
- 4 boxes made of natural or synthetic rubber or a mixture of both
- 5 plywood (9 ± 1) mm thick
- 6 support

c) For test b (flush-mounted enclosures)



Key

- 1 test force
- 2 weight
- 3 solid surface
- 4 boxes made of natural or synthetic rubber or a mixture of both
- 5 plywood (9 ± 1) mm thick

NOTE In order to achieve the specified conditions within the cabinet, it may be necessary to ensure constant circulation of the air within and, in general, to use a cabinet which is thermally insulated.

d) For test b (surface-mounted enclosures)

Figure 24 – Test devices for load compression test for enclosures made of natural or synthetic rubber or a mixture of both.

16 Resistance to heat

16.1 Parts of insulating material necessary to retain current-carrying parts

Parts of insulating material necessary to retain current-carrying parts and/or parts of the earthing circuit in position are subjected to a ball-pressure test by means of the apparatus according to IEC 60695-10-2 except that insulating parts necessary to retain earthing terminals in position shall be tested as specified in 16.2.

When it is not possible to carry out the test on the specimens, the test should be carried out on a piece at least 2 mm thick which is cut from the specimen. If this is not possible, no more than four layers, each cut from the same specimen, may be used, in which case the total thickness of the layers should be not less than 2,5 mm.

The part under test shall be placed on a steel plate at least 3 mm thick and in direct contact with it.

The surface of the part to be tested is placed in the horizontal position and a steel ball of 5 mm diameter is pressed against the surface with a force of $(20 \pm 0,5)$ N.

The test is made in a heating cabinet at a temperature of $(+125 \pm 2)$ °C. After (60 ± 5) min, the ball is removed from the specimen which is then cooled down within 10 s to approximately room temperature by immersion in cold water.

The diameter of the impression caused by the ball is measured and shall not exceed 2 mm.

16.2 Parts of insulating material not necessary to retain current-carrying parts

Parts of insulating material not necessary to retain current-carrying parts and/or parts of the earthing circuit in position, even though they are in contact with them, except for parts made of natural or synthetic rubber or a mixture of both are subjected to a ball pressure test in accordance with 16.1, but the test is made at a temperature of $(+70 \pm 2) ^\circ\text{C}$.

Parts of insulating material of flush-mounted enclosures classified according to 7.2.1.3 are subjected to the test described in 16.1 but at a temperature of $(+90 \pm 2) ^\circ\text{C}$.

If the test cannot be made on a complete enclosure, a suitable part may be cut from it for the purpose of the test.

16.3 Boxes and enclosures of insulating materials classified according to 7.2.2.2 or 7.2.2.3

16.3.1 Mechanical strength

Boxes and enclosures of insulating material(s) classified according to 7.2.2.2 or 7.2.2.3 shall have adequate mechanical strength at high temperature.

Compliance is checked by the following test.

A specimen of a box of each type and size involved, each having at least two threaded or unthreaded holes shall be tested.

A rigid crossbar (Figure 25) shall be secured across the face of each box with the size and type of screws normally provided by the box or wiring device manufacturer. The screws shall be secured in the threaded or unthreaded holes located at the face of the box by applying a torque according to the relevant column of Table 4.

A total force of 180 N, including the force exerted by the crossbar and any associated suspension means, shall be applied to the face of the box.

The boxes and enclosures shall be mounted, with the open face downward, in an air-circulating oven for 24 h at the following temperatures:


- $(+80 \pm 2) ^\circ\text{C}$ for boxes and enclosures classified according to 7.2.2.2;
- $(+105 \pm 2) ^\circ\text{C}$ for boxes and enclosures classified according to 7.2.2.3.

The box shall be supported at its open face by a flat plate that does not obstruct the test load support bracket.

After the oven ageing, the assembly shall be allowed to cool down to approximately ambient temperature in the oven, with the power switched off and the door opened.

The screws securing the crossbar to the box shall not have pulled out more than 6,3 mm. The screws shall be able to be removed by a screwdriver using a torque not exceeding 2,3 Nm.

Dimensions in millimetres



Key

A To align with the holes located at the face of the box.

Figure 25 – Rigid crossbar

16.3.2 Parts of insulating material necessary to retain parts of the earthing circuit

Parts of insulating material necessary to retain the earthing strap described in 11.2 shall be subjected to a pull test before and after ageing. After each test, the earthing strap shall not become loose or detached from the specimen.

Compliance is checked by the following tests.

The test shall be conducted on one specimen in the condition as delivered and on one specimen after it has been conditioned in an air-circulating oven for 168 h at 90 °C and then cooled to room temperature.

The test strap shown in Figure 4 shall be attached to the earthing strap by placing the slotted end under the earthing terminal screw. The threads of the earthing terminal shall not be stripped when the torque shown in the relevant column of Table 4 is applied.

For testing of the conditioned sample the test strap shall be attached prior to the conditioning.

With the specimen secured, a force of 45 N shall be applied to the test strap for 5 min in the direction perpendicular to the open face of the specimen.

The force shall be gradually applied in one smooth and continuous movement. If a tensile machine is used, a jaw separation speed of 10mm/min shall be applied.

17 Creepage distances, clearances and distances through sealing compound

See the relevant Part of 21 to 24 of the IEC 60670 series.

18 Resistance of insulating material to abnormal heat and fire

Parts of insulating material which might be exposed to thermal stresses due to electric effects, the deterioration of which might impair safety, shall not be unduly affected by abnormal heat and by fire.

Compliance is checked by means of the glow-wire test performed according to Clauses 4 to 10 of IEC 60695-2-11:2000, under the following conditions.

- *By the test made at 850 °C:*
 - *for parts of insulating material necessary to retain current-carrying parts and/or parts of the earthing circuit in position (with the exception of parts of insulating material needed to retain the earth terminal in position in a box), and*
 - *for parts of insulating material of boxes and enclosures classified according to 7.2.2, with the exception of parts protruding from the wall.*
- *By the test made at 650 °C:*
 - *for parts of insulating material not necessary to retain current-carrying parts in position (even though they are in contact with them), and*
 - *for parts of insulating material retaining earthing terminal in position;*
 - *for parts of insulating material of boxes and enclosures classified according to 7.2.2, protruding from the wall.*

A current-carrying part or a part of the earthing circuit retained by a mechanical means is considered to be retained in position. The use of grease or the like is not considered to be mechanical means.

External conductors cannot be considered as retaining the current-carrying parts.

In case of doubt, to determine whether an insulating material is necessary to retain current-carrying parts and parts of the earthing circuit in position, the device is examined without conductors while held in positions with the insulating material in question removed.

If the tests specified have to be made at more than one place on the same specimen, care shall be taken to ensure that any deterioration caused by previous tests does not affect the result of the test to be made.

Small parts, where each surface lies completely within a circle 15 mm in diameter, or where any part of the surface lies outside a 15 mm diameter circle and where it is not possible to fit a circle 8 mm in diameter on any of the surfaces, are not subjected to the test of this subclause (see Figure 26 for a diagrammatic representation).

When checking a surface, projections on the surfaces and holes which are not greater than 2 mm on the largest dimension are disregarded.

The tests are not made on parts of ceramic material.

The glow-wire test is applied to ensure that an electrically heated test wire under defined test conditions does not cause ignition of insulating parts or to ensure that a part of insulating material, which can be ignited by the heated test wire under defined conditions, has a limited time to burn without spreading fire by flame or burning parts or droplets falling down from the tested parts onto the pinewood board covered with a tissue paper.

If possible, the specimen should be a complete box or enclosure.

If the test cannot be made on a complete box or enclosure, a suitable part may be cut out for the purpose of the test.

The test is made on one specimen.

In case of doubt, the test shall be repeated on two further specimens.

The test is made by applying the glow wire once for (30 ± 1) s.

The specimen shall be positioned during the test in the most unfavourable position of its intended use (with the surface tested in a vertical position).


The tip of the glow wire shall be applied to the specified surface of the specimen taking into account the conditions of the intended use under which a heated or glowing element may come into contact with the specimen.

The specimen is regarded as having passed the glow-wire test if

- *there is no visible flame and no sustained glowing, or if*
- *flames and glowing at the specimen extinguish within 30 s after the removal of the glow wire.*

There shall be no ignition of the tissue paper or scorching of the board.

Dimensions in millimetres



IEC

Key

- 1 specimen
- 2 to be tested
- 3 no test is required

Figure 26 – Diagrammatic representation of the glow-wire test

19 Resistance to tracking

For boxes and enclosures with protection degree higher than IPX0, all parts of the insulating material retaining live parts in position shall be made of a material resistant to tracking.

For materials other than ceramic and where the creepage distances are less than twice the values specified in Clause 17, compliance is checked by the test of IEC 60112 on three specimens.

A flat surface of the part to be tested, if possible at least 15 mm × 15 mm and at least 3 mm thick, is placed in the horizontal position.

The material under test shall pass a proof-tracking index of 175 using test solution A with a time interval between drops of (30 ± 5) s.

No flashover or breakdown between electrodes shall occur before a total of 50 drops has fallen.

Alternatively, the CTI value for the material may be used. The CTI value shall not be less than 175.

20 Resistance to corrosion

Ferrous parts of boxes and enclosures shall be adequately protected against rusting.

Compliance is checked by the following test.

All grease is removed from the parts to be tested by immersion in a degreasing agent for (10 ± 1) min.

The parts are then immersed for (10 ± 1) min in a 10 % solution of ammonium chloride in water at a temperature of (20 ± 5) °C.

Without drying, but after shaking off any drops, the parts are placed for (10 ± 1) min in a box containing air saturated with moisture to a level of 91 % to 95 % at a temperature of (20 ± 5) °C.

After the parts have been dried for (10 ± 1) min in a heating cabinet at a temperature of (100 ± 5) °C, their surface shall show no sign of rust.

NOTE Traces of rust on cut edges and any yellowish film removable by rubbing are ignored. Cut edges also include punched holes and thread surfaces of tapped holes.

21 Electromagnetic compatibility (EMC)


Products covered by this standard are, in normal use, passive in respect to electromagnetic influences (emission and immunity).

Therefore, no tests are necessary.

Annex A (informative)

Examples of enclosures and parts thereof

Figure A.1 shows examples of enclosures and parts thereof.



Key

- 1 box
- 2 cover-plate
- 3 cover
- 4 pattern
- 5 accessory
- a** pattern + cover (only surface-type)
- b1** box + cover-plate (surface-type)
- b2** box + cover-plate (flush-type)

Figure A.1 – Examples of enclosures and parts thereof

Bibliography

IEC 60670 (all parts), *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations*

IEC 60670-21, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 21: Particular requirements for boxes and enclosures with provision for suspension means*

IEC 60670-22, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 22: Particular requirements for connecting boxes and enclosures*

IEC 60670-23, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 23: Particular requirements for floor boxes and enclosures*

IEC 60670-24, *Boxes and enclosures for electrical accessories for household and similar fixed electrical installations – Part 24: Particular requirements for enclosures for housing protective devices and other power dissipating electrical equipment*

IEC 61084 (all parts), *Cable trunking and ducting systems for electrical installations*

IEC 62444, *Cable glands for electrical installations*

ISO 1456, *Metallic coatings – Electrodeposited coatings of nickel plus chromium and of copper plus nickel plus chromium*

ISO 2081, *Metallic coatings – Electroplated coatings of zinc on iron or steel*

ISO 2093, *Electroplated coatings of tin – Specification and test methods*

SOMMAIRE

AVANT-PROPOS	69
1 Domaine d'application	71
2 Références normatives	71
3 Termes et définitions	72
4 Exigences générales	75
5 Notes générales sur les essais	75
6 Caractéristiques assignées	76
7 Classification	76
8 Marquage	77
9 Dimensions	78
10 Protection contre les chocs électriques	79
11 Dispositions pour la mise à la terre	79
11.1 Boîtes et enveloppes présentant des masses	79
11.2 Boîtes et enveloppes en matériau isolant classées selon 7.2.2.2 et 7.2.2.3	80
11.3 Boîtes ou enveloppes disposant de côtés démontables selon 7.1.2	82
11.4 Filetage de la borne de mise à la terre	82
12 Construction	82
12.1 Généralités	82
12.2 Couvercles, capots ou plaques de recouvrement ou parties de ceux-ci	83
12.2.1 Généralités	83
12.2.2 Fixations à vis	83
12.2.3 Fixations ne dépendant pas de vis et ne nécessitant pas un outil ou une clé pour leur manœuvre	83
12.2.4 Fixations ne dépendant pas de vis et nécessitant un outil ou une clé pour leur manœuvre	90
12.3 Trous de drainage	90
12.4 Montage de l'enveloppe	90
12.5 Boîtes et enveloppes avec orifices d'entrée pour câbles souples	90
12.6 Boîtes et enveloppes avec orifices d'entrée pour des applications autres que les câbles souples	90
12.7 Boîtes et enveloppes pourvues de serre-câble	91
12.8 Boîtes et enveloppes pourvues de dispositifs de retenue de câble	92
12.9 Parties défonçables prévues pour être ouvertes par des impacts mécaniques	93
12.9.1 Généralités	93
12.9.2 Tenue des parois défonçables	93
12.9.3 Enlèvement de la paroi défonçable	94
12.9.4 Surfaces plates entourant les parois défonçables	94
12.10 Fixations à vis	94
12.11 Fixation des boîtes et enveloppes classées selon 7.2.1	96
12.12 Fixation des boîtes et enveloppes encastrées et semi-encastrées classées selon 7.2.2.1	99
12.13 Boîtes et enveloppes classées selon 7.2.2.2 et 7.2.2.3	100
12.13.1 Généralités	100
12.13.2 Boîtes prévues pour montage sur une structure en bois intégrée dans un mur	101

12.13.3	Boîtes prévues pour montage sur une structure en bois intégrée dans un plafond	101
12.13.4	Boîtes prévues pour montage sur une structure métallique intégrée dans un mur	101
12.13.5	Volume intérieur des boîtes et enveloppes classées selon 7.2.2.2 et 7.2.2.3	102
12.13.6	Boîtes prévues pour montage dans une structure finie	103
12.14	Entrées de presse-étoupe	103
12.15	Boîtes et enveloppes pourvues d'entrées (sorties) ou orifices à manchon pour conduits	104
12.16	Volume intérieur des boîtes et enveloppes	104
13	Résistance au vieillissement, protection contre la pénétration de corps solides et contre la pénétration nuisible de l'eau	105
13.1	Résistance au vieillissement	105
13.2	Protection contre la pénétration de corps solides	107
13.3	Protection contre la pénétration nuisible de l'eau	108
14	Résistance d'isolement et rigidité diélectrique	113
15	Résistance mécanique	115
15.1	Généralités	115
15.2	Essai de choc à basse température	115
15.3	Essai de compression	117
15.4	Essai de choc pour boîtes et enveloppes	117
15.5	Essai de compression pour les enveloppes en caoutchouc naturel ou synthétique ou faites d'un mélange des deux	122
16	Résistance à la chaleur	124
16.1	Parties en matériau isolant nécessaires au maintien des pièces transportant le courant	124
16.2	Parties en matériau isolant non nécessaires au maintien des pièces transportant le courant	125
16.3	Boîtes et enveloppes en matériau isolant classées selon 7.2.2.2 ou 7.2.2.3	125
16.3.1	Résistance mécanique	125
16.3.2	Parties de matériau isolant nécessaires pour maintenir en place les parties du circuit de mise à la terre	126
17	Lignes de fuite, distances d'isolement dans l'air et distances à travers le matériau d'étanchéité	126
18	Résistance du matériau isolant à la chaleur anormale et au feu	127
19	Résistance au cheminement	129
20	Résistance à la corrosion	129
21	Compatibilité électromagnétique (CEM)	129
Annexe A (informative) Exemples d'enveloppes et de leurs éléments		130
Bibliographie		131
Figure 1 – Exemples de membranes et de passe-fil		74
Figure 2 – Démonstration d'absence de pénétration du volume interne		79
Figure 3 – Bande de mise à la terre		81
Figure 4 – Languette d'essai		81
Figure 5 – Disposition pour l'essai des capots ou plaques de recouvrement (voir 12.2.3.2 and 12.2.3.3)		85

Figure 6 – Calibre pour la vérification des contours des couvercles, capots ou plaques de recouvrement	86
Figure 7 – Exemples d'applications du calibre de la Figure 6 sur des capots fixés sans vis sur une surface de montage ou de support.....	87
Figure 8 – Critères de conformité d'application du calibre de la Figure 6	88
Figure 9 – Calibre pour la vérification des rainures, trous et dépouilles inverses	89
Figure 10 – Schéma montrant la direction d'application du calibre de la Figure 9.....	89
Figure 11 – Appareil pour l'essai des serre-câbles	92
Figure 12 – Exemple de bloc de montage pour des boîtes destinées à être encastrées dans de la maçonnerie (pour montage encastré ou semi-encastré)	97
Figure 13 – Exemple de fixation du dispositif auxiliaire monté sur un échantillon.....	98
Figure 14 – Exemple d'appareil d'essai.....	99
Figure 15 – Vérification des moyens de fixation des boîtes et enveloppes classées selon 7.2.2.1	100
Figure 16 – Essai de la force et mesure du déplacement	102
Figure 17 – Mesure du volume	105
Figure 18 – Surfaces de référence pour boîtes et enveloppes	110
Figure 19 – Paroi d'essai.....	111
Figure 20 – Exemple de volume protégé.....	113
Figure 21 – Appareil pour l'essai de choc à basse température	116
Figure 22 – Bloc de montage pour boîtes et enveloppes pour montage encastré pour application des coups sur l'arrière	118
Figure 23 – Séquence des coups pour les parties A, B, C, D, E, F et G	121
Figure 24 – Appareils d'essai pour l'essai de compression pour les enveloppes en caoutchouc naturel ou synthétique ou faites dans un mélange des deux	124
Figure 25 – Barre rigide.....	126
Figure 26 – Représentation schématique de l'essai au fil incandescent.....	128
Figure A.1 – Exemples d'enveloppes et de leurs éléments	130
Tableau 1 – Classification des boîtes et enveloppes (1 de 2)	76
Tableau 2 – Forces à appliquer aux couvercles, capots, plaques de recouvrement ou aux organes de manœuvre dont la fixation ne dépend pas de vis	84
Tableau 3 – Forces et couples à appliquer aux serre-câbles	92
Tableau 4 – Couples de serrage pour la vérification de la résistance mécanique des vis	96
Tableau 5 – Valeurs du couple d'essai pour les presse-étoupe	104
Tableau 6 – Tension d'essai pour l'essai de rigidité diélectrique.....	114
Tableau 7 – Détermination des parties A, B, C, D, E, F et G	118
Tableau 8 – Hauteur de chute pour l'essai de choc	119

COMMISSION ÉLECTROTECHNIQUE INTERNATIONALE

**BOÎTES ET ENVELOPPES POUR APPAREILLAGE
ÉLECTRIQUE POUR INSTALLATIONS ÉLECTRIQUES
FIXES POUR USAGES DOMESTIQUES ET ANALOGUES –****Partie 1: Exigences générales****AVANT-PROPOS**

- 1) La Commission Electrotechnique Internationale (IEC) est une organisation mondiale de normalisation composée de l'ensemble des comités électrotechniques nationaux (Comités nationaux de l'IEC). L'IEC a pour objet de favoriser la coopération internationale pour toutes les questions de normalisation dans les domaines de l'électricité et de l'électronique. A cet effet, l'IEC – entre autres activités – publie des Normes internationales, des Spécifications techniques, des Rapports techniques, des Spécifications accessibles au public (PAS) et des Guides (ci-après dénommés "Publication(s) de l'IEC"). Leur élaboration est confiée à des comités d'études, aux travaux desquels tout Comité national intéressé par le sujet traité peut participer. Les organisations internationales, gouvernementales et non gouvernementales, en liaison avec l'IEC, participent également aux travaux. L'IEC collabore étroitement avec l'Organisation Internationale de Normalisation (ISO), selon des conditions fixées par accord entre les deux organisations.
- 2) Les décisions ou accords officiels de l'IEC concernant les questions techniques représentent, dans la mesure du possible, un accord international sur les sujets étudiés, étant donné que les Comités nationaux de l'IEC intéressés sont représentés dans chaque comité d'études.
- 3) Les Publications de l'IEC se présentent sous la forme de recommandations internationales et sont agréées comme telles par les Comités nationaux de l'IEC. Tous les efforts raisonnables sont entrepris afin que l'IEC s'assure de l'exactitude du contenu technique de ses publications; l'IEC ne peut pas être tenue responsable de l'éventuelle mauvaise utilisation ou interprétation qui en est faite par un quelconque utilisateur final.
- 4) Dans le but d'encourager l'uniformité internationale, les Comités nationaux de l'IEC s'engagent, dans toute la mesure possible, à appliquer de façon transparente les Publications de l'IEC dans leurs publications nationales et régionales. Toutes divergences entre toutes Publications de l'IEC et toutes publications nationales ou régionales correspondantes doivent être indiquées en termes clairs dans ces dernières.
- 5) L'IEC elle-même ne fournit aucune attestation de conformité. Des organismes de certification indépendants fournissent des services d'évaluation de conformité et, dans certains secteurs, accèdent aux marques de conformité de l'IEC. L'IEC n'est responsable d'aucun des services effectués par les organismes de certification indépendants.
- 6) Tous les utilisateurs doivent s'assurer qu'ils sont en possession de la dernière édition de cette publication.
- 7) Aucune responsabilité ne doit être imputée à l'IEC, à ses administrateurs, employés, auxiliaires ou mandataires, y compris ses experts particuliers et les membres de ses comités d'études et des Comités nationaux de l'IEC, pour tout préjudice causé en cas de dommages corporels et matériels, ou de tout autre dommage de quelque nature que ce soit, directe ou indirecte, ou pour supporter les coûts (y compris les frais de justice) et les dépenses découlant de la publication ou de l'utilisation de cette Publication de l'IEC ou de toute autre Publication de l'IEC, ou au crédit qui lui est accordé.
- 8) L'attention est attirée sur les références normatives citées dans cette publication. L'utilisation de publications référencées est obligatoire pour une application correcte de la présente publication.
- 9) L'attention est attirée sur le fait que certains des éléments de la présente Publication de l'IEC peuvent faire l'objet de droits de brevet. L'IEC ne saurait être tenue pour responsable de ne pas avoir identifié de tels droits de brevets et de ne pas avoir signalé leur existence.

La Norme internationale IEC 60670-1 a été établie par le sous-comité SC23B: Prises de courant et interrupteurs, du comité d'études 23 de l'IEC: Petit appareillage

Cette deuxième édition annule et remplace la première édition parue en 2002 et son Amendement 1:2011. Cette édition constitue une révision technique.

Cette édition inclut les modifications techniques majeures suivantes par rapport à l'édition précédente: révision du Tableau 1 – Classification.

Le texte de cette norme est issu des documents suivants:

FDIS	Rapport de vote
23B/1176/FDIS	23B/1184/RVD

Le rapport de vote indiqué dans le tableau ci-dessus donne toute information sur le vote ayant abouti à l'approbation de cette norme.

Cette publication a été rédigée selon les Directives ISO/IEC, Partie 2.

Dans la présente norme, les caractères d'imprimerie suivants sont employés:

Dans cette norme, les caractères suivants sont utilisés:

- exigences: caractères romains;
- *spécifications d'essais: en italique;*
- notes explicatives: en petits caractères romains.

Une liste de toutes les parties de la série IEC 60670, publiées sous le titre général *Boîtes et enveloppes pour appareillage électrique pour installations électriques fixes pour usages domestiques et analogues*, peut être consultée sur le site web de l'IEC.

Le comité a décidé que le contenu de cette publication ne sera pas modifié avant la date de stabilité indiquée sur le site web de l'IEC sous "<http://webstore.iec.ch>" dans les données relatives à la publication recherchée. A cette date, la publication sera

- reconduite,
- supprimée,
- remplacée par une édition révisée, ou
- amendée.

BOÎTES ET ENVELOPPES POUR APPAREILLAGE ÉLECTRIQUE POUR INSTALLATIONS ÉLECTRIQUES FIXES POUR USAGES DOMESTIQUES ET ANALOGUES –

Partie 1: Exigences générales

1 Domaine d'application

La présente partie de l'IEC 60670 s'applique aux boîtes, parties d'enveloppes et enveloppes (ci-après désignées par les termes "boîtes" et "enveloppes") destinées à des appareillages électriques ayant une tension assignée ne dépassant pas 1 000 V en courant alternatif et 1 500 V en courant continu prévus pour des installations électriques fixes à usages domestiques ou analogues, pour l'intérieur ou pour l'extérieur.

Les boîtes et enveloppes conformes à la présente norme sont utilisables à des températures ambiantes ne dépassant pas habituellement +40 °C, mais leur température moyenne sur une période de 24 h ne dépasse pas +35 °C, avec une limite inférieure de la température de l'air ambiant de –5 °C.

Au cours de l'installation, il est admis que la température soit hors de la plage de températures ci-dessus d'après la classification des boîtes et des enveloppes.

La présente Norme internationale est prévue pour s'appliquer aux boîtes et enveloppes pour appareillages électriques du domaine du comité d'étude 23 de l'IEC.

Il est admis d'utiliser la présente norme comme document de référence pour d'autres comités et sous-comités d'études de l'IEC.

Les boîtes et enveloppes qui constituent une partie intégrante d'un appareillage électrique dont elles assurent la protection contre des influences externes (par exemple chocs mécaniques, pénétration de corps solides ou de l'eau, etc.) sont couvertes par la norme applicable à cet appareillage.

Cette norme ne s'applique pas aux

- rosaces de plafond;
- connecteurs supports de luminaires;
- boîtes, enveloppes et parties d'enveloppes spécifiquement conçues pour être utilisées dans les systèmes de goulottes et de conduits profilés conformes à l'IEC 61084 et qui ne sont pas prévues pour être installées en dehors de ces systèmes.

2 Références normatives

Les documents suivants sont cités en référence de manière normative, en intégralité ou en partie, dans le présent document et sont indispensables pour son application. Pour les références datées, seule l'édition citée s'applique. Pour les références non datées, la dernière édition du document de référence s'applique (y compris les éventuels amendements).

IEC 60068-2-75:1997¹, *Essais d'environnement – Partie 2-75: Essais – Essai Eh: Essais aux marteaux*

IEC 60112:2003, *Méthode de détermination des indices de résistance et de tenue au cheminement des matériaux isolants solides*

IEC 60423:2007, *Systèmes de conduits pour la gestion du câblage – Diamètres extérieurs des conduits pour installations électriques et filetages pour conduits et accessoires*

IEC 60529:1989, *Degrés de protection procurés par les enveloppes (Code IP)*

IEC 60529:1989/AMD1:1999/AMD2:2013, *Degrés de protection procurés par les enveloppes (Code IP)*

IEC 60695-2-11:2000², *Essais relatifs aux risques du feu – Partie 2-11: Essais au fil incandescent/chauffant – Méthode d'essai d'inflammabilité pour produits finis*

IEC 60695-10-2:2003³, *Essais relatifs aux risques du feu – Partie 10-2: Chaleurs anormales – Essai à la bille*

IEC 60981:2004, *Conduits électriques très lourds rigides en acier*

IEC 61032:1997, *Protection des personnes et des matériels par les enveloppes – Calibres d'essai pour la vérification*

IEC 61140:2001, *Protection contre les chocs électriques – Aspects communs aux installations et aux matériels*

IEC 61140:2001/AMD1:2004, *Protection contre les chocs électriques – Aspects communs aux installations et aux matériels*

Guide ISO/IEC 51, *Aspects liés à la sécurité – Principes directeurs pour les inclure dans les normes*

3 Termes et définitions

Pour les besoins du présent document, les termes et définitions suivants s'appliquent.

3.1

enveloppe

combinaison de parties, telles que boîtes, capots, plaques de recouvrement, couvercles, extensions de boîtes, appareillages, etc., assurant, après assemblage et montage comme en usage normal, un degré approprié de protection contre les influences externes et un degré déterminé de protection contre les contacts avec les parties actives enfermées, dans toutes les directions accessibles

Note 1 à l'article: Voir l'Annexe A.

¹ Première édition. Cette édition a été remplacée en 2014 par l'IEC 60068-2-75:2014, *Essais d'environnement – Partie 2-75: Essais – Essai Eh: Essais aux marteaux*.

² Première édition. Cette édition a été remplacée en 2014 par l'IEC 60695-2-11:2014, *Essais relatifs aux risques du feu – Partie 2-11: Essais au fil incandescent/chauffant – Méthode d'essai d'inflammabilité pour produits finis (GWEPT)*

³ Seconde édition. Cette édition a été remplacée en 2014 par l'IEC 60695-10-2:2014, *Essais relatifs aux risques du feu – Partie 10-2: Chaleurs anormales – Essai à la bille*

3.2

boîte

partie d'une enveloppe pourvue de moyens pour fixer un capot, une plaque de recouvrement, un appareillage, etc., et qui est prévue pour recevoir des appareillages (tels que socles de prises, interrupteurs, etc.)

3.3

extension de boîte

partie d'une enveloppe destinée à l'extension d'une boîte dans le but soit d'accroître son volume interne soit de l'ajuster lors du montage encastré ou semi-encastré avec la surface finie d'un mur ou élément similaire

3.4

couvercle

capot

plaque de recouvrement

partie d'une enveloppe ne constituant pas partie intégrante ou partie de l'appareillage, qui peut soit maintenir un appareillage dans sa position soit l'enfermer

3.5

couvercle de rehausse

couvercle destiné à être monté directement sur une boîte pour permettre la fixation d'appareillages et pour augmenter le volume interne de l'enveloppe

Note 1 à l'article: La partie centrale du couvercle est rehaussée afin de s'ajuster à l'épaisseur du mur ou du plafond et pour permettre le montage d'un appareillage au ras de la surface du mur ou du plafond.

3.6

partie conductrice accessible

partie conductrice d'un équipement électrique susceptible d'être touchée et qui n'est pas normalement sous tension mais peut le devenir lorsque l'isolation principale est défailante

3.7

boîte ou enveloppe pour montage en saillie

boîte ou enveloppe destinée à être montée en saillie sur une surface

Note 1 à l'article: Voir l'Annexe A.

3.8

boîte ou enveloppe pour montage encastré

boîte ou enveloppe destinée à être encastrée de façon à affleurer la surface de montage

Note 1 à l'article: Voir l'Annexe A.

3.9

boîte ou enveloppe pour montage semi-encastré

boîte ou enveloppe destinée à être encastrée dans une surface de montage et qui fait partiellement saillie au niveau de la surface de montage

3.10

presse-étoupe

dispositif conçu pour permettre l'introduction d'un câble, d'un câble souple ou d'un conducteur isolé dans une enveloppe, et qui assure l'étanchéité et la retenue; il peut aussi assurer d'autres fonctions telles que la mise à la terre, la liaison de continuité, l'isolement, le protège-câble, le détensionnement du câble ou une combinaison de celles-ci

3.11

joint

matériau utilisé pour remplir l'espace compris entre l'intérieur d'un presse-étoupe et le câble qui le traverse, habituellement comprimé par le presse-étoupe et formant donc un joint

3.12

joint d'étanchéité

matériau introduit entre surfaces conjuguées d'une boîte qui forme un joint par compression


3.13

passe-fil

composant utilisé pour soutenir et protéger le câble ou le conduit au point d'entrée, qui peut également prévenir la pénétration de l'humidité ou de polluants

Note 1 à l'article: Voir Figure 1.

[SOURCE: IEC 60050-581:2008, 581-27-19, modifiée]



Légende

- 1 boîte
- 2 membrane d'entrée
- 3 enveloppe
- 4 membrane de protection
- 5 passe-fil

Figure 1 – Exemples de membranes et de passe-fil

3.14

membrane d'entrée

composant ou partie intégrante d'une enveloppe utilisé(e) pour protéger le câble et qui peut être utilisé(e) pour soutenir le câble ou le conduit au point d'entrée

Note 1 à l'article: Une membrane d'entrée peut également prévenir la pénétration de l'humidité ou de polluants et elle peut faire partie d'un passe-fil (voir Figure 1).

3.15

membrane de protection

composant ou partie intégrante d'une enveloppe qui n'est pas destiné(e) à être traversé(e) en utilisation normale et qui est prévu(e) pour assurer une protection contre la pénétration d'eau ou de corps solides et/ou permettre le fonctionnement d'un appareillage

Note 1 à l'article: Voir Figure 1.

3.16

matériau composite

combinaison d'un métal et d'un matériau isolant

3.17**orifice à manchon**

entrée ouverte d'une boîte permettant l'insertion et la retenue d'un conduit

3.18**retenue de câble**

capacité à limiter le déplacement d'un câble contre les forces de traction

3.19**serre-câble**

capacité à limiter le déplacement d'un câble souple contre les forces de traction et pression et les torsions

3.20**bouchon**

composant utilisé pour obturer une ouverture ou une paroi défonçable ouverte

4 Exigences générales

Les boîtes et les enveloppes doivent être conçues et construites de façon à ce qu'en utilisation normale, leurs performances soient fiables et que la sécurité soit assurée en réduisant les risques à un niveau tolérable, tel que défini dans le Guide ISO/IEC 51.

La conformité est vérifiée si toutes les exigences et tous les essais applicables spécifiés sont satisfaits.

5 Notes générales sur les essais

5.1 Les essais selon cette norme sont des essais de type.

Sauf spécification contraire, les boîtes et enveloppes sont soumises aux essais dans leur état de livraison.

Les appareillages conformes à d'autres normes ne sont pas soumis à de nouveaux essais.

Les essais sur les boîtes et enveloppes en matériau isolant doivent être effectués après une période de conditionnement préalable d'au moins 10 jours à la température ambiante et à une humidité relative de l'air comprise entre 45 % et 85 %.

Sauf spécification contraire, les essais sont effectués dans l'ordre des articles à une température ambiante comprise entre ± 15 °C et ± 35 °C sur un lot de trois échantillons.

En cas de doute, les essais sont réalisés à une température ambiante de $+(20 \pm 5)$ °C sur un lot de trois échantillons neufs.

5.2 Les échantillons sont soumis à tous les essais applicables et les exigences sont satisfaites si tous les essais sont réalisés avec succès.

Si l'un des échantillons ne satisfait pas à un essai en raison d'un défaut de montage ou de fabrication, cet essai de même que ceux qui l'ont précédé et qui ont pu avoir une influence sur le résultat du dernier essai doivent être répétés sur un autre lot complet d'échantillons. Les essais qui suivent doivent eux aussi être réalisés, sur ce même lot d'échantillons, dans l'ordre demandé. Au terme de ces essais, les échantillons doivent tous être conformes aux exigences.

NOTE Lorsqu'il présente le premier lot d'échantillons, le demandeur peut aussi soumettre le lot supplémentaire qui peut s'avérer nécessaire si un échantillon est défaillant. Le laboratoire d'essais peut alors, sans autre demande, soumettre le lot supplémentaire d'échantillons à l'essai et ne le rejeter qu'en cas de nouveau défaut. Si le lot supplémentaire d'échantillons n'est pas fourni en même temps, l'échec de l'un des échantillons entraînera le rejet.

6 Caractéristiques assignées

Voir la partie applicable des Parties 21 à 24 de la série IEC 60670.

7 Classification

Les boîtes et enveloppes sont classées selon le Tableau 1. (Toutes les références de classification utilisées dans ce document, se rapportent directement à ce tableau.)

Tableau 1 – Classification des boîtes et enveloppes (1 de 2)

Critères de classification		
7.1 Nature du matériau	7.1.1 Isolant	
	7.1.2 Métallique	
	7.1.3 Composite	
	7.1.4 Caoutchouc naturel ou synthétique ou mélange des deux	
7.2 Type de montage	7.2.1 Encastrées, semi-encastrées dans des murs massifs, des plafonds ou des planchers	7.2.1.1 Ne convient pas au montage dans le béton
		7.2.1.2 Convient au montage dans le béton avec une température maximale au cours du processus de coulage de +60 °C
		7.2.1.3 Convient au montage dans le béton avec une température maximale au cours du processus de coulage de +90 °C
	7.2.2 Encastrées ou semi-encastrées dans des murs creux, des plafonds creux, des planchers creux ou dans des meubles	7.2.2.1 Classe Ha
		7.2.2.2 Classe Hb pour les murs
		7.2.2.3 Classe Hb pour les plafonds
	7.2.3 Montées en saillie sur des murs, des plafonds, des planchers ou des meubles	
7.3 Type(s) d'entrées (de sorties) ^a	7.3.1 Avec entrées pour câbles gainés pour installations fixes	
	7.3.2 Avec entrées pour câbles souples	
	7.3.3 Avec entrées pour conduits lisses ou annelés	
	7.3.4 Avec entrées pour conduits filetés	
	7.3.5 Avec entrées pour d'autres types de conducteurs/câbles ou conduits.	
	7.3.6 Avec orifice à manchon	
	7.3.7 Sans entrée. Les ouvertures d'entrée seront pratiquées pendant l'installation	

Tableau 1 (2 de 2)

Critères de classification		
7.4 Moyens de fixation	7.4.1 Avec retenue de câble	
	7.4.2 Avec serre-câble	
	7.4.3 Avec fixation de conduit souple	
	7.4.4 Sans fixation	
7.5 Température minimale pendant l'installation	7.5.1 −5 °C	
	7.5.2 −15 °C	
	7.5.3 −25 °C	
7.6 Degré de protection contre l'accès aux parties dangereuses et contre les effets nuisibles dus à la pénétration de corps solides étrangers selon l'IEC 60529 avec un degré minimum IP 2X		
7.7 Le degré de protection contre les effets nuisibles dus à la pénétration d'eau selon l'IEC 60529		
7.8 Degré de protection de la partie montée à l'intérieur d'un mur creux des boîtes classées selon 7.2.2.1	7.8.1 IP 2X	
	7.8.2 > IP2X	
7.9 Dispositions pour la fixation des appareillages dans les boîtes	7.9.1 Boîtes équipées de vis	
	7.9.2 Boîtes prévues pour recevoir des vis	
	7.9.3 Boîtes prévues pour recevoir des griffes	
	7.9.4 Boîtes prévues pour recevoir d'autres dispositifs	
a Les boîtes et enveloppes peuvent avoir plus d'un type d'entrée.		
NOTE Dans les pays suivants, les boîtes et enveloppes de classe Ha sont utilisées: BR, CH, DE, FR, IT, NO, PT, SE, UK		

8 Marquage

8.1 Les marquages apposés sur les boîtes et enveloppes doivent comporter les éléments suivants:

- a) le nom, la marque commerciale ou une marque d'identification du fabricant ou du vendeur responsable.

De plus, les marquages des enveloppes doivent comporter:

- b) un premier chiffre caractéristique pour le degré de protection contre l'accès aux parties dangereuses et contre les effets nuisibles dus à la pénétration de corps solides étrangers, s'il est déclaré comme supérieur à 4 auquel cas le second chiffre caractéristique doit aussi être indiqué;
- c) un second chiffre caractéristique pour le degré de protection contre les effets nuisibles dus à la pénétration d'eau, s'il est déclaré comme supérieur à 2 auquel cas le premier chiffre caractéristique doit aussi être indiqué;

IPXX

- d) le marquage suivant  sur les capots des enveloppes encastrées prévues pour un montage sur des surfaces rugueuses et dont le degré IP est affecté par la surface (voir la Figure 5).

Le degré de protection IP doit, le cas échéant, être marqué sur la partie extérieure de l'enveloppe de façon à être facilement visible lorsque l'enveloppe est montée et raccordée comme en usage normal;

- e) la référence de type, qui peut être un numéro de catalogue.

NOTE Dans le pays suivant, le marquage de la référence de type n'est pas utilisé: UK.

- f) pour les boîtes et les enveloppes classées selon 7.2.2.2 et 7.2.2.3, le volume minimal interne en cm^3 tel qu'il a été déterminé par l'essai de 12.16. Le volume interne doit être marqué à l'intérieur de la boîte ou de l'enveloppe. Le marquage d'une boîte ou d'une enveloppe doit être tel que la valeur puisse être lue après installation de la boîte de façon normale, mais avant l'installation des dispositifs de câblage et du câble;

Les informations suivantes doivent être marquées sur la boîte et l'enveloppe ou fournies par le fabricant, sur le plus petit emballage ou dans les instructions du fabricant dont la fourniture avec le produit n'est pas exigée:

- g) $+90\text{ }^{\circ}\text{C}$ pour les boîtes et les enveloppes classées selon 7.2.1.3;
- h) les informations nécessaires concernant les ouvertures qui peuvent être pratiquées pendant l'installation dans le cas de boîtes et d'enveloppes classées selon 7.3.7;
- i) la température minimale pendant l'installation des boîtes classées selon 7.5.2 et 7.5.3;
- j) le symbole H_a pour les boîtes classées selon 7.2.2.1, le symbole H_b pour les boîtes classées selon 7.2.2.2 et 7.2.2.3.

A moins que cela ne soit évident, des informations complémentaires pour l'utilisation correcte de l'enveloppe doivent être données dans les instructions du fabricant dont la fourniture avec le produit n'est pas exigée.

Dans des cas particuliers visant à l'obtention d'un degré de protection supérieur par l'utilisation de pièces spéciales, il convient de fournir une feuille d'instructions indiquant le degré de protection supérieur. Dans un tel cas, le marquage couvre le degré de protection initial.

8.2 Le marquage appliqué sur le produit doit être durable et facilement lisible.

La conformité à 8.1 et 8.2 est vérifiée par examen et par l'essai suivant.

L'essai est effectué en frottant le marquage à la main pendant 15 s avec un chiffon imbibé d'eau et de nouveau pendant 15 s avec un chiffon imbibé d'essence.

NOTE Les marquages effectués par moulage, pression ou gravure sont considérés comme durables et ne sont donc pas soumis à cet essai.

Il est recommandé que l'essence utilisée se compose d'hexane comme solvant avec une teneur maximale en hydrocarbures aromatiques de 0,1 % en volume, un indice de kauri-butanol d'environ 29, un point d'ébullition initial d'environ $+65\text{ }^{\circ}\text{C}$, un point sec d'environ $+69\text{ }^{\circ}\text{C}$ et une masse volumique d'environ $0,68\text{ g/cm}^3$.

Après l'essai, le marquage doit encore être lisible.

9 Dimensions

Les boîtes et enveloppes doivent être conformes aux feuilles de normes appropriées, le cas échéant.

La conformité est vérifiée par examen et par mesure.

10 Protection contre les chocs électriques

Les boîtes et enveloppes doivent être conçues de façon telle que, lorsqu'elles sont assemblées, équipées et installées comme en usage normal conformément aux instructions du fabricant, les parties actives ne soient pas accessibles.

Lorsque les enveloppes sont fournies sans capot, plaque de recouvrement ou appareillage, elles sont soumises aux essais équipées des pièces appropriées installées selon les instructions du fabricant.

La conformité est vérifiée par examen et en cas de doute par l'essai suivant.

Les enveloppes doivent être soumises à l'essai avec le calibre d'essai 11 de l'IEC 61032 appliqué pendant 1 min avec une force de 20 N et ce calibre d'essai ne doit pas pénétrer dans le volume interne de l'enveloppe, comme cela est représenté à la Figure 2.




Figure 2 – Démonstration d'absence de pénétration du volume interne

Les essais doivent être réalisés sur les parties accessibles après installation.

De plus, toutes les enveloppes conformes à 7.1.1, 7.1.3 et 7.1.4 avec des parties en matériau thermoplastique ou élastomère doivent être soumises pendant 1 min à une force appliquée avec la pointe du calibre d'essai 11 de l'IEC 61032 mais à une température ambiante de $+(35 \pm 2) ^\circ\text{C}$, les enveloppes étant à cette température.

Ce calibre est appliqué avec une force de 75 N à tous les emplacements où l'affaiblissement du matériau isolant pourrait compromettre la sécurité, à l'exception des membranes, des passe-fil, des parties défonçables ou parties analogues.

Les parties défonçables sont soumises aux essais du 12.9.2.

11 Dispositions pour la mise à la terre

11.1 Boîtes et enveloppes présentant des masses

Les boîtes et enveloppes présentant des masses doivent être pourvues d'un dispositif de mise à la terre de faible résistance ou doivent prévoir des dispositions pour l'équipement avec un tel dispositif de mise à la terre. Pour les besoins de cette exigence, les petites vis ou pièces analogues isolées des parties actives et servant à la fixation des bases, des capots ou des plaques de recouvrement, etc., ne sont pas considérées comme des masses.

Les masses des capots ou des plaques de recouvrement doivent être raccordées, par l'intermédiaire d'une connexion de faible résistance, au dispositif de mise à la terre quand elles sont équipées comme en usage normal.

La conformité est vérifiée par l'essai suivant:

On fait passer un courant alternatif de (25 ± 1) A, fourni par une source de tension à vide ne dépassant pas 12 V, entre la borne de terre et, successivement, chaque partie conductrice accessible. La chute de tension entre la borne de terre et chaque partie conductrice accessible est mesurée et la résistance est calculée à partir du courant et de cette chute de tension.

En aucun cas la résistance ne doit dépasser 0,05 Ω .

Il convient de veiller à ce que la résistance de contact entre l'extrémité de la sonde de mesure et la partie conductrice accessible en essai n'ait pas d'influence sur les résultats des essais.

NOTE Pour les boîtes et enveloppes isolantes présentant un degré de protection supérieure à IPX0, des dispositions peuvent être prises pour ajouter des moyens pour la continuité effective du conducteur de mise à la terre quand plus d'une entrée est prévue.


Les dispositifs de mise à la terre ou les dispositions pour l'équipement de tels dispositifs de mise à la terre doivent être placés de sorte que:

- les dispositifs soient facilement accessibles au travers de la face ouverte de la boîte, et
- le démontage d'un appareillage monté dans la boîte ne perturbe pas la continuité du circuit de mise à la terre, et
- les dispositifs ne fassent pas partie d'un capot démontable, de l'arrière ou d'un côté de la boîte ou de l'enveloppe.


La conformité est vérifiée par examen.

11.2 Boîtes et enveloppes en matériau isolant classées selon 7.2.2.2 et 7.2.2.3

Les boîtes et enveloppes en matériau isolant doivent être pourvues au minimum d'une bande de mise à la terre ayant une borne à vis pour la mise à la terre de capacité de connexion d'au moins 4 mm². La conception de la bande de mise à la terre doit garantir que les étriers de montage métalliques des appareils montés dans la boîte ainsi que les capots métalliques installés sur la boîte sont connectés aux conducteurs de mise à la terre (voir les Figures 3 et 4).

**Légende**

- 1 bande de mise à la terre
- 2 vis de borne de mise à la terre
- 3 boîte en plastique
- 4 appareillage
- 5 capot métallique
- 6 étrier métallique de montage de l'appareillage
- 7 borne de mise à la terre de l'appareillage
- 8 bretelle de liaison

Figure 3 – Bande de mise à la terre**Figure 4 – Languette d'essai**

La conformité est vérifiée par examen.

La bande de mise à la terre doit être fixée de façon sûre à la boîte ou à l'enveloppe.

La conformité est vérifiée par l'essai de 16.3.2.

11.3 Boîtes ou enveloppes disposant de côtés démontables selon 7.1.2

Une boîte ou une enveloppe classée selon 7.1.2 et qui dispose de côtés démontables doit être construite de sorte que la liaison électrique entre des parties détachables comprenne au moins une connexion par vis.

La conformité est vérifiée par examen.

11.4 Filetage de la borne de mise à la terre

Le filetage de la borne de mise à la terre livrée avec ou intégrée aux boîtes et aux enveloppes ne doit pas être déformé lors de l'application du couple indiqué dans la colonne appropriée du Tableau 4.

La conformité est vérifiée par examen et par l'essai suivant.

Les vis sont serrées et desserrées 5 fois.

L'essai est réalisé au moyen d'un tournevis adapté ou d'un outil approprié en appliquant un couple comme indiqué au Tableau 4.

Si une vis a une tête hexagonale avec une fente, on ne réalise que l'essai avec le tournevis, avec le couple applicable donné dans la colonne II du Tableau 4.

Des valeurs de couple supérieures peuvent être utilisées si le fabricant l'indique, lorsque les informations correspondantes sont fournies.

La colonne I s'applique aux vis qui ne peuvent pas être serrées avec un tournevis avec une lame d'une largeur supérieure au diamètre nominal du filetage de la vis.

La colonne II s'applique aux autres vis qui sont serrées au moyen d'un tournevis.

La colonne III s'applique aux vis et aux écrous qui sont serrés avec un moyen autre qu'un tournevis.

La colonne IV s'applique aux vis qui sont serrées au moyen d'un tournevis à lame carrée.

Pendant l'essai, il ne doit se produire aucun dommage, tel que rupture de vis ou détérioration des fentes de tête (rendant impossible l'utilisation du tournevis approprié) ou des filetages ou de l'enveloppe de nature à affecter l'utilisation ultérieure des moyens de fixation. Les vis doivent être serrées graduellement avec un mouvement régulier et continu.

12 Construction

12.1 Généralités

Les boîtes et enveloppes doivent être construites sans aucune arête vive. Les bavures doivent être enlevées des lignes de moulage des surfaces intérieures de sorte qu'il n'existe aucune arête vive ni aucun obstacle indu au passage du câblage ou au couplage des parties pour l'usage prévu du produit.

Les surfaces intérieures et extérieures d'une boîte ou d'un capot ne doivent pas présenter de traces de décollement, d'écaillage, de pelage et doivent être lisses et libres de toutes cloques, craquelures et autres défauts.

La conformité est vérifiée par examen.

12.2 Couvercles, capots ou plaques de recouvrement ou parties de ceux-ci

12.2.1 Généralités

Les couvercles, capots ou plaques de recouvrement ou parties de ceux-ci, telles que les membranes de protection, qui sont destinés à assurer la protection contre les chocs électriques, doivent être maintenus en place efficacement.

Il est recommandé que les moyens de fixation des capots ou plaques de recouvrement soient imperdables. L'utilisation de rondelles de serrage en carton ou matière analogue est considérée comme un moyen approprié pour maintenir en place les vis destinées à ne pas être enlevées.

12.2.2 Fixations à vis

Une boîte ou une enveloppe prévue pour accepter un couvercle, un capot ou une plaque de recouvrement avec fixation par vis doit être équipée des dispositifs pour recevoir les vis prévues.

Pour les couvercles, capots ou plaques de recouvrement dont la fixation est de type à vis, la conformité est vérifiée par examen.

12.2.3 Fixations ne dépendant pas de vis et ne nécessitant pas un outil ou une clé pour leur manœuvre

12.2.3.1 Généralités

Une boîte ou une enveloppe destinée à recevoir un couvercle, un capot ou une plaque de recouvrement dont la fixation ne dépend pas de vis ne nécessitant pas d'outil ou de clé pour sa manœuvre doit être équipée de moyens pour fixer le couvercle, le capot ou la plaque de recouvrement.

Pour les couvercles, capots ou plaques de recouvrement dont l'enlèvement est obtenu en appliquant une force conforme aux exigences du Tableau 2 dans une direction approximativement perpendiculaire à la surface de montage/support avec le calibre B de l'IEC 61032 lorsque leur enlèvement peut permettre l'accès:

- aux parties actives;
- aux parties conductrices non raccordées à la terre séparées des parties actives par une isolation principale;
- seulement aux:
 - parties isolantes, ou
 - parties conductrices raccordées à la terre, ou
 - parties conductrices séparées des parties actives par une isolation double ou renforcée, ou
 - parties actives des circuits TBTS selon l'IEC 61140, de tension ne dépassant pas 25 V en courant alternatif ou 60 V en courant continu.

La conformité est vérifiée par les essais de 12.2.3.2. et de 12.2.3.3.

Tableau 2 – Forces à appliquer aux couvercles, capots, plaques de recouvrement ou aux organes de manœuvre dont la fixation ne dépend pas de vis

Accessibilité du calibre d'essai B de l'IEC 61032 après retrait des couvercles, capots ou plaques de recouvrement ou parties de ceux-ci	Force à appliquer N			
	Enveloppes conformes à 12.2.3.4 et 12.2.3.5		Enveloppes non conformes à 12.2.3.4 et 12.2.3.5	
	Ne doit pas se détacher	Doit se détacher*	Ne doit pas se détacher	Doit se détacher*
Aux parties actives	40	120	80	120
Aux parties conductrices non raccordées à la terre séparées des parties actives par une isolation principale	10	120	20	120
Aux parties isolantes, parties conductrices raccordées à la terre, parties conductrices séparées des parties actives par une isolation double ou renforcée ou aux parties actives des circuits TBTS conformes à l'IEC 61140 ayant une tension inférieure ou égale à 25 V en courant alternatif ou 60 V en courant continu	10	120	10	120
* Cette colonne n'est pas applicable pour 12.2.4				

Les boîtes et enveloppes sont montées comme en usage normal.

Les boîtes et enveloppes pour montage encastré sont fixées et installées comme en usage normal. Si elles sont pourvues d'un dispositif de verrouillage qui peut être manœuvré sans outil, ces dispositifs ne sont pas verrouillés.

12.2.3.2 Vérification du non-enlèvement des couvercles, capots ou plaques de recouvrement

Les forces sont appliquées graduellement avec un mouvement régulier et continu dans une direction perpendiculaire à la surface de montage, de façon telle que la force résultante agissant au centre des couvercles, des capots ou des plaques de recouvrement ou de leurs parties soit comme spécifiée dans la colonne appropriée du Tableau 2.


Les forces sont appliquées pendant 1 min.

Les couvercles, capots ou plaques de recouvrement ne doivent pas se détacher.

Pour les boîtes ou enveloppes pour montage encastré, l'essai est ensuite répété sur de nouveaux échantillons, le couvercle, le capot ou la plaque de recouvrement est monté sur la boîte après qu'une feuille de matériau dur, d'épaisseur $(1 \pm 0,1)$ mm, a été placée sur le mur autour du cadre support, comme représenté à la Figure 5.

La feuille de matériau dur est utilisée pour simuler du papier à tapisser et peut être constituée de plusieurs pièces.

Dimensions en millimètres

**Légende**

- | | | | |
|---|-------------------------|---|------------------|
| 1 | feuille de matériau dur | 4 | mur |
| 2 | plaque de recouvrement | 5 | boîte de montage |
| 3 | cadre support | | |

Figure 5 – Disposition pour l'essai des capots ou plaques de recouvrement (voir 12.2.3.2 and 12.2.3.3)

12.2.3.3 Vérification de l'enlèvement des couvercles, capots ou plaques de recouvrement

Une force ne dépassant pas celle spécifiée dans la colonne appropriée du Tableau 2 est appliquée graduellement avec un mouvement régulier et continu aux couvercles, capots, plaques de recouvrement ou parties de ceux-ci dans une direction perpendiculaire à la surface de montage/de support au moyen d'un crochet placé successivement dans chaque rainure, trou, espace ou endroit analogue prévu pour les enlever.

Les couvercles, capots ou plaques de recouvrement doivent se détacher.

L'essai est effectué 10 fois sur chaque partie détachable dont la fixation ne dépend pas de vis (en répartissant si possible équitablement les points d'application). La force d'enlèvement est appliquée à chaque fois au niveau des différentes rainures, différents trous ou endroits analogues prévus pour enlever les parties détachables.

Pour les boîtes ou enveloppes pour montage encastré, l'essai est ensuite répété sur de nouveaux échantillons.

Les couvercles, capots ou plaques de recouvrement sont montés sur la boîte après qu'une feuille de matériau dur, d'épaisseur $(1 \pm 0,1)$ mm, a été placée sur le mur autour du cadre support, comme représenté à la Figure 5.

Après l'essai, les échantillons ne doivent présenter aucun dommage entraînant la non-conformité à la présente norme.

12.2.3.4 Vérification du contour des couvercles, capots ou plaques de recouvrement

Le calibre de la Figure 6 est poussé vers chaque côté de chaque couvercle, capot ou plaque de recouvrement fixé sans vis sur une surface de montage ou de support comme représenté à la Figure 7. La face B s'appuyant sur la surface de montage/de support, la face A lui étant perpendiculaire, le calibre est appliqué perpendiculairement à chaque côté en essai.

Si un couvercle, un capot ou une plaque de recouvrement est fixé sans vis sur un autre couvercle, à un autre capot ou une autre plaque de recouvrement ou bien à une boîte de montage ayant le même contour, la face B du calibre doit être placée au même niveau que la jonction. Le contour du couvercle, du capot ou de la plaque de recouvrement ne doit pas dépasser le contour de la surface de support.

Les distances entre la face C du calibre et le contour du côté en essai, mesurées parallèlement à la face B, ne doivent pas décroître (à l'exception des rainures, trous, dépouilles inverses ou éléments analogues placés à une distance inférieure à 7 mm à partir d'un plan comprenant la face B et satisfaisant à l'essai de 12.2.3.5) lorsque les mesures sont répétées en partant du point X dans la direction de la flèche Y (voir Figure 8).





Figure 6 – Calibre pour la vérification des contours des couvercles, capots ou plaques de recouvrement




IEC

Légende

- 1 surface de montage
- 2 capot
- 3 surface support
- 4 pièce d'écartement ayant la même épaisseur que la surface support

Figure 7 – Exemples d'applications du calibre de la Figure 6 sur des capots fixés sans vis sur une surface de montage ou de support

Dimensions en millimètres



Les cas a) et b) ne sont pas conformes.

Les cas c), d), e) et f) sont conformes (la conformité doit cependant aussi être vérifiée selon les exigences de 12.2.3.5 en utilisant le calibre de la Figure 9).


Figure 8 – Critères de conformité d'application du calibre de la Figure 6

12.2.3.5 Vérification des rainures, trous et dépouilles inverses

Un calibre selon la Figure 9, appliqué avec une force de $(1 \pm 0,2)$ N, ne doit pas pénétrer de plus de 1,0 mm depuis la partie supérieure de toute rainure, trou ou dépouille inverse, ou élément analogue lorsque le calibre est appliqué parallèlement à la surface de montage/de support et perpendiculairement à la partie en essai, comme l'illustre la Figure 10.

NOTE La vérification de la pénétration de plus de 1,0 mm du calibre selon la Figure 10 est effectuée en référence à une surface perpendiculaire à la face B et comprenant la partie supérieure du contour des rainures, trous, dépouilles inverses ou éléments analogues.


Dimensions en millimètres



Légende

- 1 tige d'essai (métallique)
- 2 bords à angles droits vifs

Figure 9 – Calibre pour la vérification des rainures, trous et dépouilles inverses



Légende

- 1 capot
- 2 support de montage

Figure 10 – Schéma montrant la direction d'application du calibre de la Figure 9

12.2.4 Fixations ne dépendant pas de vis et nécessitant un outil ou une clé pour leur manœuvre

Pour les couvercles, capots ou plaques de recouvrement dont la fixation ne dépend pas de vis et dont l'enlèvement est obtenu en utilisant un outil et/ou une clé selon les instructions du fabricant, la conformité est vérifiée par les mêmes essais que ceux indiqués en 12.2.3, excepté que les couvercles, capots ou plaques de recouvrement ou parties de ceux-ci ne doivent pas se détacher lorsque l'on applique une force n'excédant pas 120 N dans des directions perpendiculaires à la surface de montage/de support.

12.3 Trous de drainage

Les enveloppes pour montage en saillie et semi-encasté de degré de protection IPX1 à IPX6 doivent être conçues pour permettre l'ouverture d'un trou de drainage d'au moins 5 mm de diamètre ou de 20 mm² de surface, et d'une longueur ou largeur minimale de 3 mm.

Les trous de drainage doivent être situés de façon telle et doivent être disponibles en nombre tel qu'un trou soit toujours efficace dans n'importe laquelle des positions de montage prévues de l'enveloppe.

NOTE Un trou de drainage au dos de l'enveloppe est jugé efficace si la conception de l'enveloppe assure une séparation avec le mur, pour procurer un espace de drainage pour l'eau ayant au moins la taille spécifiée pour le trou de drainage.

La conformité est vérifiée par examen et par mesure.

12.4 Montage de l'enveloppe

Les enveloppes doivent être prévues pour une fixation convenable en fonction du type de montage (voir 7.2).

Les enveloppes en matériau isolant doivent être construites de façon telle que toutes les parties conductrices des moyens de fixation à l'intérieur de la boîte ou de l'enveloppe prévus pour être utilisés pour le montage de l'enveloppe soient entourées par une isolation dépassant la partie supérieure du moyen de fixation d'au moins 10 % de la largeur maximale de la cavité dans laquelle se trouve le moyen de fixation.

La conformité est vérifiée par examen et par mesure.

12.5 Boîtes et enveloppes avec orifices d'entrée pour câbles souples

Les entrées (sorties) équipant les boîtes et enveloppes classées selon 7.3.2 doivent être conçues et construites de façon telle que les câbles souples puissent être introduits facilement, et ne provoquent pas de dommages au câble souple lorsqu'ils pénètrent dans la boîte ou dans l'enveloppe qui pourrait compromettre son usage ultérieur.

La conformité est vérifiée par un essai manuel.

12.6 Boîtes et enveloppes avec orifices d'entrée pour des applications autres que les câbles souples

Les éventuels orifices d'entrée classés selon 7.3 autres que ceux classés selon 7.3.2 doivent permettre l'introduction

- d'un conduit ou d'un accessoire approprié les raccordant à la boîte ou à l'enveloppe et/ou,
- de la gaine de protection du câble

de façon à assurer une protection mécanique des conducteurs quand ils pénètrent la boîte ou l'enveloppe.

Les orifices d'entrée pour conduits ou au moins pour deux de ceux-ci, s'il y en a plusieurs, doivent pouvoir recevoir des conduits d'une dimension ou d'une combinaison quelconque de dimensions conformes aux exigences de l'IEC 60423 et/ou de l'IEC 60981.

La conformité est vérifiée par examen avec les câbles ou conduits appropriés installés.

Des orifices d'entrées de dimensions adéquates peuvent aussi être obtenus en utilisant des parois défonçables ou des pièces d'insertion appropriées ou au moyen d'un outil de découpe adapté.

NOTE Dans le pays suivant, il est exigé que les ouvertures des boîtes prévues pour recevoir des interrupteurs ou des socles de prises aient des orifices à manchon avec retenues de câbles: NL.

12.7 Boîtes et enveloppes pourvues de serre-câble

Les moyens de fixation pour les boîtes et enveloppes classées selon 7.4.2 doivent être tels que la connexion des conducteurs du câble souple ne soit pas soumise à des contraintes lorsque ce câble souple est accessible et risque d'être soumis à des contraintes après l'installation.

Les moyens de suppression des tensions et de prévention des torsions doivent être clairement établis.

Les serre-câbles doivent

- être adaptés aux différents types de câbles souples pour lesquels la boîte est destinée à être utilisée;
- être construits de façon qu'au moins une partie du serre-câble soit partiellement intégrée ou fixée de manière permanente à l'une des parties composantes de la boîte;
- être constitués d'un matériau isolant ou pourvus d'un revêtement isolant fixé aux parties métalliques.

La conformité est vérifiée par examen et par l'essai suivant.

L'efficacité du serre-câble est contrôlée au moyen d'un dispositif conforme à la Figure 11.

Le serre-câble est utilisé comme en usage normal, les vis de serrage éventuelles étant serrées avec un couple égal aux deux tiers du couple approprié indiqué dans le Tableau 4 ou, pour les presse-étoupe, égal au couple approprié spécifié dans le Tableau 5.


Après ré-assemblage de l'échantillon, il ne doit pas être possible, avec la force spécifiée au Tableau 3, d'enfoncer le câble dans l'échantillon sur plus de 1 mm.

Le câble est ensuite soumis à 50 reprises, pendant 1 s, à la force de traction qui est spécifiée au Tableau 3, et immédiatement après, le câble souple est soumis à un couple non inférieur aux valeurs spécifiées au Tableau 3, appliqué aussi près que possible de l'entrée de câble, pendant une durée de (15 ± 1) s.

Tableau 3 – Forces et couples à appliquer aux serre-câbles

Dimensions extérieures du câble souple mm	Force N	Couple Nm
Jusqu'à 5,2 × 7,6 inclus	40 ± 2	0,05
Jusqu'à 8 inclus	50 ± 2	0,1
Supérieures à 8 et jusqu'à 11 inclus	60 ± 2	0,15
Supérieures à 11 et jusqu'à 16 inclus	80 ± 2	0,35
Supérieures à 16	100 ± 2	0,42

Après les essais, le câble souple ne doit pas s'être déplacé de plus de 2 mm et le serre-câble (suppression des tensions) ne doit présenter aucun dommage entraînant la non-conformité à la présente norme.



Légende

- 1 boîte
- 2 manivelle
- 3 excentrique

Figure 11 – Appareil pour l'essai des serre-câbles

12.8 Boîtes et enveloppes pourvues de dispositifs de retenue de câble

Les dispositifs de retenue de câble dans les boîtes et enveloppes classées selon 7.4.1 doivent maintenir le câble en place.

NOTE Dans le pays suivant, un dispositif de retenue est exigé pour les boîtes et les enveloppes pour les murs creux en raison des pratiques d'installation: DE.

La conformité est vérifiée par l'essai suivant qui est effectué sur trois échantillons de dispositifs de retenue de câble.

Pour les boîtes et enveloppes classées selon 7.5.2 ou 7.5.3, l'essai doit être réalisé à $(-15 \pm 2) ^\circ\text{C}$ et $(-25 \pm 2) ^\circ\text{C}$ respectivement.

Pour commencer, un câble de diamètre nominal maximal puis un câble de diamètre nominal minimal en conformité avec les spécifications du fabricant doivent être utilisés.

Le câble est disposé dans le dispositif de retenue de câble selon les instructions du fabricant.

Le câble est chargé avec une force axiale de $(20 \pm 1) \text{ N}$.

La charge est maintenue pendant 1 min et, à la fin de cette période, le déplacement du câble ne doit pas dépasser 3 mm, après le retrait de la charge.

12.9 Parties défonçables prévues pour être ouvertes par des impacts mécaniques

12.9.1 Généralités

Les parois défonçables destinées à être ouvertes par des impacts mécaniques doivent pouvoir être ouvertes sans endommager la boîte.

Les parois défonçables destinées à être utilisées avec des câbles doivent être exemptes d'éclats ou bavures.

Dans les parois défonçables destinées à être utilisées avec des conduits et/ou un passe-fil ou une membrane, les éclats ou bavures ne sont pas pris en compte.

Pour obturer une paroi défonçable ouverte dans une boîte ou une enveloppe classée selon 7.1.2, on peut utiliser un bouchon.

Ce bouchon utilisé sans écrou de blocage

- ne doit pas être délogé ou endommagé et
- son efficacité ne doit pas être compromise et
- il doit satisfaire à toutes les exigences pour les parois défonçables.

Cette exigence ne s'applique pas à un bouchon qui est monté par vissage dans une entrée filetée.

La conformité est vérifiée par examen et par les essais tels que spécifiés en 12.9.2 et 12.9.3.

12.9.2 Tenue des parois défonçables

Pour les boîtes et les enveloppes qui possèdent des parois défonçables qui

- *ne fournissent pas d'accès aux parties actives et sont accessibles après l'installation, une force de $(30 \pm 1) \text{ N}$ doit être appliquée à la paroi défonçable pendant $(15 \pm 1) \text{ s}$,*
- *fournissent un accès direct aux parties actives après l'installation, une force de $(40 \pm 1) \text{ N}$ doit être appliquée à la paroi défonçable pendant $(60 \pm 1) \text{ s}$,*

au moyen d'un mandrin de 6 mm de diamètre avec une extrémité plate.

La force doit être appliquée sans choc dans une direction perpendiculaire au plan de la paroi défonçable et au point le plus susceptible de causer un mouvement.

Lorsque la boîte est équipée d'une paroi défonçable étagée, la force doit être appliquée à la paroi la plus petite.

La paroi défonçable doit rester en place et le degré de protection de la boîte ou de l'enveloppe mesuré 1 h après le retrait de la force doit être inchangé.

12.9.3 Enlèvement de la paroi défonçable

Les parois défonçables doivent être enlevées au moyen d'un outil, comme indiqué par le fabricant. Le côté d'un tournevis peut être passé une fois le long du bord de l'ouverture de la paroi défonçable pour enlever tout ergot facilement détachable restant le long du bord.

Pour les boîtes ou enveloppes classées selon 7.1.1 ou 7.1.3, l'essai est répété avec une boîte ou enveloppe n'ayant pas été soumise à essai auparavant et ayant été conditionnée pendant $5\text{ h} \pm 10\text{ min}$, l'air étant maintenu à la température minimale rencontrée pendant l'installation, comme spécifié en 7.5. Immédiatement après ce conditionnement, la paroi défonçable doit être enlevée comme indiqué ci-dessus.

Pour une boîte et une enveloppe pourvue de parois défonçables étagées, on ne doit observer aucun déplacement d'un étage plus large lorsqu'un étage plus petit est enlevé.

Après l'essai, sauf au niveau des parois défonçables pour conduits et/ou pour utilisation avec un passe-fil ou une membrane, aucune arête vive ne doit subsister et la boîte et l'enveloppe ne doivent pas être endommagées.

12.9.4 Surfaces plates entourant les parois défonçables

Les parois défonçables destinées à être utilisées avec des passe-fil, des presse-étoupe ou accessoires doivent être situées sur des surfaces plates pour permettre aux passe-fil, aux presse-étoupe ou aux accessoires d'être positionnés en contact complet avec ces surfaces lorsqu'ils sont installés comme prévu.

Les protubérances ou les entailles doivent être interdites sur la surface plate, toutefois, des trous doivent être autorisés. Les zones de la surface plate de parois défonçables adjacentes qui se chevauchent partiellement ou totalement satisfont à l'objectif de cette exigence.

La conformité est vérifiée par examen et par des mesures conformément à la norme nationale appropriée, s'il en existe une.

12.10 Fixations à vis

Les moyens de fixation pour couvercles, capots, plaques de recouvrement, appareillages, bornes, dispositifs de connexion, arrêts de traction, etc., utilisant des vis doivent être conçus et construits de façon à supporter les contraintes mécaniques survenant pendant l'installation et en usage normal.

Les vis ou d'autres moyens de fixation en matériau isolant similaires aux vis sans filetage normalisé qui doivent être serrés à l'aide d'un outil quel qu'il soit pour la fixation des capots, doivent être soumises aux essais conformément aux instructions du fabricant.

NOTE Dans le pays suivant, il est exigé que les boîtes pour montage encastré possèdent des pièces d'insertion métalliques et soient équipées de vis métalliques à filetage métrique ISO: NL.

Les vis autotaraudeuses par déformation et les vis autotaraudeuses à découpe destinées uniquement aux assemblages mécaniques peuvent être utilisées à condition que les vis soient fournies avec la pièce avec laquelle elles sont destinées à être assemblées.

Pour les vis autotaraudeuses par déformation et les vis autotaraudeuses à découpe, l'opération d'assemblage par vis doit être effectuée avant la réalisation des essais.

La conformité est vérifiée par examen et par l'essai suivant.

Les vis des moyens de fixation sont serrées et desserrées:

- 10 fois pour les vis métalliques s'engageant dans un filetage en matériau isolant;*
- 5 fois dans tous les autres cas.*

Les vis et écrous s'engageant dans un filetage en matériau isolant et les vis en matériau isolant sont complètement enlevés et réinsérés à chaque fois. L'essai est effectué en utilisant un tournevis ou un outil approprié et en appliquant un couple conforme aux indications données dans le Tableau 4.

S'il s'agit d'une vis à tête hexagonale avec fente, seul l'essai avec le tournevis est réalisé, avec le couple approprié indiqué dans la colonne II du Tableau 4.

Si l'information correspondante est fournie, des valeurs de couples plus élevées peuvent être utilisées si cela est indiqué par le fabricant.

La colonne I s'applique

- aux vis qui ne peuvent pas être serrées au moyen d'un tournevis ayant une lame plus large que le diamètre nominal du filetage de la vis,*
- aux vis non métalliques,*
- aux vis métalliques se vissant dans un filetage en matériau isolant. Dans ce dernier cas, la largeur de l'empreinte de l'outil de serrage de la vis est choisie, à la place du diamètre du filetage, quand cette largeur d'empreinte est inférieure au diamètre nominal du filetage avec un minimum de 3 mm.*

La colonne II s'applique aux autres vis qui sont serrées au moyen d'un tournevis.

La colonne III s'applique aux vis et écrous qui sont serrés par un autre moyen qu'un tournevis.

La colonne IV s'applique aux vis qui sont serrées au moyen d'un tournevis à lame carrée.

Pendant l'essai, on ne doit constater aucun dommage tel qu'un bris de vis ou une détérioration de la fente de la tête (rendant impossible l'usage d'un tournevis approprié), des filetages ou de l'enveloppe, compromettant l'utilisation ultérieure des moyens de fixation. Les vis doivent être serrées graduellement avec un mouvement régulier et continu.

Tableau 4 – Couples de serrage pour la vérification de la résistance mécanique des vis

Diamètre nominal de filetage mm	Couple pour vis métalliques et non métalliques Nm			
	I	II	III	IV
Jusqu'à 2,8 inclus	0,20	0,40	0,40	0,70
Supérieur à 2,8 et jusqu'à 3,0 inclus	0,25	0,50	0,50	0,90
Supérieur à 3,0 et jusqu'à 3,2 inclus	0,30	0,60	0,60	1,10
Supérieur à 3,2 et jusqu'à 3,6 inclus	0,40	0,80	0,80	1,40
Supérieur à 3,6 et jusqu'à 4,1 inclus	0,70	1,20	1,20	1,80
Supérieur à 4,1 et jusqu'à 4,7 inclus	0,80	1,80	1,80	2,30
Supérieur à 4,7 et jusqu'à 5,3 inclus	0,80	2,00	2,00	4,00
Supérieur à 5,3 et jusqu'à 6,0 inclus	1,20	2,50	3,00	4,40
Supérieur à 6,0 et jusqu'à 8,0 inclus	2,50	3,50	6,00	4,70
Supérieur à 8,0	3,00 ^a	4,00	10,00	5,00

^a Ou à spécifier par le fabricant.

12.11 Fixation des boîtes et enveloppes classées selon 7.2.1

Les boîtes et enveloppes pour montage encastré autres que celles pour les murs creux, et comme indiqué autrement ci-dessous, doivent être équipées de dispositifs de fixation pour leur fixation convenable dans le mur, le plafond ou le plancher. Les vis prévues pour la fixation de la boîte ou de l'enveloppe à la structure du bâtiment ne sont pas nécessairement fournies avec la boîte ou l'enveloppe mais peuvent être fournies par l'installateur selon les instructions du fabricant.

Les dispositifs de fixation fournis séparément pour une boîte ou une enveloppe doivent satisfaire aux exigences des dispositifs de fixation de la boîte ou de l'enveloppe avec laquelle ils sont destinés à être utilisés et doivent comprendre un moyen de fixation à la boîte ou à l'enveloppe.

Les vis, les supports mécaniques supplémentaires ou les caractéristiques de conception qui empêchent le déplacement de la boîte ou de l'enveloppe sont considérés être des dispositifs de fixation appropriés.

NOTE Les arêtes, nervures, arêtes partielles encastrées et similaires sont des exemples de caractéristiques de conception, destinées à empêcher le déplacement de la boîte ou de l'enveloppe.

La conformité est vérifiée par examen.

Les boîtes et enveloppes ne satisfaisant pas à au moins l'une des exigences ci-dessus et disposant d'un volume interne inférieur à 400 cm³, doivent être soumises aux essais comme suit.

Le volume interne de la boîte ou de l'enveloppe doit être vérifié par examen ou par l'essai de 12.16.

Pour les boîtes et les parties d'enveloppes devant être noyées dans la maçonnerie, l'échantillon est monté dans un bloc de montage comme représenté à la Figure 12 et il est fixé conformément aux instructions du fabricant.

L'espace entre le profil extérieur principal de l'échantillon et le profil intérieur du renforcement dans le bloc de montage doit être d'au moins 20 mm et pour les parties dépassant du profil principal jamais moins de 10 mm. Le bloc de montage est rempli avec le matériau spécifié dans

les instructions du fabricant ou avec du plâtre si les instructions du fabricant ne spécifient pas le matériau.

L'assemblage est conservé à température ambiante pendant $(10 \pm 1/0)$ jours.

Le dispositif auxiliaire décrit à la Figure 13 est monté sur l'échantillon et les vis sont serrées avec un couple égal aux deux tiers du couple applicable indiqué dans le Tableau 4.


L'assemblage est ensuite fixé à la plaque de montage (A) d'un dispositif d'essai tel que représenté à la Figure 14, de sorte que les axes des vis soient perpendiculaires au plan de montage.

Le poids total du dispositif y compris le poids principal (PP) doit être de $(72 \pm 0,1)$ N, et le poids supplémentaire (PS) doit être de $(8 \pm 0,1)$ N.

Le poids supplémentaire (PS) et le poids principal (PP) sont introduits sur l'axe du dispositif et fixés par le support (C) (voir Figure 14).

Le poids supplémentaire doit tomber 10 fois d'une hauteur de 50 mm sur le poids principal.

Après l'essai, l'échantillon ne doit pas avoir été déplacé de plus de 0,5 mm du bloc de montage.




Légende

- 1 échantillon
- 2 plâtre
- 3 bloc de bois

* L'intervalle entre le profil externe principal de la boîte et le profil interne du logement dans le bloc de montage doit être égal à au moins 20 mm et pour les parties qui dépassent du profil principal jamais moins de 10 mm.

Figure 12 – Exemple de bloc de montage pour des boîtes destinées à être encastrées dans de la maçonnerie (pour montage encastré ou semi-encastré)




Légende

- 1 dispositif auxiliaire
- 2 échantillon

Figure 13 – Exemple de fixation du dispositif auxiliaire monté sur un échantillon

IECNORM.COM : Click to view the full PDF of IEC 60670-1:2015

**Légende**

- 1 poids supplémentaire (PS)
- 2 poids principal (PP)
- 3 support (C)
- 4 plaque de montage (A)

Figure 14 – Exemple d'appareil d'essai

12.12 Fixation des boîtes et enveloppes encastrées et semi-encastrées classées selon 7.2.2.1

Les boîtes et enveloppes pour murs creux ou similaires classées selon 7.2.2.1 doivent être pourvues des moyens appropriés de fixation de la boîte ou de l'enveloppe aux murs creux, aux plafonds creux, aux planchers creux ou à des meubles.

Les moyens de fixation ne doivent pas dépendre du système de gestion du câblage.

La conformité est vérifiée par l'essai suivant.

Un échantillon de boîte ou d'enveloppe est monté dans une paroi d'essai en suivant les instructions du fabricant. Si les instructions du fabricant ne spécifient pas un type particulier de paroi, on doit utiliser une plaque de contre-plaqué de (10 ± 1) mm d'épaisseur, de 500 mm de large et de 500 mm de haut.

a) Vérification de la résistance à l'arrachement et à la torsion

Un levier doit être fixé à l'échantillon par le moyen de fixation pour appareillages ou capots, comme représenté à la Figure 15.


Ce levier est chargé avec une force F_1 comme représenté à la Figure 15 a) pendant 1 min, de façon à obtenir un couple ($F_1 \times a$) de 3 Nm sur la boîte; simultanément, le levier est chargé avec une force F_2 , comme représenté à la Figure 15 b), de 100 N appliquée à l'axe principal de la boîte perpendiculairement à la surface de montage.

Après ces essais, les échantillons ne doivent présenter aucun dommage affectant leur usage ultérieur, et le déplacement du levier ne doit pas dépasser 2° .

b) Vérification du non-déplacement

L'extrémité du levier est soumise pendant 1 min à une force F_3 appliquée au point où F_1 a été appliquée de façon à obtenir un couple ($F_3 \times b$) de 3 Nm appliqué à la boîte, comme représenté à la Figure 15 c).

Après l'essai, le bord de la boîte ne doit pas s'être déplacé de plus de 1 mm par rapport à la surface de montage.



Légende

- 1 échantillon d'essai
- 2 feuille de contreplaqué
- 3 levier
- 4 axe principal de la boîte

Figure 15 – Vérification des moyens de fixation des boîtes et enveloppes classées selon 7.2.2.1

12.13 Boîtes et enveloppes classées selon 7.2.2.2 et 7.2.2.3

12.13.1 Généralités

Les boîtes et enveloppes pour murs creux ou similaires classées selon 7.2.2.2 et 7.2.2.3 doivent être pourvues des moyens appropriés de fixation de la boîte ou de l'enveloppe aux murs creux et aux plafonds creux.

Les moyens de fixation ne doivent pas dépendre du système de gestion du câblage.

La conformité est vérifiée par les essais en 12.13.2, 12.13.3, 12.13.4 ou 12.13.6 selon ce qui est applicable.

12.13.2 Boîtes prévues pour montage sur une structure en bois intégrée dans un mur

La boîte doit être montée comme en usage normal sur une structure en bois d'une section de (38 mm × 90 mm) et de n'importe quelle longueur convenable, de façon telle que le plan de la face avant de la boîte soit en position verticale.

L'assemblage doit résister à une force de 225 N appliquée graduellement au centre de la base de la boîte pendant 5 min.

Après avoir ôté la force, il ne doit y avoir ni arrachement de clous ou de vis utilisés pour le montage ni déplacement de la face de la boîte dans un plan horizontal de plus de 3 mm.

12.13.3 Boîtes prévues pour montage sur une structure en bois intégrée dans un plafond

La boîte doit être montée comme en usage normal sur une structure en bois d'une section de (38 mm × 190 mm) et de n'importe quelle longueur convenable, de façon telle que le plan de la face avant de la boîte soit en position horizontale.

L'assemblage doit résister à une force de 225 N appliquée graduellement au centre de la face avant de la boîte pendant 1 min.

La force étant toujours appliquée, la déflexion de la face de la boîte ne doit pas dépasser 6 mm, la mesure étant effectuée depuis un plan parallèle à la face horizontale de la structure de bois.

12.13.4 Boîtes prévues pour montage sur une structure métallique intégrée dans un mur

La boîte doit être montée comme en usage normal sur une structure métallique intégrée dans le mur, conformément à la Figure 16.


L'assemblage doit résister à une force de 180 N appliquée graduellement au centre de la face avant de la boîte pendant 5 min, d'abord dans une direction tendant à pousser la boîte dans l'ouverture du mur puis dans la direction opposée tendant à extraire la boîte hors de l'ouverture.

La force étant toujours appliquée, la déflexion de la boîte ne doit pas dépasser 2 mm dans chacune des directions.

NOTE Un support additionnel de la boîte peut être nécessaire pour minimiser la déflexion.

L'application de la force et la mesure du déplacement sont représentées à la Figure 16.

Dimensions en millimètres



Légende

- 1 boîte
- 2 étrier en acier
- 3 support additionnel
- 4 déflexion maximale
- 5 contreplaqué
- 6 bras
- 7 trois vis par côté par panneau

Figure 16 – Essai de la force et mesure du déplacement

12.13.5 Volume intérieur des boîtes et enveloppes classées selon 7.2.2.2 et 7.2.2.3

Pour les boîtes, les enveloppes, les couvercles de rehausse et les extensions de boîtes classés selon 7.2.2.2 et 7.2.2.3, le volume intérieur déclaré d'une boîte, d'une enveloppe, d'un couvercle de rehausse ou d'une extension de boîte doit être contrôlé.

Dans le cas d'une boîte ou d'une enveloppe avec une cloison, le volume de chaque section ainsi délimitée doit être vérifié.

La conformité est vérifiée par l'essai de 12.16.

12.13.6 Boîtes prévues pour montage dans une structure finie

Les moyens de fixation d'une boîte prévue pour installation dans une structure finie ne doivent pas se fissurer ou se briser et la face de la boîte ne doit pas s'être déplacée de façon permanente de plus de 3,2 mm du plan de la face de la surface d'essai lorsque la mesure est réalisée 1 min après le retrait de la charge d'essai.

NOTE Dans une structure finie, les éléments d'encadrement structurels ne sont pas habituellement accessibles pour le montage et la fixation des boîtes ou des enveloppes encastrées ou semi-encastrées dans les murs creux.

La conformité est vérifiée par l'essai suivant:

Six boîtes prévues pour un usage dans les murs ou huit boîtes prévues pour un usage dans les plafonds doivent être installées dans une feuille de contreplaqué de 9,5 mm d'épaisseur renforcée avec un support à 152 mm à partir d'un côté de l'ouverture des boîtes, ou dans une surface finie conformément aux instructions du fabricant.

Les vis pour les moyens de fixation d'une boîte doivent être serrées conformément aux instructions du fabricant. En l'absence d'instructions, les vis doivent être serrées conformément à la colonne IV du Tableau 4. Le foirage d'une vis avant son serrage au couple spécifié ne doit pas se produire plus d'une fois.

Après installation, une force de 222 N doit être appliquée pendant 5 min consécutives à chacune des deux boîtes perpendiculairement au plan de la face de la surface d'essai le long de l'axe de la boîte en tendant à pousser la boîte dans l'ouverture. La même force doit être appliquée à chacune des deux boîtes qui n'ont pas été soumises à essai auparavant dans une direction tendant à tirer la boîte à l'extérieur de l'ouverture. À l'issue de l'essai, la vis doit pouvoir être enlevée avec un tournevis.

Deux échantillons supplémentaires de boîtes fixés de manière à ce que le plan de l'avant de la boîte soit vertical, doivent être soumis à une force de 222 N appliquée pendant 5 min suspendus du coin arrière inférieur du bord arrière extérieur de la boîte.

12.14 Entrées de presse-étoupe

Les presse-étoupe ne doivent pas endommager la boîte ou l'enveloppe lorsqu'ils sont utilisés comme prévu.

La conformité est vérifiée par l'essai suivant.

Les presse-étoupe sont équipés d'une tige métallique cylindrique ayant un diamètre égal au diamètre intérieur du joint, en millimètres, arrondi au nombre entier le plus proche, comme spécifié dans la première colonne du Tableau 5. Les presse-étoupe sont ensuite serrés et desserrés 10 fois au moyen d'un outil approprié avec le couple indiqué dans le Tableau 5 avec une tolérance de $(\begin{smallmatrix} +5 \\ 0 \end{smallmatrix})$ %, le couple approprié étant appliqué pendant $1 \text{ min} \pm 5 \text{ s}$.

Tableau 5 – Valeurs du couple d'essai pour les presse-étoupe

Diamètre de la tige d'essai mm	Couple Nm	
	Presse-étoupe métalliques	Presse-étoupe en matériau isolant
Jusqu'à 8 inclus	4,0	2,5
Supérieur à 8 et jusqu'à 14 inclus	6,3	3,8
Supérieur à 14 et jusqu'à 20 inclus	7,5	5,0
Supérieur à 20	10,0	7,5

Après l'essai, les boîtes et enveloppes ne doivent présenter aucun dommage entraînant la non-conformité à la présente norme.

12.15 Boîtes et enveloppes pourvues d'entrées (sorties) ou orifices à manchon pour conduits

12.15.1 Les boîtes et enveloppes classées selon 7.3.4 ainsi que les orifices coniques selon 7.3.6 doivent résister aux essais de 12.15.2, 12.15.3 et 12.15.4.

Les orifices à manchons filetés ne sont pas soumis aux essais de 12.15.2 et 12.15.3.

Les boîtes et enveloppes classées selon 7.4.3 doivent satisfaire aux essais des paragraphes 12.15.2 et 12.15.3.

Les essais sont réalisés avec des conduits dont les dimensions nominales minimales sont conformes à l'IEC 60423 ou à l'IEC 60981 après installation comme en usage normal ou après assemblage selon les instructions du fabricant.

12.15.2 Les enveloppes pourvues d'un orifice d'entrée pour conduits éventuels doivent être soumises à l'essai de façon à ce qu'une partie de conduit d'une dimension minimale soit pressée pendant $1 \text{ min} \pm 5 \text{ s}$ avec une force de $(100 \pm 2) \text{ N}$. L'orifice d'entrée doit empêcher l'entrée ultérieure du conduit dans la boîte.

12.15.3 Un essai de traction doit être effectué comme suit après l'essai selon 12.15.2. Une partie de conduit ayant la dimension minimale correspondant à l'ouverture d'insertion doit être soumise pendant 1 min à une force de traction de $(20 \pm 2) \text{ N}$. Le conduit ne doit pas se détacher de l'orifice d'entrée de l'enveloppe.

12.15.4 La résistance à la flexion d'un orifice d'entrée doit être vérifiée comme suit. Une partie de conduit doit être insérée dans l'orifice d'entrée avec une force de compression de $(100 \pm 2) \text{ N}$ et en appliquant un couple de flexion de 3 Nm. La contrainte doit monter lentement de zéro à la valeur totale et l'essai doit être réalisé dans six directions différentes passant par la ligne médiane de l'orifice d'entrée avec un intervalle de $(60 \pm 2)^\circ$. L'orifice d'entrée doit être chargé à chaque position angulaire pendant 1 min. L'orifice d'entrée ne doit pas se détacher ni être endommagé et le conduit doit être maintenu dans l'orifice d'entrée.

NOTE Un arrêt d'entrée peut être conçu comme une nervure sur l'intérieur de l'orifice d'entrée.


12.16 Volume intérieur des boîtes et enveloppes

Lorsqu'il y est fait référence dans la présente norme, le volume interne déclaré de la boîte ou de l'enveloppe, chaque section cloisonnée d'une boîte ou d'une enveloppe, les couvercles de rehausse et les extensions de boîte doivent être mesurés de la manière suivante.

- Toutes les vis intérieures, fixations, etc., doivent être enlevées, à l'exception des bornes de mise à la terre et des vis d'assemblage.

- b) *Tous les éléments internes, tels que les capots ou les ergots pour montage encastré, qui dépassent le bord normal de la boîte ou de l'enveloppe doivent être mis de niveau avec le bord.*
- c) *Toutes les parois défonçables doivent être laissées telles qu'elles se présentent après avoir été défoncées et doivent être rendues étanches extérieurement.*
- d) *Toutes les ouvertures doivent être bouchées avec de la pâte à modeler, du mastic, de la cire ou tout autre matériau, et doivent être mises de niveau avec la surface intérieure.*
- e) *La boîte, l'enveloppe ou les couvercles de rehausse doivent être couverts avec une plaque plane constituée de n'importe quel matériau transparent adéquat n'ayant pas plus de 3,2 mm d'épaisseur. Au centre de la plaque, un trou de diamètre nominal de 13 mm doit être effectué (voir Figure 17). Si nécessaire, l'espace entre la boîte, l'enveloppe ou le couvercle de rehausse et la plaque doit être garni avec le matériau utilisé pour fermer les autres ouvertures.*
- f) *En utilisant un cylindre gradué adéquat ou un récipient de mesure rempli avec de l'eau à température ambiante, la boîte, l'enveloppe ou le couvercle de rehausse doit être rempli sans déborder. La différence entre le volume d'eau dans le cylindre de mesure avant et après le remplissage de la boîte, de l'enveloppe ou du couvercle de rehausse donne le volume de la boîte.*

Le volume d'une poche latérale prévue pour augmenter le volume d'une boîte ou d'une enveloppe doit être calculé en utilisant une profondeur de poche inférieure ou égale à la plus faible dimension de l'ouverture dans la poche latérale.



Légende

- 1 boîte
- 2 capot
- 3 ouverture pour le remplissage en eau
- 4 scellement si nécessaire

Figure 17 – Mesure du volume

13 Résistance au vieillissement, protection contre la pénétration de corps solides et contre la pénétration nuisible de l'eau

13.1 Résistance au vieillissement

13.1.1 Les boîtes et enveloppes en matériau isolant et composite, les presse-étoupe, les passe-fil et les membranes remplaçables doivent être résistants au vieillissement.

La conformité est vérifiée comme suit.

Les boîtes et enveloppes en matériau isolant ou composite prévues pour être équipées d'un presse-étoupe ou d'un passe-fil sont montées et équipées comme en usage normal ou selon les instructions du fabricant.

Les boîtes et les enveloppes en matériau isolant ou composite qui ne sont pas prévues pour être équipées d'un presse-étoupe, de passe-fil ou membranes sont assemblées selon les instructions du fabricant.

Les pièces destinées à des usages décoratifs qui peuvent être enlevées sans l'aide d'un outil doivent être retirées avant les essais.

Pour les boîtes et enveloppes équipées de presse-étoupe et de passe-fil, la moitié environ du nombre des presse-étoupe ou des passe-fil de chacune des boîtes et enveloppes est équipée de joints ainsi que de tiges métalliques cylindriques d'un diamètre égal à la valeur inférieure spécifiée pour le diamètre global moyen du plus petit câble, conformément aux valeurs spécifiées par le fabricant. Le reste des presse-étoupe ou passe-fil de ces mêmes boîtes et enveloppes est équipé de joints et de tiges métalliques cylindriques d'un diamètre égal à la valeur supérieure spécifiée pour le diamètre global moyen du plus grand câble déclaré par le fabricant.

Si le nombre de presse-étoupe ou de passe-fil dans une boîte est supérieur à six, l'essai est réalisé avec trois presse-étoupe ou passe-fil équipés pour la plus petite dimension de câble et trois presse-étoupe ou passe-fil équipés pour la plus grande dimension de câble dans chaque boîte.

Dans le cas de passe-fil, la tige doit être maintenue en place de façon telle qu'elle ne puisse pas bouger. Le moyen utilisé pour maintenir la tige en place ne doit pas avoir d'influence sur les résultats des essais.

Les presse-étoupe sont serrés avec un couple égal aux deux tiers de celui appliqué au cours de l'essai de 12.14 (Tableau 5), toutes les autres ouvertures étant fermées. Des valeurs de couples plus élevées peuvent être utilisées si cela est indiqué par le fabricant.

Les échantillons sont ensuite soumis à un essai dans une enceinte chauffante (étuve) avec une atmosphère présentant la composition et la pression de l'air ambiant.

La température dans l'enceinte chauffante est de $(70 \pm 2) ^\circ\text{C}$.

Les échantillons sont conservés dans l'enceinte chauffante pendant $(168 \substack{+4 \\ 0})$ h.

Après traitement, les échantillons sont retirés de l'enceinte et conservés à la température ambiante pendant $(96 \substack{+4 \\ 0})$ h.

Après l'essai, l'échantillon ne doit présenter ni déformation nuisible ni dommage semblable susceptible d'affecter son utilisation ultérieure au sens de la présente norme.

13.1.2 Les passe-fil, les bouchons et les membranes d'entrée présents dans les ouvertures d'entrée ainsi que les membranes de protection doivent être fixés de façon sûre et ne doivent pas être déplacés par les contraintes mécaniques et thermiques survenant en usage normal.

La conformité est vérifiée par l'essai suivant, qui doit être effectué sur tous les passe-fil, tous les bouchons et sur toutes les membranes, remplaçables ou non.

Les passe-fil, les bouchons et les membranes sont soumis aux essais fixés sur les enveloppes.