



UL 1097

STANDARD FOR SAFETY

Double Insulation Systems for Use in
Electrical Equipment

ULNORM.COM : Click to view the full PDF of UL 1097 2021

ULNORM.COM : Click to view the full PDF of UL 1097 2021

UL Standard for Safety for Double Insulation Systems for Use in Electrical Equipment, UL 1097

Sixth Edition, Dated February 1, 2012

Summary of Topics

This revision of ANSI/UL 1097 dated December 16, 2021 is being issued to update the title page to reflect the most recent designation as a Reaffirmed American National Standard (ANS). No technical changes have been made.

Text that has been changed in any manner or impacted by UL's electronic publishing system is marked with a vertical line in the margin.

The requirements are substantially in accordance with Proposal(s) on this subject dated October 29, 2021.

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system, or transmitted in any form by any means, electronic, mechanical photocopying, recording, or otherwise without prior permission of UL.

UL provides this Standard "as is" without warranty of any kind, either expressed or implied, including but not limited to, the implied warranties of merchantability or fitness for any purpose.

In no event will UL be liable for any special, incidental, consequential, indirect or similar damages, including loss of profits, lost savings, loss of data, or any other damages arising out of the use of or the inability to use this Standard, even if UL or an authorized UL representative has been advised of the possibility of such damage. In no event shall UL's liability for any damage ever exceed the price paid for this Standard, regardless of the form of the claim.

Users of the electronic versions of UL's Standards for Safety agree to defend, indemnify, and hold UL harmless from and against any loss, expense, liability, damage, claim, or judgment (including reasonable attorney's fees) resulting from any error or deviation introduced while purchaser is storing an electronic Standard on the purchaser's computer system.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 1097 2021

FEBRUARY 1, 2012
(Title Page Reprinted: December 16, 2021)



ANSI/UL 1097-2012 (R2021)

1

UL 1097

Standard for Double Insulation Systems for Use in Electrical Equipment

First Edition – November, 1978
Second Edition – April, 1983
Third Edition – June, 1993
Fourth Edition – September, 1997
Fifth Edition – July, 2004

Sixth Edition

February 1, 2012

This ANSI/UL Standard for Safety consists of the Sixth Edition including revisions through December 16, 2021.

The most recent designation of ANSI/UL 1097 as a Reaffirmed American National Standard (ANS) occurred on December 16, 2021. ANSI approval for a standard does not include the Cover Page, Transmittal Pages, and Title Page.

Comments or proposals for revisions on any part of the Standard may be submitted to UL at any time. Proposals should be submitted via a Proposal Request in UL's On-Line Collaborative Standards Development System (CSDS) at <https://csds.ul.com>.

UL's Standards for Safety are copyrighted by UL. Neither a printed nor electronic copy of a Standard should be altered in any way. All of UL's Standards and all copyrights, ownerships, and rights regarding those Standards shall remain the sole and exclusive property of UL.

COPYRIGHT © 2021 UNDERWRITERS LABORATORIES INC.

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 1097 2021

CONTENTS

INTRODUCTION

1	Scope	5
2	General	5
2.1	Units of measurement.....	5
2.2	Undated references	5
3	Glossary.....	5

CONSTRUCTION

4	General	7
5	Reinforced Insulation.....	8
5.1	General	8
5.2	Brush caps and brush holders	8
5.3	Commutator and end turns of the armature winding.....	9
5.4	Switches	9
5.5	Power-supply cord.....	10
5.6	Internal wiring.....	10
5.7	Other locations	11
6	Flexible Cord	11
7	Strain Relief.....	11
8	Bushings	11
9	Capacitors	12
10	Transformers	12
11	Spacings.....	12
12	Internal Wiring.....	13

PERFORMANCE

13	Leakage Current Test	14
14	Dielectric Voltage-Withstand Tests.....	17
15	Insulation Resistance Test	17
16	Resistance to Impact Tests	18
17	Overload Tests on Isolating Transformers.....	18
18	Overload Test on Motors	20
19	Abnormal Operation Test	21
20	Investigation of Armature Employing Reinforced Insulation Test.....	21
21	Moisture Resistance Test	22

MANUFACTURING AND PRODUCTION TESTS

22	Production-Line Dielectric Voltage-Withstand Test	22
----	---	----

MARKINGS

23	General	23
----	---------------	----

No Text on This Page

ULNORM.COM : Click to view the full PDF of UL 1097 2021

INTRODUCTION

1 Scope

1.1 These requirements cover electrically operated equipment marked "Double Insulation" or "Double Insulated" to be used in accordance with the National Electrical Code, ANSI/NFPA 70.

1.2 Equipment marked "Double Insulation" or "Double Insulated" shall comply with the applicable requirements in this standard and the standard covering the particular type of equipment – the end-product standard. In cases where the end-product standard contains requirements for double insulation, that standard takes precedence.

2 General

2.1 Units of measurement

2.1.1 Values stated without parentheses are the requirement. Values in parentheses are explanatory or approximate information.

2.2 Undated references

2.2.1 Any undated reference to a code or standard appearing in the requirements of this standard shall be interpreted as referring to the latest edition of that code or standard.

3 Glossary

3.1 For the purpose of this standard the following definitions apply.


3.2 **ACCESSIBLE PART or SURFACE** – A part or surface subject to contact by persons under any condition of operation or user function. In a determination of whether a live or dead part or surface is accessible to such contact, the criteria specified in the product standard are to be applied.

3.3 **BASIC INSULATION** (formerly **FUNCTIONAL INSULATION**) – The insulation applied to live parts to provide basic protection against electric shock. Basic insulation does not necessarily include insulation used exclusively for functional purposes.


3.4 **DEAD METAL PART** – A metal or other electrically conductive part, accessible or inaccessible, that is not conductively connected to a live part.

3.5 **DOUBLE INSULATION** – An insulation system comprised of basic (formerly functional) insulation and supplementary insulation, with the two insulations physically separated and arranged so that they are not simultaneously subjected to the same deteriorating influences (temperature, contaminants, and the like) to the same degree. See [Figure 3.1](#).

Figure 3.1

Examples illustrating [3.5](#)

A -- CONSIDERED TO CONSTITUTE DOUBLE INSULATION



B -- NOT CONSIDERED TO CONSTITUTE DOUBLE INSULATION.
CONSTRUCTION TO BE INVESTIGATED AS REINFORCED INSULATION.

3.6 **LIVE PART** – A part that is conductively connected either to the power-supply circuit, or a secondary circuit that operates at more than 42.4 V peak with reference to ground or accessible metal, and in which the available current measured through a 1500-ohm resistor shunted with a 0.15- μ F capacitor connected from the part to ground or to any other accessible part exceeds 0.25 mA.

3.7 **REINFORCED INSULATION** – An improved basic (formerly functional) insulation with such mechanical and electrical qualities that it, in itself, provides the same degree of protection against electric shock as double insulation. It may consist of one or more layers of insulating material. Its acceptance in place of double insulation is described in [4.1](#) and Reinforced Insulation, Section [5](#).

3.8 **SUPPLEMENTARY (PROTECTING) INSULATION** – An independent insulation provided in addition to the basic (formerly functional) insulation to protect against electric shock in case of mechanical rupture or electrical breakdown of the basic insulation. An enclosure of insulating material may form a part or the whole of the supplementary insulation.

CONSTRUCTION

4 General

4.1 The equipment shall be constructed so that double insulation is interposed between all live parts and each of the following:

- a) All accessible surfaces of the equipment;
- b) All inaccessible dead parts and surfaces that are conductively connected to accessible dead parts or surfaces or both.

Exception No. 1: A construction that provides increased through-air and over-surface spacings between live parts and accessible dead parts and surfaces specified in the end-product standard (refer to [Table 11.1](#)) is acceptable in place of double insulation. This construction may be used only where it is impractical to provide double insulation.

Exception No. 2: A construction using Reinforced Insulation, Section [5](#), is acceptable in place of double insulation. This construction may be used only where it is impractical to provide double insulation.

4.2 The thickness and the resistance to deterioration with aging of insulation employed as supplementary insulation shall not be less than that required for the same material employed as basic insulation. A greater thickness of supplementary insulation is required if severe environmental or use conditions are likely.

4.3 The insulation qualities and resistance to deterioration with aging of materials employed as reinforced insulation shall not be less than the combination of basic and supplementary insulation.

4.4 The equipment shall be constructed so that the added protection provided by the supplementary or reinforced insulation is not reduced by the normal use and reasonable abuse (see Resistance to Impact Tests, Section [16](#), and Abnormal Operation Test, Section [19](#)) to which the equipment is likely to be subjected.

4.5 The equipment shall be constructed so that the following parts are not accessible:

- a) A live part;
- b) A dead part that is insulated from live parts by basic insulation only, unless it is Reinforced Insulation, Section [5](#);

c) Basic insulation itself, unless it is Reinforced Insulation, Section 5.

4.6 The equipment shall be constructed so that all parts – straps, screws, nuts, washers, springs, and the like – are secured so that they are not likely to become loosened or displaced if such loosening or displacement reduces the spacings to values below those specified in [Table 11.1](#).

4.7 Parts secured by two independent fastenings or by means of screws or nuts provided with lock washers are to be regarded as not likely to become loose, provided that these fastening means are not required to be removed during routine servicing.

Exception: Where loosening or displacement of the part causes malfunctioning of the equipment and does not result in an accessible live part.

4.8 Leakage, rupture, or overfilling of a reservoir, pipe, tube, or the like for storing or conducting water or other fluid associated with the equipment shall not render either basic, reinforced, or supplementary insulation ineffective or result in deterioration of the insulation.

5 Reinforced Insulation

5.1 General

5.1.1 Reinforced insulation can be accepted in place of double insulation in the locations described in [5.2.1.1 – 5.7.1](#).

5.2 Brush caps and brush holders

5.2.1 General

5.2.1.1 Reinforced insulation can be accepted in an accessible brush cap or brush holder if the construction complies with each of the following:

- a) The brush cap or brush holder shall be recessed so that, when it is mounted normally, its top is inside the plane of the opening in the surrounding portion of the enclosure of the equipment.
- b) The brush cap or brush holder shall be entirely of insulating material.
- c) The brush cap or brush holder shall acceptably withstand the impact test described in [16.2](#).

5.2.2 Brush holders in enclosures of insulating material

5.2.2.1 Reinforced insulation is acceptable in place of double insulation at a brush holder assembly that is supported in the insulating-material housing of the equipment. The total insulation thickness shall not be less than 3/16 inch (4.8 mm) provided that any path between parts of the enclosure is broken by barriers or the like so that there is no direct path from the outside to live parts of the brush holder assembly.

5.2.3 Brush holders in enclosures of conductive material

5.2.3.1 Reinforced insulation is acceptable in place of double insulation at a brush holder assembly that has its own enclosure of insulating material if the construction complies with both of the following:

- a) All live parts of the brush holder assembly shall be enclosed in the enclosure of insulating material.

Exception: The wiring terminals and the brush itself need not comply with this requirement.

b) The enclosure of the brush holder assembly shall be separated from accessible dead metal parts by any one or more of the following constructions:

- 1) Mica not thinner than 0.005 inch (0.13 mm);
- 2) Other inorganic insulation having electrical properties at least equivalent to those of mica;
- 3) Acceptable organic insulating material not less than 1/16 inch (1.6 mm) thick.

5.3 Commutator and end turns of the armature winding

5.3.1 Reinforced insulation is acceptable between the commutator segments and the shaft, the end turns and the shaft, and in both locations if the insulation consists of one or more of the following:

- a) Sheet mica that is not less than 0.005 inch (0.13 mm) thick.
- b) Other inorganic insulation having electrical properties at least equivalent to those of mica. If such insulation is used under the commutator segments, the thickness of the insulation shall not be less than 0.080 inch (2.0 mm). If such insulation is used under the end turns, the thickness of the insulation shall not be less than 0.040 inch (1.02 mm) or the length of the air gap, whichever is larger.
- c) Acceptable organic insulating material provided that the armature complies with the armature-investigation tests described in the Investigation of Armature Employing Reinforced Insulation Test, Section [20](#).

5.3.2 If any of the constructions described in [5.3.1\(b\)](#) is used, the armature laminations shall be insulated from the shaft by either of the following:

- a) Sheet mica that is not less than 0.005 inch (0.13 mm) thick.
- b) Other inorganic insulation having electrical properties at least equivalent to those of mica. The insulation shall have a thickness not less than 0.040 inch (1.0 mm) or the length of the air gap, whichever is larger.

5.4 Switches

5.4.1 General

5.4.1.1 Reinforced insulation is acceptable in place of double insulation at a switch in equipment with double insulation if the switch has its own enclosure of insulating material and if the following conditions are met:

- a) A dead metal part that extends outside of the switch enclosure shall not enter the arc chamber;
- b) The plunger, toggle, or the like that contacts live parts inside the switch shall be entirely of insulating material;
- c) With the exposed external parts of the plunger, toggle, or the like removed, a live part inside the switch enclosure shall not be accessible, and a live part inside the switch shall not be contacted by a metal actuating arm, cam, or the like;
- d) All live parts of the switch other than terminals shall be completely enclosed in the switch enclosure.
- e) The construction shall comply with [5.4.2.1](#) or [5.4.3.1](#).

5.4.2 Switches in equipment enclosures of conductive material

5.4.2.1 If a switch is located in equipment that has a conductive enclosure, reinforced insulation is acceptable in place of double insulation (see also [5.4.1.1](#)) provided that both of the following conditions are met:

- a) That portion of a switch or switch enclosure that contains arcing parts, and may therefore be subjected to arcing, shall be separated from exposed dead metal of the equipment by means of not less than 0.005-inch (0.13 mm) thick mica or by other insulation having at least the equivalent electrical properties.
- b) Any metal in contact with the switch enclosure shall be insulated from the accessible dead metal of the equipment by supplementary insulation.

5.4.3 Switches in equipment enclosures of insulating material

5.4.3.1 If a switch is located in equipment that has an enclosure of insulating material, reinforced insulation is acceptable in place of double insulation provided that metal mounting screws or rivets by which the switch is secured to accessible dead metal of the equipment do not pass through the body of the switch enclosure. (See also [5.4.1.1](#).) The mounting means may pass through tabs, ears, or other projections from the switch body, including a piece of insulating material secured to the switch.

5.5 Power-supply cord

5.5.1 Reinforced insulation is acceptable in place of double insulation at points inside the equipment where the power-supply cord contacts supplementary insulation.

5.5.2 Inside the equipment, a nonjacketed power-supply cord (see [6.2](#)) or the insulated individual conductors of a jacketed supply cord may be insulated from an accessible dead metal part by supplementary insulation in any one of the following forms:

- a) An insulating liner;
- b) A coating of insulating material;
- c) A sleeve around the cord, if the sleeve is loose-fitting and is secured to the enclosure.

5.5.3 If the nonjacketed flexible cord in a power-supply cord or one or more of the insulated individual conductors of a jacketed flexible cord in a power-supply cord contacts supplementary insulation inside the equipment, the cord insulation or the individual insulation and the supplementary insulation shall be such that they are not affected to the same degree by deteriorating influences such as heat, contaminants, and the like. The flexible cord jacket itself may serve as the supplementary insulation for the insulated individual conductors provided that the conditions of use of the equipment are not likely to stress or degrade the physical properties of the jacket.

5.6 Internal wiring

5.6.1 Reinforced insulation is acceptable in place of double insulation at points inside of the equipment where the insulated wiring – including insulated splices – contacts supplementary insulation.

5.6.2 Internal wiring that has basic insulation – including an insulated splice – shall be spaced 1/32 inch (0.8 mm) from an accessible dead metal part.

5.6.3 If internal wiring that has basic insulation – including an insulated splice – contacts an enclosure of insulating material, the insulation on the wire and the enclosure of the insulating material shall be such that they are not affected to the same degree by deteriorating influences such as heat and contaminants.

5.6.4 Insulating tubing may be accepted as supplementary insulation between internal wiring that has basic insulation – including an insulated splice – and accessible dead metal parts, if all of the following conditions are met.

- a) The tubing shall be loose-fitting on the conductors.
- b) The tubing shall be fixed in position so as to prevent relative movement between the tubing and the metal.
- c) The length of the leads shall prevent any tension during assembly or repair.
- d) The tubing shall not contact sharp bends, projections, corners, or the like, nor shall it be subjected to tension or compression.
- e) The wiring shall not be subject to flexing.
- f) The materials of the tubing and the insulation on the wire shall be such that they are not affected to the same degree by deteriorating influences such as heat and contaminants.
- g) The tubing shall be of a thickness that is acceptable for the application.

5.7 Other locations

5.7.1 Reinforced insulation is acceptable in place of double insulation anywhere in the equipment if the reinforced insulation consists of one or more layers with a total thickness of not less than 3/16 inch (5 mm). In a multilayer assembly, contact between adjacent layers is acceptable.

6 Flexible Cord

6.1 A power-supply cord shall not include a grounding conductor.

6.2 A power-supply cord shall be a jacketed type.

Exception: Non-jacketed flexible cords may be investigated for use as a power-supply cord for specific equipment when the equipment standard does not require a jacketed cord.

6.3 Inside the equipment, a non-jacketed flexible cord or the insulated individual conductors of a jacketed flexible cord shall not contact an accessible dead metal part.

7 Strain Relief

7.1 If an accessible metal strain-relief clamp is employed, it shall be provided with supplementary insulation located between the clamp and the flexible cord.

8 Bushings

8.1 A bushing of insulating material shall be provided at each point at which a flexible cord passes through a dead metal part. A bushing of rubber, neoprene, polyvinyl chloride, or similar material is not acceptable for this application.

9 Capacitors

9.1 The dielectric in a capacitor shall not be depended upon as supplementary (protecting) insulation.

10 Transformers

10.1 If a secondary circuit of an isolating transformer is conductively connected to an accessible metal part or terminal or outlet for connection of circuits external to the equipment, the secondary circuit shall be considered to be accessible dead metal. The primary of the transformer shall be isolated from the secondary circuit by means of insulation that complies with the requirements described in Overload Tests on Isolating Transformers, Section [17](#).

11 Spacings

11.1 Spacings shall be in accordance with [Table 11.1](#) except that larger spacings may be required at points at which carbon dust or other conductive contaminants exist or might accumulate.


11.2 The spacing specified as the minimum acceptable in item 1 of [Table 11.1](#) does not apply to the inherent spacings of a component (such as a snap switch) of equipment. The acceptability of spacings on a component is based on the requirements for that component.

Table 11.1
Minimum spacings

Parts between which spacings are measured	Minimum acceptable spacings
1. Uninsulated live parts and dead metal parts that are separated by basic insulation only, other than reinforced insulation	Not less than the through-air and over-surface spacings required in the end-product standard
2. Accessible dead metal parts ^a and dead metal parts separated from uninsulated live parts by basic insulation only (this ordinarily is a spacing resulting from supplementary insulation)	Not less than the through-air and over-surface spacings required in the end-product standard
3. Uninsulated live parts and dead metal parts ^a separated by double insulation or by reinforced insulation, where acceptable, except as indicated in item 4	Not less than twice the through-air and over-surface spacings required in the end-product standard between uninsulated live parts and dead metal parts that are separated by basic insulation
4. Uninsulated live parts and accessible dead metal parts ^a at a commutator or other location in which foreign materials can build up	5/16 inch (8.0 mm) over surface
5. Uninsulated live parts, including enameled wire wound in the form of a coil and reliably held in place, and the interior surface of insulating material that serves as supplementary insulation	1/32 inch (0.8 mm)
6. Outer surface of a wrapped coil and the interior surface of insulation material that serves as supplementary insulation	1/32 inch (0.8 mm)

^a If the outer surface of the enclosure consists wholly or partially of insulating material, the spacings applied to accessible dead metal also apply to metal foil wrapped tightly around and in intimate contact with the enclosure. The foil is to be drawn tightly across any opening in the enclosure to form a flat plane across such opening. See [Figure 11.1](#).

Figure 11.1
Method of covering enclosure with foil for measurement and tests



SB0722

12 Internal Wiring

12.1 Internal wiring shall be located or restrained so that breakage or loosening of the wire at a termination and subsequent displacement cannot reduce the spacings to values below those specified in [Table 11.1](#).

Exception: Where breakage or loosening of the wire at a termination and subsequent displacement causes malfunctioning of the appliance and does not result in a live part being made accessible.

12.2 Compliance with [12.1](#) can be accomplished by any one or more of the following means:

- a) The use of barriers;
- b) Relative placement of parts;
- c) Physical restraint of the conductor in addition to that resulting from its normal electrical connections;
- d) Other equivalent means.

12.3 The requirement in [12.1](#) requires that a brush holder be constructed so that, upon removal of the cap, the spring cannot touch accessible dead metal.

12.4 The connection of a lead to a switch or other component likely to require replacement and the connection of a lead to a conductor of the power-supply cord shall be made so that, if the component or power-supply cord is to be replaced, it shall not be necessary to do any of the following:

- a) Cut a conductor.
- b) Disconnect a soldered and taped splice between two conductors.
- c) Disconnect a soldered joint between a lead and a bus bar, strap, or terminal.

12.5 A supplementary part, such as an insulating barrier liner, that is necessary to maintain the level of insulation shall be secured to the equipment so that it remains in place when the power-supply cord or a component, such as a switch, is being replaced.

Exception: A supplementary part need not be fixed to the equipment if its design precludes its being left out after servicing of the equipment.

PERFORMANCE

13 Leakage Current Test

13.1 The equipment shall be subjected to the leakage current test described in the end-product standard. If the end-product standard does not specify a leakage current test for double insulated equipment, the test method described in [13.2 – 13.9](#) may be used in its entirety or modified as appropriate for the specific type of end product.

13.2 For a product rated for a nominal 120/240-volt (120 volts or less to ground) or less supply, the leakage current of the equipment when tested in accordance with [13.3 – 13.9](#) shall not be more than:

- a) 0.25 mA for accessible dead metal parts;
- b) 0.5 mA for inaccessible dead metal parts; and
- c) 0.5 mA between accessible and inaccessible dead metal parts.

13.3 Equipment having parts, such as the commutator-and-brush assembly of a universal motor, that are likely to produce conductive dust is to be conditioned as described in [13.4](#) before being tested for leakage current. Equipment that is not likely to produce conductive dust is to be tested without the conditioning described in [13.4](#).

13.4 If the equipment has parts likely to produce conductive dust, it is to be operated at no load for 100 hours, or until any motor brushes wear out if the latter condition occurs at less than 100 and at more than 25 hours of operation. If the brushes wear out at less than 25 hours of operation, they are to be replaced and operation is to be continued until the appliance has operated for a total of 25 hours. Operation is to be continuous unless the motor is not for such operation.

13.5 Leakage current refers to all currents, including capacitively coupled currents, that may be conveyed from any dead metal parts, accessible and inaccessible, of the equipment to other dead metal parts of the equipment or to ground.

13.6 All accessible and inaccessible dead metal parts are to be tested for leakage currents. The leakage currents are to be measured to the grounded supply conductor individually as well as collectively and from one part to another.

Exception: If inaccessible dead metal parts such as an armature of a motor move during normal operation, measurements involving the moving parts are to be made with switch S1 (see [Figure 13.1](#)), open.

13.7 If a conductive surface other than metal is used for the enclosure or part of the enclosure, the leakage current is to be measured using metal foil with an area of 10 by 20 centimeters in contact with the

surface. Where the surface is smaller than 10 by 20 centimeters, the metal foil is to be the same size as the surface. The metal foil is not to remain in place long enough to affect the temperature of the equipment.


13.8 The measurement circuit for leakage current is to be as shown in [Figure 13.1](#). The measuring instrument is defined in (a) – (d). The meter that is actually used for a measurement need only indicate the same numerical value for a particular measurement as would the defined instrument. The meter used need not have all of the features of the defined instrument.

- a) The meter is to have an input impedance of 1500 ohms resistive shunted by a capacitance of 0.15 μ F.
- b) The meter is to indicate 1.11 times the average of the full-wave rectified composite waveform of current through the resistor.
- c) Over a frequency range 0 – 100 kHz, the measurement circuitry is to have a frequency response (ratio of indicated to actual value of current) that is equal to the ratio of the impedance of a 1500-ohm resistance shunted by a 0.15- μ F capacitor to 1500 ohms. At an indication of 0.25 or 0.5 mA, the measurement is to have an error of not more than 5 percent at 60 Hz.
- d) Unless the meter is being used to measure leakage from one part of the equipment to another, the meter is to be connected between the dead metal parts and the earth-grounded supply conductor.


13.9 The supply voltage is to be adjusted to 120, 208, or 240 V. The test sequence, with reference to the measuring circuit ([Figure 13.1](#)), is to be as follows:

- a) With switch S1 open, the equipment is to be connected to the measuring circuit. Leakage current is to be measured using both positions of switch S2, and with the equipment switching devices in all of their intended operating positions.
- b) Switch S1 is then to be closed energizing the equipment and, within a period of 5 seconds, the leakage current is to be measured using both positions of switch S2, and with the equipment switching devices in all of their normal operating positions.
- c) The leakage current is to be monitored until thermal stabilization. Both positions of switch S2 are to be used in determining this measurement. Thermal stabilization is to be obtained by operation as in the normal-temperature test in the end-product standard.


Figure 13.1
Leakage-current measurement circuit



Product intended for connection to a 120- or 240-V power supply.



Product intended for connection to a 120-V power supply.



Product intended for connection to a 3-wire, grounded-neutral power supply, as illustrated above. Represents 240- or 208-V supply.

Notes:

A – Probe with a shielded lead.

B – Separated and used as a clip when measuring currents from one part of a product to another.

ULTRON.COM. Click to view the full PDF of UL 1097-2021

14 Dielectric Voltage-Withstand Tests

14.1 The equipment shall withstand for 1 minute without breakdown the application of a 60 Hz essentially sinusoidal potential in accordance with [Table 14.1](#).

Table 14.1
Points of application and voltages for dielectric voltage-withstand test

Points between which potential is to be applied	Test potential in volts
1. Live parts and inaccessible dead metal parts	Voltage prescribed for dielectric voltage-withstand test in the end-product standard
2. Inaccessible dead metal parts and accessible dead metal parts – or for equipment with an outer enclosure of insulating material, metal foil wrapped tightly around the enclosure – see Figure 11.1	2000 V plus twice the rated voltage of the equipment
3. Accessible dead metal parts, or the foil mentioned in item 2, and metal foil in contact with the inner surfaces of insulating barriers provided to accomplish compliance with 12.1	2000 V plus twice the rated voltage of the equipment
4. Accessible dead metal parts and:	
a. Metal foil wrapped around the power-supply cord inside the inlet bushings, cord guards, strain-relief clamps, and the like or	2000 V plus twice the rated voltage of the equipment
b. A metal rod of the same cross-sectional dimensions as the cord and inserted in its place	2000 V plus twice the rated voltage of the equipment
5. Live parts and accessible dead metal parts, or the foil mentioned in item 2	3500 V plus twice the rated voltage of the equipment

15 Insulation Resistance Test

15.1 After conditioning as described in [15.4](#), the equipment shall have an insulation resistance not less than the following:

- a) Between live parts and accessible dead metal parts – 7 megohms;
- b) Between live parts and inaccessible dead metal parts – 2 megohms;
- c) Between inaccessible dead metal parts and accessible dead metal parts – 5 megohms.

15.2 For equipment having an outer enclosure consisting wholly or partly of insulating material, the term "accessible dead metal parts" used in [15.1](#) signifies metal foil tightly wrapped around the exterior of the enclosure.

15.3 If the equipment has parts that might produce conductive dust, the insulation-resistance test is to be made on the sample used for the leakage-current test.

15.4 In preparation for the test, the sample is to be conditioned at $32.0 \pm 2.0^{\circ}\text{C}$ ($91.4 \pm 3.6^{\circ}\text{F}$) for 4 hours and then placed in an enclosure for 48 hours at $20.0 - 30.0^{\circ}\text{C}$ ($68.0 - 86.0^{\circ}\text{F}$) and a relative humidity of 88 ± 2 percent. The specified relative humidity can be obtained by placing a supply of a saturated solution of potassium sulphate inside a tightly closed compartment.

15.5 The measurements of insulation resistance are to be made with the equipment still in the conditioning chamber.

15.6 In determinations of insulation resistance, a direct potential of 500 V is to be employed, and the value of insulation resistance is to be determined 1 minute after application of the test potential. An acceptable megohmmeter can be used for conducting the insulation-resistance test, or other similar means can be employed. The sample is not to be energized during this test.

15.7 Following the insulation-resistance test, and while still humidity-conditioned, the sample shall be subjected to the Dielectric Voltage-Withstand Tests, Section [14](#).

16 Resistance to Impact Tests

16.1 The equipment shall withstand the impact tests applicable to the end-product standard without resulting in any of the following:

- a) Reduction of spacings below the minimum acceptable values;
- b) Making accessible to contact live parts and dead metal parts that are insulated from live parts by only basic insulation;
- c) Breakage, cracking, rupture, or the like, that have an adverse effect on the insulation;
- d) Producing any other condition that increases the risk of electric shock from the equipment. The equipment is to comply with the dielectric voltage-withstand requirements applicable to the equipment after being subjected to the impact.

16.2 An accessible brush holder or brush cap shall withstand an impact energy of 1 pound-force·feet (1.36 J) without cracking and without exposing live parts.

16.3 The impact is to be applied by the hemispherical end of a solid, smooth, steel cylinder having a C-scale Rockwell hardness of 65 ± 5 , a diameter of 0.25 inch (6.4 mm), a length to produce a weight of 0.22 ± 0.01 pound (0.100 ± 0.004 kg), and a velocity to produce a kinetic energy of 1 pound-force·feet (1.36 J) at the time of impact. The cylinder is to fall freely or is to be suspended by cords and fall as a pendulum through the distance required to cause it to strike the surface with the specified impact energy. The point of impact and the center of gravity of the cylinder are to be in a line parallel to the direction of travel at the time of impact.

16.4 If an accessible metal switch handle, knob, operating button, or the like has an insulating cover to provide either supplementary or reinforced insulation, the insulating material shall withstand an impact of 5 pounds-force·feet (6.78 J) as specified in [16.6](#) without cracking or breaking the insulating material – or the inner layer of insulation if there is more than one layer – or dislodging the handle from its normal position.

16.5 An accessible switch handle, knob, operating button, or the like consisting entirely of insulating material shall withstand an impact of 5 pounds-force·feet (6.78 J) as specified in [16.6](#) without dislodging the handle from its normal position.

Exception: The requirement in [16.5](#) does not apply if, with the handle dislodged or broken by the impact, live parts or normally inaccessible dead metal parts are not accessible.

16.6 For the impact test in [16.4](#) and [16.5](#), a smooth steel sphere 2 inches (50.8 mm) in diameter and weighing 1.18 pounds (0.535 kg) is to be used. The sphere is to fall freely or is to be suspended by a cord and fall as a pendulum through the distance required to cause it to strike the surface with the specified impact.

17 Overload Tests on Isolating Transformers

17.1 An isolating transformer that has: